

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2486 Date Prepared : 09/03/2019
 Sample Code : S19-4389
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 08/21/2019 10:21 Date/Time Submitted : 08/21/2019 22:40
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER TANK, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 9/3/2019

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2487 Date Prepared : 09/03/2019
 Sample Code : S19-4390
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 08/21/2019 10:32 Date/Time Submitted : 08/21/2019 22:40
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/3/2019

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis