

CITY/MUNICIPALITY : BIÑAN	MONTH : April	YEAR : 2019
DOH ACCREDITATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-04-BIN

SAMPLE LOCATION				MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE	DATE COLLECTED	HPC ¹	Coliforms/100 mL ²	
				CFU/mL	TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN						
1	Laguna Well Field 1	S	5-Apr	7	ABSENCE	ABSENCE
2	Guardhouse Entrance, Phase 4C, San Jose Village I	D	6-Apr	< 1	ABSENCE	ABSENCE
3	Clubhouse, Phase 3B, San Jose Village I	D	6-Apr	< 1	ABSENCE	ABSENCE
4	Pump 11, Phase 5, San Jose Village II	S	6-Apr	3	ABSENCE	ABSENCE
5	Clubhouse, Phase 5, San Jose Village II	D	6-Apr	< 1	ABSENCE	ABSENCE
6	Clubhouse, Phase 6, San Jose Village III	D	6-Apr	< 1	ABSENCE	ABSENCE
7	Guardhouse, AVIDA Shophouse	D	6-Apr	< 1	ABSENCE	ABSENCE
8	De La Salle University and Technology Complex	D	6-Apr	< 1	ABSENCE	ABSENCE
BRGY. CANLALAY						
9	Clubhouse, Golden City Canlalay	D	11-Apr	-	ABSENCE	ABSENCE
10	Drinking Fountain, Canlalay Elementary School	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. DELA PAZ						
11	Water Pump, Almeda Subdivision	S	11-Apr	-	ABSENCE	ABSENCE
12	Barangay Hall	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. GANADO						
13	Drinking Fountain, Ganado Elementary School	D	15-Apr	< 1	ABSENCE	ABSENCE
BRGY. HALANG						
14	9999 WP Metroville Complex	S	11-Apr	-	ABSENCE	ABSENCE
15	Clubhouse, Metroville Complex	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. LANGKIWA						
16	Block 3 Lot 9, Phase II, Southville, Langkiwa	D	7-Apr	< 1	ABSENCE	ABSENCE
BRGY. LOMA						
17	Water Pump, Block 4 Lot 37, Celina Technopark	S	6-Apr	< 1	ABSENCE	ABSENCE
18	Block 43 Lot 13, Celina Technopark	D	6-Apr	4	ABSENCE	ABSENCE
19	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	8-Apr	< 1	ABSENCE	ABSENCE
20	Block 10 Lot 24, Laguna Bel-Air 3	D	8-Apr	< 1	ABSENCE	ABSENCE
21	Clubhouse, Laguna Bel-Air 3	D	8-Apr	< 1	ABSENCE	ABSENCE
22	Drinking Fountain, Loma Elementary School	D	6-Apr	< 1	ABSENCE	ABSENCE
BRGY. MAMPLASAN						
23	Clubhouse, Verdana Homes Subdivision	D	6-Apr	1	ABSENCE	ABSENCE
24	United Laboratories (UNILAB) Inc.	D	15-Apr	8	ABSENCE	ABSENCE
BRGY. POBLACION						
25	Water Pump, Brgy. Poblacion	S	6-Apr	< 1	ABSENCE	ABSENCE
26	Brgy. Hall	D	6-Apr	21	ABSENCE	ABSENCE
BRGY. PLATERO						
27	Elevated Water Tank, Mondo Bambini	S	9-Apr	-	PRESENCE	ABSENCE
28	Clubhouse, Mondo Bambini	D	9-Apr	-	ABSENCE	ABSENCE
29	Elevated Water Tank, Prima Casa	S	9-Apr	-	ABSENCE	ABSENCE
30	Clubhouse, Prima Casa	D	9-Apr	-	ABSENCE	ABSENCE
31	Water Pump, Spring Time	S	9-Apr	-	ABSENCE	ABSENCE
32	Block 1 Lot 7, Spring Time	D	9-Apr	-	ABSENCE	ABSENCE


33	Drinking Fountain, St. Michael School of Biñan	D	15-Apr	8	ABSENCE	ABSENCE
34	Sea-oil, National Road	D	15-Apr	< 1	ABSENCE	ABSENCE
BRGY. SAN ANTONIO						
35	Biñan City Hall	S	15-Apr	< 1	ABSENCE	ABSENCE
36	Alonte Stadium	D	15-Apr	< 1	ABSENCE	ABSENCE
37	Water Pump, Margarita Homes Subdivision	S	15-Apr	< 1	ABSENCE	ABSENCE
38	Block 5 Lot 12, Margarita Homes Subdivision	D	15-Apr	1	ABSENCE	ABSENCE
39	9022 Water Pump (WP) Faraon Subdivision	S	11-Apr	-	ABSENCE	ABSENCE
40	Malaban Health Center	D	11-Apr	-	ABSENCE	ABSENCE
41	Drinking Fountain 1, Malaban Elementary School	D	11-Apr	-	ABSENCE	ABSENCE
42	Drinking Fountain 2, Malaban Elementary School	D	11-Apr	-	ABSENCE	ABSENCE
43	Cistern Tank, Pavillion Mall	D	15-Apr	< 1	ABSENCE	ABSENCE
44	Mesa Inasal, Pavillion Mall	D	15-Apr	< 1	ABSENCE	ABSENCE
BRGY. SANTO NIÑO						
45	Jollibee National Hi-Way	D	15-Apr	16	ABSENCE	ABSENCE
BRGY. SAN VICENTE						
46	Block 8 Lot 6, Bayabas St., Phase 8 Olivarez Homes	D	7-Apr	< 1	ABSENCE	ABSENCE
47	Biñan Doctors Hospital	D	15-Apr	< 1	ABSENCE	ABSENCE
47	Cistern Tank, Central Mall	D	7-Apr	< 1	ABSENCE	ABSENCE
	Drinking Fountain, San Vicente Elementary Sch.	D	7-Apr	< 1	ABSENCE	ABSENCE
48	Biñan Intergrated National High School	D	6-Apr	< 1	ABSENCE	ABSENCE
BRGY. SANTO TOMAS						
49	HOA Office, Adelina Subdivsion	S	15-Apr	< 1	ABSENCE	ABSENCE
50	Block 1 Lot 16, Phase 4, Olivarez Homes South	D	7-Apr	< 1	ABSENCE	ABSENCE
51	Water Pump, Pragmatic	S	7-Apr	< 1	ABSENCE	ABSENCE
52	Block 1 Lot 5, Bais St., Pragmatic	D	7-Apr	< 1	ABSENCE	ABSENCE
53	Tawi Tawi St., Phase 6, South City Homes	D	7-Apr	< 1	ABSENCE	ABSENCE
54	Pump, South Plains II Subdivision	S	7-Apr	< 1	ABSENCE	ABSENCE
55	Block 11 Lot 2, South Plains II Subdivision	D	7-Apr	< 1	ABSENCE	ABSENCE
56	Block 35 Lot 21, Southville Town and Country	D			ABSENCE	ABSENCE
57	Water Pump, Town & Country - Amsterdam	S	7-Apr	< 1	ABSENCE	ABSENCE
58	Block 35 Lot 21, Town & Country - Amsterdam	D	7-Apr	< 1	ABSENCE	ABSENCE
59	Block 2 Lot 5, Town & Country - Pennsylvania	D	7-Apr	< 1	ABSENCE	ABSENCE
BRGY. SORO - SORO						
60	9067 Soro-soro	S	11-Apr	-	ABSENCE	ABSENCE
61	#76 Soro-Soro	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. TUBIGAN						
62	#60 Florinda Compound	D	7-Apr	< 1	ABSENCE	ABSENCE
BRGY. ZAPOTE						
63	Wate Pump, Summer Breeze	S	9-Apr	-	ABSENCE	ABSENCE
64	Clubhouse, Summer Breeze	D	9-Apr	-	ABSENCE	ABSENCE
65	Elevated Water Tank, Evergreen	S	9-Apr	-	ABSENCE	ABSENCE
66	Clubhouse, Evergreen	D	9-Apr	-	ABSENCE	ABSENCE
67	Clubhouse, Althea	D	15-Apr	28	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		67	PNSDW LIMIT	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:



CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161



LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CABUYAO	MONTH : April	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-04-CAB

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹ CFU/mL	Coliforms/100 mL ²	
					TOTAL	<i>Escherichia coli</i>
BRGY. BANAY-BANAY						
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	6-Apr	-	ABSENCE	ABSENCE
2	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	D	6-Apr	-	ABSENCE	ABSENCE
BRGY. BANLIC						
3	Water Pump, Gran Seville Subdivision	S	8-Apr	< 1	ABSENCE	ABSENCE
4	Gate Entrance, Gran Seville Subdivision	D	8-Apr	< 1	ABSENCE	ABSENCE
BRGY. BIGAA						
5	#253 Elsol Subdivision	D	6-Apr	-	ABSENCE	ABSENCE
BRGY. GULOD						
6	Block 12, Noah St., Celestine Ville	S	4-Apr	< 1	ABSENCE	ABSENCE
7	Guardhouse, Celestine Ville	D	4-Apr	< 1	ABSENCE	ABSENCE
BRGY. MARINIG						
8	Block 3 Lot 17, Phase 1, Celestine Homes	S	6-Apr	-	ABSENCE	ABSENCE
9	Block 23, Lot 10, Phase 1, Celestine Homes	D	6-Apr	-	ABSENCE	ABSENCE
10	Block 9, Carnation St., Phase 2, Celestine Homes	S	6-Apr	-	ABSENCE	ABSENCE
11	Block 13 Lot 2, Phase 2, Celestine Homes	D	6-Apr	-	ABSENCE	ABSENCE
BRGY. NIUGAN						
12	Water Pump, Block 25, Phase 3, Southville	S	6-Apr	-	ABSENCE	ABSENCE
13	Block 19 Lot 33, Phase 3, Southville	D	6-Apr	-	ABSENCE	ABSENCE
14	Block 2 Lot 6, St. Francis Homes 6	D	6-Apr	-	ABSENCE	ABSENCE
15	Water Pump, Block 45, Phase 8, Southville	S	6-Apr	-	ABSENCE	ABSENCE
16	Block 40 Lot 132, Southville	D	6-Apr	-	ABSENCE	ABSENCE
17	Water Pump, Block 54, Phase 10, Southville	S	6-Apr	-	ABSENCE	ABSENCE
18	Block 47 Lot 101, Phase 10, Southville	D	6-Apr	-	ABSENCE	ABSENCE
BRGY. SAN ISIDRO						
19	Block 3 Lot 33, Multiland IV	D	8-Apr	< 1	ABSENCE	ABSENCE
20	Water Pump, San Isidro Heights Subdivision	S	8-Apr	< 1	ABSENCE	ABSENCE
21	Block 3 Lot 1, San Isidro Heights Subdivision	D	8-Apr	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		21	PNSDW	< 1	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:

ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:

CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

CITY/MUNICIPALITY : CABUYAO	MONTH : April	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-04-CAB


NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹	Coliforms/100 mL ²	
				CFU/mL	TOTAL	<i>Escherichia coli</i>
BRGY. MAMATID						
1	Tank, Buena Rosario Subdivision	S	4-Apr	< 1	ABSENCE	ABSENCE
2	Block 7 Lot 6, Buena Rosario Subdivision	D	4-Apr	< 1	ABSENCE	ABSENCE
3	Block 101 Samar st., Phase 2, Mabuhay City	S	4-Apr	< 1	ABSENCE	ABSENCE
4	Block 94 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	4-Apr	9	ABSENCE	ABSENCE
5	Block 141, Carmona St., Phase 2, Mabuhay City	S	4-Apr	< 1	ABSENCE	ABSENCE
6	Block 134 Lot 22, Phase 2, Mabuhay City	D	4-Apr	1	ABSENCE	ABSENCE
7	Block 198, Galacia St., Phase 2, Mabuhay City	S	4-Apr	3	ABSENCE	ABSENCE
8	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	D	4-Apr	< 1	ABSENCE	ABSENCE
9	Panganig St., Phase 3 Cluster, Mabuhay City	S	8-Apr	< 1	ABSENCE	ABSENCE
10	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	8-Apr	< 1	ABSENCE	ABSENCE
11	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	4-Apr	3	ABSENCE	ABSENCE
12	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	D	4-Apr	< 1	ABSENCE	ABSENCE
13	Water Pump, Joshua St., Phase 5, Mabuhay City	S	8-Apr	< 1	ABSENCE	ABSENCE
14	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	8-Apr	< 1	ABSENCE	ABSENCE
15	Source, Phase 1E Mabuhay Executive	S	4-Apr	2	ABSENCE	ABSENCE
16	Block 236 Lot 9, Phase 1E Mabuhay Executive	D	4-Apr	< 1	ABSENCE	ABSENCE
BRGY. PULO						
17	Water Pump, Block 12 Lot 22, Cabuyao Central	S	8-Apr	5	ABSENCE	ABSENCE
18	Clubhouse, Narra Avenue, Cabuyao Central	D	8-Apr	< 1	ABSENCE	ABSENCE
19	Water Pump, Block 11, Willow Park Homes	S	8-Apr	< 1	ABSENCE	ABSENCE
20	Clubhouse, Willow Park Homes	D	8-Apr	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		20	PNSDW	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

CITY/MUNICIPALITY : SANTA ROSA	MONTH : April	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-04-STR


NO	ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹ CFU/mL	Coliforms/100 mL ²	
					TOTAL	<i>Escherichia coli</i>
BRGY. CAINGIN						
1	Water Pump, Block 57, Phase 1, Southville	S	11-Apr	-	ABSENCE	ABSENCE
2	Block 25 Lot 7, Phase 3, Southville	D	11-Apr	-	ABSENCE	ABSENCE
4	Phase 8 & 9, Southville	S	11-Apr	-	ABSENCE	ABSENCE
5	Block 2 Lot 16, Phase 9, Southville	D	11-Apr	-	ABSENCE	ABSENCE
6	Water Pump, Phase 5, Southville	s	11-Apr	-	ABSENCE	ABSENCE
7	Southville National High School, Southville	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. KANLURAN						
8	#621 Rizal Boulevard	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. LABAS						
9	Block 18 Lot 2, Alfonso Homes I	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. MALUSAK						
10	Drinking Fountain 1, Central 1 Elementary Sch.	D	11-Apr	-	ABSENCE	ABSENCE
11	Drinking Fountain, Santa Rosa City Hall	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. MARKET AREA						
12	Source, Market Area	S	11-Apr	-	ABSENCE	ABSENCE
BRGY. SINALHAN						
13	Block 8 Lot 16, Bayshore III	D	11-Apr	-	ABSENCE	ABSENCE
14	4026, Sinalhan Road, Purok 2	S	11-Apr	-	ABSENCE	ABSENCE
15	Amoranto Compund, Phase 2, Sinalhan	D	11-Apr	-	ABSENCE	ABSENCE
BRGY. TAGAPO						
16	Water Pump, Fairfield of Margana Subdivision	S	7-Apr	< 1	ABSENCE	ABSENCE
17	Block 2 Lot 21, Fairfield of Margana Subdivision	D	7-Apr	< 1	ABSENCE	ABSENCE
18	Water Pump, Rosewood Homes I	S	7-Apr	< 1	ABSENCE	ABSENCE
19	Block 3 Lot 31, Rosewood Homes I	D	7-Apr	< 1	ABSENCE	ABSENCE
20	Block 4 Lot 1, Rosewood Homes II	D	7-Apr	< 1	ABSENCE	ABSENCE
21	#31 JP Rizal Boulevard	D	7-Apr	< 1	ABSENCE	ABSENCE
22	Clubhouse, Buena Rosa 1 Subdivision	D	7-Apr	< 1	ABSENCE	ABSENCE
23	Water Pump, Buena Rosa 10 Subdivision	S	7-Apr	< 1	ABSENCE	ABSENCE
24	Block 1 Lot 64, Buena Rosa 10 Subdivision	D	7-Apr	< 1	ABSENCE	ABSENCE
25	Cistern Tank, SM Sta. Rosa	D	7-Apr	< 1	ABSENCE	ABSENCE
26	2nd Floor Faucet, SM Sta. Rosa	D	7-Apr	< 1	ABSENCE	ABSENCE
27	Cistern Tank, Robinson's Mall	D	7-Apr	2	ABSENCE	ABSENCE
28	Chummie Shawarma, Robinson's Mall	D	7-Apr	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			28	PNSDW	<500	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Collert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

CITY/MUNICIPALITY : SANTA ROSA	MONTH : April	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-04-STR

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹ CFU/mL	Coliforms/100 mL ²	
					TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO						
1	#1354 Facundo Compound	D	7-Apr	< 1	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	S	15-Apr	< 1	ABSENCE	ABSENCE
3	Clubhouse, South Hampton	D	15-Apr	< 1	ABSENCE	ABSENCE
4	Block 5 Lot 19, JB Village, Sta. Rosa Tagaytay Road	D	4-Apr	23	ABSENCE	ABSENCE
BRGY. DILA						
5	Phase 3E, Mabuhay Homes 2000	S	4-Apr	< 1	ABSENCE	ABSENCE
6	Block 2 Lot 10, Mabuhay Homes 2000	D	4-Apr	< 1	ABSENCE	ABSENCE
7	Block 12, Phase 2E, Mabuhay Homes 2000	S	4-Apr	< 1	ABSENCE	ABSENCE
8	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	4-Apr	< 1	ABSENCE	ABSENCE
9	Drinking Fountain, Dila Elementary School	D	4-Apr	< 1	ABSENCE	ABSENCE
BRGY. DITA						
10	Block 24 Lot 2, New Santa Rosa Homes	S	4-Apr	6	ABSENCE	ABSENCE
11	Block 19 Lot 11, New Santa Rosa Homes	D	4-Apr	< 1	ABSENCE	ABSENCE
12	Block 4 Lot 32, San Lorenzo Royale	S	15-Apr	14	ABSENCE	ABSENCE
13	Block 11 Lot 52, San Lorenzo Royale	D	15-Apr	< 1	ABSENCE	ABSENCE
14	Water Tank, SolCar Ville Subdivision	S	4-Apr	1	ABSENCE	ABSENCE
15	Block 3 Lot 7, SolCar Ville Subdivision	D	4-Apr	< 1	ABSENCE	ABSENCE
16	Clubhouse, Villa Esmeralda	D	15-Apr	< 1	ABSENCE	ABSENCE
17	#1780 National Road	D	4-Apr	< 1	ABSENCE	ABSENCE
18	R & B Ice Plant, Inc.	D			ABSENCE	ABSENCE
19	Science HighSchool, Phase 1, Laguna Bel-Air	D	8-Apr	< 1	ABSENCE	ABSENCE
20	56 Cypress, Laguna Bel-Air	D	8-Apr	< 1	ABSENCE	ABSENCE
21	Church, Block 108, Phase 5, Laguna Bel-Air	D	8-Apr	< 1	ABSENCE	ABSENCE
22	Block 47 Lot 12 Laguna Bel-Air IV	D	8-Apr	< 1	ABSENCE	ABSENCE
23	8001, Pump 1, Acacia St., Santa Rosa Village I	S	8-Apr	< 1	ABSENCE	ABSENCE
24	Clubhouse. Phase 4B, Santa Rosa Village I	D	8-Apr	< 1	ABSENCE	ABSENCE
25	Clubhouse, Santa Rosa Village II	D	8-Apr	< 1	ABSENCE	ABSENCE
26	Pump 9 & 10, Santa Rosa Estates I	S	8-Apr	< 1	ABSENCE	ABSENCE
27	Clubhouse Santa Rosa Estates I	D	8-Apr	< 1	ABSENCE	ABSENCE
BRGY. DON JOSE						
28	Drinking Fountain, Don Jose National High School	D	8-Apr	< 1	ABSENCE	ABSENCE
BRGY. MACABLING						
29	Deepwell, Buena Rosa 9 Subdivision	S	7-Apr	64	ABSENCE	ABSENCE
30	Block 4 Lot 26, Phase 2, Buena Rosa 9 Subdivision	D	7-Apr	170	ABSENCE	ABSENCE
31	Deepwell, Corinthian Subdivision	S	7-Apr	< 1	ABSENCE	ABSENCE
32	Block 11 Lot 19, Corinthian Subdivision	D	7-Apr	< 1	ABSENCE	ABSENCE
33	Water Pump, Metrogate	S	4-Apr	< 1	ABSENCE	ABSENCE
34	Clubhouse, Metrogate	D	4-Apr	< 1	ABSENCE	ABSENCE
BRGY. MALITLIT						
35	Clubhouse Casan Residencia Subdivision	D	4-Apr	< 1	ABSENCE	ABSENCE
36	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	15-Apr	< 1	ABSENCE	ABSENCE


37	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	15-Apr	1	ABSENCE	ABSENCE
38	Main Road, Phase 2, Terra Fortuna	S	15-Apr	< 1	ABSENCE	ABSENCE
39	Block 11 Lot 16, Terra Fortuna	D	15-Apr	< 1	ABSENCE	ABSENCE
40	9999 W, Villa Las Casas	S	15-Apr	< 1	ABSENCE	ABSENCE
41	Block 1 Lot 17, Villa Las Casas	D	15-Apr	3	ABSENCE	ABSENCE
42	Drinking Fountain, Malitlit Elementary School	D	4-Apr	5	ABSENCE	ABSENCE
43	Blowoff, Eton City	D	8-Apr	< 1	ABSENCE	ABSENCE
BRGY. POOC						
44	Deepwell, Alinsod	S	11-Apr	-	ABSENCE	ABSENCE
45	Tank, Villa Mercedes	S	11-Apr	-	PRESENCE	ABSENCE
46	Block 2 Lot 1, Villa Mercedes	D	11-Apr	-	ABSENCE	ABSENCE
47	Drinking Fountain 1, Pulong Sta. Cruz Elementary Sch.	D	15-Apr	< 1	ABSENCE	ABSENCE
48	Drinking Fountain 2, Pulong Sta. Cruz Elementary Sch.	D	15-Apr	24	ABSENCE	ABSENCE
49	Block 6 Lot 8, Buklod Diwa	D	15-Apr	8	ABSENCE	ABSENCE
BRGY. SANTO DOMINGO						
50	Clubhouse Santa Rosa Estates II	D	8-Apr	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		50	PNSDW LIMIT	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1164 Date Issued : 05/06/2019
 Sample Code : S19-1802 Document Number : 19-WQM-04-ALA-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 18:17 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER TANK, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	11	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 05/11/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1165 Date Issued : 05/06/2019
 Sample Code : S19-1803 Document Number : 19-WQM-04-ALA-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 17:48 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	6	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 05/11/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1194 Date Issued : 05/06/2019
 Sample Code : S19-1791 Document Number : 19-WQM-04-CAL-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 12:44 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	8	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1195 Date Issued : 05/06/2019
 Sample Code : S19-1792 Document Number : 19-WQM-04-CAL-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 12:57 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1196 Date Issued : 05/06/2019
 Sample Code : S19-1793 Document Number : 19-WQM-04-CAL-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 13:12 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 07/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1197 Date Issued : 05/06/2019
 Sample Code : S19-1794 Document Number : 19-WQM-04-CAL-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 12:14 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	5	9215B. Pour Plate Method	04/09/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1198 Date Issued : 05/06/2019
 Sample Code : S19-1795 Document Number : 19-WQM-04-CAL-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 12:22 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1199 Date Issued : 05/06/2019
 Sample Code : S19-1796 Document Number : 19-WQM-04-CAL-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 11:57 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1200 Date Issued : 05/06/2019
 Sample Code : S19-1797 Document Number : 19-WQM-04-CAL-07
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/09/2019 12:06 Date/Time Submitted : 04/09/2019 15:52
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/09/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1166 Date Issued : 05/06/2019
 Sample Code : S19-1804 Document Number : 19-WQM-04-PAB-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 16:48 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/10/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1167 Date Issued : 05/06/2019
 Sample Code : S19-1805 Document Number : 19-WQM-04-PAB-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 16:53 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : CLUBHOUSE, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1168 Date Issued : 05/06/2019
 Sample Code : S19-1808 Document Number : 19-WQM-04-PAB-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:51 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1169 Date Issued : 05/06/2019
 Sample Code : S19-1809 Document Number : 19-WQM-04-PAB-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:58 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 65 LOT 2, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/11/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1172 Date Issued : 05/06/2019
 Sample Code : S19-1810 Document Number : 19-WQM-04-STC-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:16 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : SOURCE, AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	14	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1173 Date Issued : 05/06/2019
 Sample Code : S19-1811 Document Number : 19-WQM-04-STC-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:29 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	2	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1174 Date Issued : 05/06/2019
 Sample Code : S19-1812 Document Number : 19-WQM-04-STC-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:30 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1175 Date Issued : 05/06/2019
 Sample Code : S19-1813 Document Number : 19-WQM-04-STC-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:52 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1176 Date Issued : 05/06/2019
 Sample Code : S19-1814 Document Number : 19-WQM-04-STC-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:42 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : LAGUNA MEDICAL CENTER, LAGUNA, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	13	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1177 Date Issued : 05/06/2019
 Sample Code : S19-1815 Document Number : 19-WQM-04-PAG-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 12:19 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1178 Date Issued : 05/06/2019
Sample Code : S19-1816 Document Number : 19-WQM-04-PAG-02
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 04/10/2019 12:26 Date/Time Submitted : 04/10/2019 21:30
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : RESERVOIR, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA


PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/1/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1179 Date Issued : 05/06/2019
 Sample Code : S19-1817 Document Number : 19-WQM-04-PAG-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:34 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : PUMP STATION #5, POBLACION 2, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 05/10/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1180 Date Issued : 05/06/2019
 Sample Code : S19-1818 Document Number : 19-WQM-04-PAG-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:43 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : COSME ST., BRGY. DOS, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1181 Date Issued : 05/06/2019
 Sample Code : S19-1819 Document Number : 19-WQM-04-PAG-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:48 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : MABINI ST., BRGY. DOS, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/11/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1182 Date Issued : 05/06/2019
 Sample Code : S19-1820 Document Number : 19-WQM-04-PAG-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 13:57 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PUMP STATION #4, BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1183 Date Issued : 05/06/2019
 Sample Code : S19-1821 Document Number : 19-WQM-04-PAG-07
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:06 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1184 Date Issued : 05/06/2019
 Sample Code : S19-1822 Document Number : 19-WQM-04-PAG-08
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:13 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CHRISTIAN GENERAL HOSPITAL, BRGY. POBLACION I, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1185 Date Issued : 05/06/2019
 Sample Code : S19-1823 Document Number : 19-WQM-04-PAG-09
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:30 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : PUMP STATION #7, BRGY. CUBAO, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1186 Date Issued : 05/06/2019
Sample Code : S19-1824 Document Number : 19-WQM-04-PAG-10
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 04/10/2019 14:42 Date/Time Submitted : 04/10/2019 21:30
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : SITIO BRGY. CUBAO, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1187 Date Issued : 05/06/2019
 Sample Code : S19-1825 Document Number : 19-WQM-04-PAG-11
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 14:54 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : PUMP STATION #2, PINAGSANGAN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1188 Date Issued : 05/06/2019
 Sample Code : S19-1826 Document Number : 19-WQM-04-PAG-12
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:14 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : EMIL'S PANSITAN, PINAGSANGAN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1189 Date Issued : 05/06/2019
 Sample Code : S19-1827 Document Number : 19-WQM-04-PAG-13
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:27 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : E. AQUINO STREET, BRGY. MAULAWIN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1190 Date Issued : 05/06/2019
 Sample Code : S19-1828 Document Number : 19-WQM-04-PAG-14
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:38 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : GEN LUNA STREET, BRGY. MAULAWIN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1191 Date Issued : 05/06/2019
 Sample Code : S19-1829 Document Number : 19-WQM-04-PAG-15
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 15:54 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : GATABAN APARTMENT, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/7/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1192 Date Issued : 05/06/2019
 Sample Code : S19-1830 Document Number : 19-WQM-04-PAG-16
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 16:14 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : SITIO DOS, BRGY. BUBOY, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	8	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1193 Date Issued : 05/06/2019
 Sample Code : S19-1831 Document Number : 19-WQM-04-PAG-17
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 16:42 Date/Time Submitted : 04/10/2019 21:30
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PAGWAD OFFICE, J.P RIZAL ST., BRGY. DOS, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1170 Date Issued : 05/06/2019
 Sample Code : S19-1806 Document Number : 19-WQM-04-VIC-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 12:31 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, BRGY. NANHAYA, VICTORIA, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	420	9215B. Pour Plate Method	04/10/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1171 Date Issued : 05/06/2019
 Sample Code : S19-1807 Document Number : 19-WQM-04-VIC-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 04/10/2019 12:35 Date/Time Submitted : 04/10/2019 19:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : 22 REBONG ST., BRGY. NANHAYA, VICTORIA, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	2	9215B. Pour Plate Method	04/10/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis