

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 77

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 01/12/2023-01/20/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
01/16/2023 15:28	S23-0160	Laguna Wellfield 1	ABSENCE	ABSENCE	8
01/20/2023 15:40	S23-0286	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	(-)
01/20/2023 15:29	S23-0287	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	(-)
01/20/2023 15:18	S23-0288	Pump 11, Phase 5, San Jose Village II	ABSENCE	ABSENCE	(-)
01/20/2023 15:10	S23-0289	Clubhouse, Phase 5, San Jose Village II	ABSENCE	ABSENCE	(-)
01/20/2023 15:01	S23-0290	Clubhouse, Phase 6, San Jose Village III	ABSENCE	ABSENCE	(-)
01/20/2023 16:16	S23-0291	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	(-)
01/20/2023 16:10	S23-0292	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	(-)
BRGY. CANLALAY					
01/16/2023 10:29	S23-0145	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
01/16/2023 10:39	S23-0146	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
01/16/2023 10:00	S23-0151	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	3
BRGY. GANADO					
01/17/2023 12:25	S23-0197	Ganado Elementary School	ABSENCE	ABSENCE	1
BRGY. HALANG					
01/16/2023 11:05	S23-0141	9999 Water Pump Metroville Complex	ABSENCE	ABSENCE	2
01/16/2023 11:23	S23-0142	Block 31 Lot 19, Metroville Complex	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA					
01/18/2023 13:10	S23-0217	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/20/2023 13:49	S23-0296	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	(-)
01/20/2023 13:30	S23-0297	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	(-)
BRGY. LOMA					
01/20/2023 14:32	S23-0293	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	(-)
01/20/2023 13:51	S23-0307	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	(-)
01/20/2023 14:02	S23-0308	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	(-)
01/20/2023 14:48	S23-0295	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	(-)
BRGY. MAMPLASAN					
01/19/2023 16:56	S23-0282	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
01/17/2023 11:59	S23-0198	Amherst Laboratories, (UNILAB) Inc.	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
01/16/2023 09:37	S23-0152	Barangay Hall	ABSENCE	ABSENCE	2
BRGY. PLATERO					
01/12/2023 09:42	S23-0096	Elevated Water Tank, Mondo Bambini	ABSENCE	ABSENCE	2
01/12/2023 09:58	S23-0097	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	< 1
01/12/2023 11:43	S23-0098	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	7
01/12/2023 11:57	S23-0099	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
01/13/2023 11:24	S23-0111	Water Pump, Springtime	ABSENCE	ABSENCE	< 1
01/12/2023 14:25	S23-0101	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	9
01/17/2023 10:19	S23-0200	Sea-oil, National Road	ABSENCE	ABSENCE	4
01/17/2023 10:10	S23-0202	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	< 1
01/12/2023 10:58	S23-0105	Water Pump, Jubilation Village - East	ABSENCE	ABSENCE	1
01/12/2023 11:10	S23-0106	Clubhouse, Jubilation Village - East	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN ANTONIO					
01/17/2023 13:02	S23-0208	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
01/17/2023 12:51	S23-0209	Alonte Stadium	ABSENCE	ABSENCE	3
01/17/2023 10:42	S23-0203	Water Pump, Margarita Homes Subdivision	ABSENCE	ABSENCE	< 1
01/17/2023 10:56	S23-0204	Block 1 Lot 12, Margarita Homes	ABSENCE	ABSENCE	< 1
01/16/2023 08:38	S23-0147	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
01/16/2023 08:20	S23-0153	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	< 1
01/17/2023 11:24	S23-0205	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	17
01/17/2023 11:31	S23-0206	Bonchon, Pavilion Mall	ABSENCE	ABSENCE	7
01/16/2023 09:20	S23-0148	Malaban Health Center	ABSENCE	ABSENCE	< 1
01/16/2023 09:08	S23-0149	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	5
01/16/2023 09:00	S23-0150	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO					
01/17/2023 11:37	S23-0207	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE					
01/18/2023 12:52	S23-0216	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	< 1
01/18/2023 13:18	S23-0218	Drinking Fountain, San Vicente Elementary School	ABSENCE	ABSENCE	< 1
01/18/2023 13:40	S23-0219	Block 8 Lot 6 Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	1
01/18/2023 13:30	S23-0220	Cistern Tank, Central Mall	ABSENCE	ABSENCE	< 1
01/17/2023 09:39	S23-0201	Biñan Doctor's Hospital	ABSENCE	ABSENCE	7
BRGY. SANTO TOMAS					
01/17/2023 13:34	S23-0199	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	< 1
01/18/2023 11:21	S23-0226	Water Pump, Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
01/18/2023 11:28	S23-0227	Block 1 Lot 5, Bais St., Pragmatic	ABSENCE	ABSENCE	< 1
01/17/2023 13:48	S23-0211	HOA Office, Adelina Complex	ABSENCE	ABSENCE	< 1
01/18/2023 12:40	S23-0215	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	1
01/18/2023 12:20	S23-0213	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
01/18/2023 12:33	S23-0214	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/18/2023 10:45	S23-0221	Water Pump, Town & Country, Amsterdam St.	ABSENCE	ABSENCE	< 1
01/18/2023 10:24	S23-0222	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
01/18/2023 12:10	S23-0223	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
01/18/2023 10:59	S23-0224	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
01/18/2023 11:10	S23-0225	Blk 1 Lt 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO					
01/16/2023 11:50	S23-0143	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
01/16/2023 11:46	S23-0144	#76 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
01/20/2023 13:59	S23-0298	Water Pump, San Antonio South	ABSENCE	ABSENCE	(-)
01/20/2023 14:10	S23-0299	Block 3 Lot 23, San Antonio South	ABSENCE	ABSENCE	(-)
BRGY. ZAPOTE					
01/12/2023 08:24	S23-0092	Water Pump, Summer Breeze	ABSENCE	ABSENCE	< 1
01/13/2023 10:25	S23-0110	Guardhouse Entrance, Summer Breeze	ABSENCE	ABSENCE	< 1
01/12/2023 09:00	S23-0094	Elevated Water Tank, Evergreen	ABSENCE	ABSENCE	3
01/12/2023 09:14	S23-0095	Clubhouse, Evergreen	ABSENCE	ABSENCE	2
01/12/2023 10:29	S23-0103	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	4
01/12/2023 10:44	S23-0104	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	< 1
01/12/2023 15:05	S23-0102	Clubhouse, Jubilation Village - West	ABSENCE	ABSENCE	99
01/12/2023 14:89	S23-0107	Water Pump, Jubilation Village-West	ABSENCE	ABSENCE	< 1
01/17/2023 13:12	S23-0210	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)