

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 73

TOTAL PARAMETERS TESTED: 3


ANALYSIS DATE(S) : 06/03/2025-06/13/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
06/11/2025 13:57	S25-3843	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
06/18/2025 13:29	S25-4007	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
06/18/2025 13:16	S25-4008	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
06/18/2025 11:38	S25-4009	Pump 11, Phase 5, San Jose Village II	ABSENCE	ABSENCE	6
06/18/2025 11:55	S25-4010	Clubhouse, Phase 5, San Jose Village II	ABSENCE	ABSENCE	12
06/18/2025 11:15	S25-4011	Clubhouse, Phase 6, San Jose Village III	ABSENCE	ABSENCE	< 1
06/18/2025 13:01	S25-4012	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	4
06/18/2025 12:20	S25-4013	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
06/09/2025 13:26	S25-3738	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
06/09/2025 13:45	S25-3739	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	3
BRGY. HALANG					
06/09/2025 14:31	S25-3734	9999 Water Pump, Metroville Complex	ABSENCE	ABSENCE	< 1
06/09/2025 14:17	S25-3735	Clubhouse, Metroville Complex	ABSENCE	ABSENCE	< 1
BRGY. GANADO					
06/03/2025 09:38	S25-3590	Ganado Elementary School	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
06/09/2025 11:56	S25-3744	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LANGKIWA					
06/18/2025 09:29	S25-4020	Water Pump, Southville 5A	ABSENCE	ABSENCE	5
06/18/2025 09:16	S25-4017	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	< 1
06/18/2025 09:38	S25-4018	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
06/17/2025 12:42	S25-3950	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
BRGY. LOMA					
06/18/2025 10:19	S25-4014	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
06/11/2025 12:44	S25-3826	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
06/11/2025 12:32	S25-3827	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	<1
06/18/2025 10:28	S25-4016	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN					
06/18/2025 10:42	S25-4015	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
06/10/2025 13:11	S25-3767	Amherst Laboratory (UNILAB)	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
06/24/2025 10:38	S25-4191	Barangay Hall	ABSENCE	ABSENCE	6
BRGY. PLATERO					
06/17/2025 12:20	S25-3979	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	< 1
06/17/2025 13:50	S25-3981	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
06/17/2025 13:38	S25-3980	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
06/17/2025 14:05	S25-3982	Water Pump, Springtime	ABSENCE	ABSENCE	< 1
06/17/2025 14:27	S25-3983	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	41
06/03/2025 11:31	S25-3593	Sea-oil, National Road	ABSENCE	ABSENCE	< 1
06/03/2025 11:21	S25-3595	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	24
BRGY. SAN ANTONIO					
06/10/2025 12:18	S25-3765	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
06/10/2025 12:27	S25-3766	Alonte Stadium	ABSENCE	ABSENCE	< 1
06/03/2025 11:49	S25-3596	Block 12 Lot 3, Margarita Homes	ABSENCE	ABSENCE	40
06/09/2025 10:38	S25-3740	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	46
06/09/2025 11:10	S25-3746	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	60
06/03/2025 10:25	S25-3597	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
06/03/2025 10:24	S25-3598	Maja, Pavilion Mall	ABSENCE	ABSENCE	6
06/09/2025 10:13	S25-3741	Malaban Health Center	ABSENCE	ABSENCE	49

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
06/09/2025 10:01	S25-3742	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	< 1
06/09/2025 09:52	S25-3743	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO					
06/03/2025 10:57	S25-3599	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE					
06/17/2025 12:31	S25-3949	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	3
06/30/2025 12:00	S25-4296	Block 8 Lot 6 Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	< 1
06/30/2025 11:20	S25-4297	Drinking Fountain, San Vicente Elementary School	ABSENCE	ABSENCE	1
06/17/2025 13:02	S25-3953	Cistern Tank, Central Mall	ABSENCE	ABSENCE	50
06/03/2025 11:09	S25-3594	Binan Doctor's Hospital	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS					
06/03/2025 12:54	S25-3592	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	< 1
06/19/2025 13:01	S25-3959	Block 1 Lot 5, Bais St., Pragmatic	ABSENCE	ABSENCE	4
06/03/2025 13:07	S25-3603	Block 3 Lot 14, Adelina Complex	ABSENCE	ABSENCE	< 1
06/17/2025 13:16	S25-3948	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	19
06/17/2025 12:12	S25-3946	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	1
06/17/2025 12:18	S25-3947	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	37
06/17/2025 10:14	S25-3954	Water Pump, Town & Country, Amsterdam St.	ABSENCE	ABSENCE	7
06/17/2025 10:28	S25-3955	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	110
06/17/2025 10:40	S25-3956	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	154
06/17/2025 10:12	S25-3957	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	35
06/17/2025 11:21	S25-3958	Blk 1 Lt 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	19
BRGY. SORO – SORO					
06/10/2025 15:31	S25-3736	#76 Manila S Road	ABSENCE	ABSENCE	< 1
06/10/2025 15:16	S25-3737	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
06/18/2025 08:57	S25-4019	Gate Entrance, San Antonio South	ABSENCE	ABSENCE	2
BRGY. ZAPOTE					
06/17/2025 09:47	S25-3975	Water Pump, Summer Breeze	ABSENCE	ABSENCE	20

NOT VALID WITHOUT QR CODE



REVIEWED BY:


 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
06/24/2025 09:59	S25-4189	Guardhouse, Summer Breeze	ABSENCE	ABSENCE	< 1
06/17/2025 12:09	S25-3978	Clubhouse, Evergreen	ABSENCE	ABSENCE	11
06/24/2025 09:36	S25-4188	Elevated Water Tank, Evergreen	ABSENCE	ABSENCE	< 1
06/30/2025 14:36	S25-3984	Water Pump, Jubilation Village - West	ABSENCE	ABSENCE	12
06/17/2025 15:03	S25-3985	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	9
06/17/2025 12:37	S25-3986	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	< 1
06/17/2025 12:51	S25-3987	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	< 1
06/17/2025 13:08	S25-3988	Water Pump, Jubilation Village - East	ABSENCE	ABSENCE	< 1
06/17/2025 13:24	S25-3989	Clubhouse, Jubilation Village - East	ABSENCE	ABSENCE	< 1
06/03/2025 12:33	S25-3562	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A - Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)