

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 77

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 02/07/2022 – 02/20/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
02/07/2022 12:10	S22-0565	Laguna Wellfield 1	7.26 / 28.5	0.12	ABSENCE	ABSENCE	< 1
02/07/2022 13:01	S22-0567	Guardhouse Entrance, Phase 4C, San Jose Village I	7.28 / 27.4	0.28	ABSENCE	ABSENCE	< 1
02/07/2022 13:12	S22-0568	Clubhouse, Phase 3B, San Jose Village II	7.30 / 26.1	0.20	ABSENCE	ABSENCE	< 1
02/07/2022 13:18	S22-0569	Pump 11, Phase 5, San Jose Village II	7.35 / 27.5	0.36	ABSENCE	ABSENCE	< 1
02/07/2022 13:29	S22-0570	Clubhouse, Phase 5, San Jose Village II	7.50 / 28.1	0.25	ABSENCE	ABSENCE	< 1
02/07/2022 13:38	S22-0571	Clubhouse, Phase 6, San Jose Village III	7.40 / 27.6	0.18	ABSENCE	ABSENCE	< 1
02/07/2022 14:01	S22-0572	Main Gate, AVIDA Shophouse	7.55 / 28.1	0.48	ABSENCE	ABSENCE	< 1
02/07/2022 14:15	S22-0573	DLSU Science and Technology Complex, LTI Spine Road	7.60 / 27.5	0.30	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
02/15/2022 15:53	S22-0778	Clubhouse, Golden City Subdivision	7.56 / 30.5	0.20	ABSENCE	ABSENCE	< 1
02/15/2022 16:07	S22-0779	Drinking Fountain, Canlalay Elementary School	7.46 / 28.8	0.26	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
02/15/2022 15:12	S22-0784	Water Pump, Almeda Subdivision	7.85 / 28.8	0.56	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
02/16/2022 11:44	S22-0788	Ganado Elementary School	7.54 / 29.6	0.4	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
02/15/2022 16:26	S22-0774	9999 Water Pump Metroville Complex	7.59 / 27.9	0.10	ABSENCE	ABSENCE	< 1
02/15/2022 16:40	S22-0775	Block 30 Lot 17, Metroville Complex	7.18 / 27.8	< 0.02	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
02/18/2022 15:29	S22-0848	Block 3 Lot 9, Phase II, Southville	7.40 / 27.5	0.30	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/07/2022 14:53	S22-0577	Drinking Fountain, Southville 5A National High School	7.60 / 27.5	0.20	ABSENCE	ABSENCE	< 1
02/07/2022 15:10	S22-0578	Drinking Fountain, Langkiwa Elementary School	7.58 / 26.1	0.18	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
02/07/2022 14:21	S22-0574	Block 43 Lot 13, Celina Technopark	7.50 / 26.1	0.25	ABSENCE	ABSENCE	< 1
02/07/2022 11:59	S22-0599	Brenna Model House, Laguna Bel-Air III	7.40 / 27.9	0.20	ABSENCE	ABSENCE	< 1
02/07/2022 12:17	S22-0600	Block 2, Hilcrest Road, Laguna Bel-Air III	7.47 / 26.8	0.12	ABSENCE	ABSENCE	< 1
02/07/2022 12:34	S22-0601	Clubhouse, Laguna Bel-Air III	7.43 / 27.9	0.23	ABSENCE	ABSENCE	< 1
02/07/2022 14:33	S22-0576	Drinking Fountain, Loma Elementary	7.38 / 27.5	0.28	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
02/07/2022 14:50	S22-0575	Clubhouse, Verdana Homes Subdivision	7.40 / 29.1	0.40	ABSENCE	ABSENCE	< 1
02/16/2022 12:07	S22-0789	United Laboratories (UNILAB) Inc.	7.50 / 27.9	0.71	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
02/15/2022 14:54	S22-0785	Barangay Hall	7.94 / 28.9	0.13	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
02/10/2022 12:17	S22-0688	Elevated Water Tank, Mondo Bambini	7.79 / 28.2	0.82	ABSENCE	ABSENCE	< 1
02/10/2022 12:27	S22-0689	Clubhouse, Mondo Bambini	7.93 / 28.7	0.63	ABSENCE	ABSENCE	1
02/10/2022 13:24	S22-0690	Elevated Water Tank, Prima Casa	8.00 / 29.5	0.44	ABSENCE	ABSENCE	6
02/10/2022 13:32	S22-0691	Clubhouse, Prima Casa	7.95 / 31.4	0.33	ABSENCE	ABSENCE	< 1
02/10/2022 13:47	S22-0692	Water Pump, Spring Time	7.75 / 29.1	0.17	ABSENCE	ABSENCE	2
02/10/2022 13:59	S22-0693	Block 7 Lot 10, Spring Time	7.69 / 29.4	0.21	ABSENCE	ABSENCE	< 1
02/16/2022 16:10	S22-0791	Sea-oil, National Road	7.37 / 33.6	0.31	ABSENCE	ABSENCE	< 1
02/16/2022 16:31	S22-0793	Drinking Fountain, St. Michael School	7.44 / 29.0	0.33	ABSENCE	ABSENCE	< 1
02/10/2022 13:03	S22-0697	Water Pump, Jubilation Village - East	7.85 / 28.7	0.20	ABSENCE	ABSENCE	< 1
02/10/2022 13:10	S22-0698	Clubhouse, Jubilation Village - East	7.81 / 28.4	0.15	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARI C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. SAN ANTONIO							
02/16/2022 12:18	S22-0799	Water Pump, Biñan City Hall	7.61 / 28.2	0.15	ABSENCE	ABSENCE	310
02/16/2022 12:31	S22-0800	Alonte Stadium	7.56 / 28.5	0.27	ABSENCE	ABSENCE	2
02/16/2022 15:59	S22-0794	Water Pump, Margarita Homes Subdivision	7.80 / 29.2	1.57	ABSENCE	ABSENCE	< 1
02/16/2022 15:26	S22-0795	Block 1 Lot 12, Margarita Homes	7.74 / 29.3	1.26	ABSENCE	ABSENCE	< 1
02/15/2022 14:00	S22-0780	9022 Water Pump, Faraon Subdivision	7.93 / 30.6	1.13	ABSENCE	ABSENCE	< 1
02/15/2022 13:40	S22-0786	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	7.34 / 28.1	0.09	ABSENCE	ABSENCE	< 1
02/16/2022 13:57	S22-0796	Cistern Tank, Pavilion Mall	7.71 / 28.6	0.22	ABSENCE	ABSENCE	< 1
02/16/2022 14:06	S22-0797	Reyes Barbecue, Pavilion Mall	7.71 / 27.8	0.17	ABSENCE	ABSENCE	< 1
02/15/2022 14:28	S22-0781	Malaban Health Center	7.91 / 33.2	1.02	ABSENCE	ABSENCE	< 1
02/15/2022 14:15	S22-0782	Wash Area 1, Malaban Elementary School	7.87 / 33.1	1.49	ABSENCE	ABSENCE	< 1
02/15/2022 14:20	S22-0783	Wash Area 2, Malaban Elementary School	7.85 / 30.9	1.35	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
02/16/2022 14:17	S22-0798	Jollibee National Hi-Way	7.64 / 28.1	0.34	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
02/16/2022 13:39	S22-0801	407 Water Pump, San Vicente Subdivision	7.68 / 29.4	0.30	ABSENCE	ABSENCE	< 1
02/18/2022 15:40	S22-0849	Drinking Fountain, San Vicente Elementary School	7.48 / 29.0	0.29	ABSENCE	ABSENCE	< 1
02/18/2022 16:00	S22-0850	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.35 / 27.6	0.29	ABSENCE	ABSENCE	118
02/18/2022 14:59	S22-0862	Cistern Tank, Central Mall	7.67 / 29.0	0.36	ABSENCE	ABSENCE	< 1
02/16/2022 16:20	S22-0792	Biñan Doctor's Hospital	7.53 / 30.6	0.43	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
02/16/2022 13:09	S22-0790	Water Pump, Adelina Complex 3	7.47 / 28.6	0.28	ABSENCE	ABSENCE	99
02/16/2022 13:21	S22-0802	HOA Office, Adelina Complex	7.54 / 30.9	0.20	ABSENCE	ABSENCE	< 1
02/18/2022 17:18	S22-0856	Water Pump, Pragmatic Subdivision	7.28 / 27.5	0.30	ABSENCE	ABSENCE	1
02/18/2022 17:28	S22-0857	Block 1 Lot 5, Bais St., Pragmatic	7.38 / 28.5	0.14	ABSENCE	ABSENCE	3
02/18/2022 14:10	S22-0860	Tawi Tawi St., Phase 6, South City Homes	7.57 / 28.3	0.29	ABSENCE	ABSENCE	< 1
02/18/2022 13:38	S22-0858	Water Pump, South Plains II Subdivision	7.48 / 29.5	0.35	ABSENCE	ABSENCE	< 1
02/18/2022 13:50	S22-0859	Block 11 Lot 2, South Plains II Subdivision	7.35 / 27.6	0.38	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
02/18/2022 16:16	S22-0851	Water Pump, Town & Country, Amsterdam	7.56 / 28.5	0.35	ABSENCE	ABSENCE	< 1
02/18/2022 16:28	S22-0852	Blk 35 Lot 21, Southville Town & Country	7.59 / 29.7	0.28	ABSENCE	ABSENCE	1
02/18/2022 16:40	S22-0853	Blk 2 Lot 5, Town & Country, Pennsylvania	7.30 / 29.5	0.30	ABSENCE	ABSENCE	1
02/18/2022 17:01	S22-0854	Water Pump, Phase 4, Olivarez Homes South	7.45 / 27.6	0.28	ABSENCE	ABSENCE	2
02/18/2022 17:10	S22-0855	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.58 / 26.9	0.18	ABSENCE	ABSENCE	6
BRGY. SORO – SORO							
02/15/2022 17:17	S22-0774	Water Pump, 9067 Manila S Road	7.59 / 27.4	0.62	ABSENCE	ABSENCE	< 1
02/15/2022 17:03	S22-0777	#76 Manila S Road	7.64 / 27.7	0.63	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
02/07/2022 14:31	S22-0654	Water Pump, San Antonio South	7.55 / 29.7	0.21	ABSENCE	ABSENCE	< 1
02/07/2022 15:34	S22-0580	Block 3 Lot 23, San Antonio South	7.30 / 29.1	0.10	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
02/18/2022 14:21	S22-0861	#60 Florinda Compound	7.50 / 27.4	0.30	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
02/10/2022 11:32	S22-0684	Water Pump, Summer Breeze	7.69 / 28.5	0.49	ABSENCE	ABSENCE	< 1
02/10/2022 11:40	S22-0685	Clubhouse, Summer Breeze	7.76 / 28.1	0.49	ABSENCE	ABSENCE	< 1
02/10/2022 11:57	S22-0686	Elevated Water Tank, Evergreen	7.71 / 28.6	1.33	ABSENCE	ABSENCE	< 1
02/10/2022 12:05	S22-0687	Clubhouse, Evergreen	7.86 / 28.9	1.33	ABSENCE	ABSENCE	< 1
02/10/2022 12:39	S22-0695	Water Pump, Jubilation Village - South	7.78 / 28.6	0.27	ABSENCE	ABSENCE	< 1
02/10/2022 12:49	S22-0696	Clubhouse, Jubilation Village - South	7.78 / 30.6	0.12	ABSENCE	ABSENCE	< 1
02/10/2022 14:11	S22-0694	Clubhouse, Jubilation Village - West	7.58 / 29.3	0.43	ABSENCE	ABSENCE	1
02/16/2022 12:46	S22-0803	Clubhouse, Althea Residences	7.43 / 29.1	0.41	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable


DEVIATIONS: No deviation noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.