

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 70**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 10/06/2020-10/15/2020**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>							
10/07/2020 12:40	S20-6721	Laguna Wellfield 1	7.49 / 30.4	0.87	ABSENCE	ABSENCE	< 1
10/08/2020 12:18	S20-6760	Guardhouse Entrance, Phase 4C, San Jose Village I	7.55 / 28.6	0.44	ABSENCE	ABSENCE	< 1
10/08/2020 12:35	S20-6761	Clubhouse, Phase 3B, San Jose Village I	7.47 / 28.1	0.37	ABSENCE	ABSENCE	< 1
10/08/2020 12:54	S20-6762	Pump 11, Phase 5, San Jose Village II	7.58 / 28.6	0.30	ABSENCE	ABSENCE	< 1
10/08/2020 13:20	S20-6763	Clubhouse, Phase 5, San Jose Village II	7.77 / 28.7	0.27	ABSENCE	ABSENCE	< 1
10/08/2020 13:47	S20-6764	Clubhouse, Phase 6, San Jose Village III	7.42 / 28.3	0.23	ABSENCE	ABSENCE	< 1
10/08/2020 14:09	S20-6765	Main Gate, AVIDA Shophouse	7.44 / 28.6	0.35	ABSENCE	ABSENCE	3
10/08/2020 14:30	S20-6760	Shuttle Parking, DLSU Science and Technology Complex, LTI Spine Road	7.41 / 28.9	0.22	ABSENCE	ABSENCE	< 1
<b>BRGY. CANLALAY</b>							
10/13/2020 15:05	S20-6921	Clubhouse, Golden City Canlalay	7.26 / 29.0	0.23	ABSENCE	ABSENCE	< 1
10/13/2020 15:28	S20-6922	Drinking Fountain, Canlalay Elementary School	7.38 / 27.8	0.24	ABSENCE	ABSENCE	< 1
<b>BRGY. DELA PAZ</b>							
10/13/2020 16:30	S20-6927	Water Pump, Almeda Subdivision	7.36 / 28.8	0.45	ABSENCE	ABSENCE	< 1
10/13/2020 16:40	S20-6928	Barangay Hall	7.38 / 27.8	0.38	ABSENCE	ABSENCE	< 1
<b>BRGY. GANADO</b>							
10/06/2020 09:47	S20-6651	Ganado Elementary School	7.49 / 28.9	0.10	ABSENCE	ABSENCE	< 1
<b>BRGY. HALANG</b>							
10/13/2020 14:30	S20-6917	9999 Water Pump Metroville Complex	7.85 / 27.6	0.55	ABSENCE	ABSENCE	1
10/13/2020 14:40	S20-6918	Clubhouse, Metroville Complex	7.36 / 28.0	0.36	ABSENCE	ABSENCE	6

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBAR  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. LANGKIWA</b>							
10/13/2020 15:32	S20-6907	Block 3 Lot 9, Phase II, Southville	-	0.94	ABSENCE	ABSENCE	< 1
10/08/2020 10:41	S20-6771	Drinking Fountain, Southville 5A National High School	7.45 / 29.6	0.22	ABSENCE	ABSENCE	1
10/08/2020 11:37	S20-6772	Drinking Fountain, Langkiwa Elementary School	7.47 / 29.7	0.21	ABSENCE	ABSENCE	< 1
<b>BRGY. LOMA</b>							
10/08/2020 09:50	S20-6767	Block 43 Lot 13, Celina Technopark	7.55 / 27.6	0.35	ABSENCE	ABSENCE	< 1
10/08/2020 10:16	S20-6769	Drinking Fountain, Loma Elementary School	7.37 / 28.7	0.25	ABSENCE	ABSENCE	< 1
10/08/2020 12:07	S20-6755	Brenna Model House, Block 9D Lot 5, Laguna Bel-Air III	7.94 / 27.2	0.80	ABSENCE	ABSENCE	< 1
10/08/2020 12:14	S20-6756	Hillcrest Road, Block 2 Laguna Bel-Air III	7.84 / 27.4	0.76	ABSENCE	ABSENCE	< 1
10/08/2020 12:23	S20-6757	Clubhouse, Laguna Bel-Air III	7.76 / 27.6	0.79	ABSENCE	ABSENCE	< 1
<b>BRGY. MALABAN</b>							
10/13/2020 16:26	S20-6925	Drinking Fountain, Malaban Elementary School	7.30 / 27.9	0.34	ABSENCE	ABSENCE	< 1
<b>BRGY. MAMPLASAN</b>							
10/08/2020 12:03	S20-6768	Clubhouse, Verdana Homes Subdivision	7.41 / 28.9	0.47	ABSENCE	ABSENCE	< 1
10/06/2020 09:16	S20-6652	United Laboratories (UNILAB) Inc.	7.41 / 29.7	0.19	ABSENCE	ABSENCE	< 1
<b>BRGY. POBLACION</b>							
10/13/2020 17:10	S20-6929	Water Pump, Poblacion	7.40 / 28.8	0.06	ABSENCE	ABSENCE	< 1
10/13/2020 17:20	S20-6930	Barangay Hall, Poblacion	7.36 / 29.8	0.02	ABSENCE	ABSENCE	15
<b>BRGY. PLATERO</b>							
10/08/2020 13:00	S20-6777	Elevated Water Tank, Mondo Bambini	7.66 / 28.9	0.12	ABSENCE	ABSENCE	2
10/08/2020 13:20	S20-6778	Clubhouse, Mondo Bambini	7.45 / 27.9	0.09	ABSENCE	ABSENCE	11
10/08/2020 12:25	S20-6779	Elevated Water Tank, Prima Casa	7.66 / 27.9	0.14	ABSENCE	ABSENCE	5
10/08/2020 12:30	S20-6780	Clubhouse, Prima Casa	7.18 / 27.8	0.10	ABSENCE	ABSENCE	6
10/08/2020 13:33	S20-6781	Water Pump, Spring Time	7.69 / 28.0	0.15	ABSENCE	ABSENCE	1
10/08/2020 13:40	S20-6782	Block 1 Lot 7, Spring Time	7.58 / 27.8	0.08	ABSENCE	ABSENCE	< 1
10/06/2020 10:17	S20-6654	Sea-oil, National Road	7.30 / 29.6	0.18	ABSENCE	ABSENCE	< 1
10/06/2020 10:57	S20-6656	Drinking Fountain, St. Michael School	7.34 / 29.6	0.10	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN ANTONIO</b>							
10/06/2020 13:36	S20-6662	Biñan City Hall	7.38 / 30.1	0.35	ABSENCE	ABSENCE	< 1
10/06/2020 14:07	S20-6663	Alonte Stadium	7.29 / 28.7	0.32	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
10/06/2020 11:18	S20-6657	Water Pump, Margarita Homes Subdivision	7.45 / 30.6	0.30	ABSENCE	ABSENCE	2
10/06/2020 11:35	S20-6658	Ibanez Residence, Margarita Homes	7.48 / 29.4	0.22	ABSENCE	ABSENCE	< 1
10/13/2020 15:40	S20-6923	9022 Water Pump, Faraon Subdivision	7.30 / 28.8	0.40	ABSENCE	ABSENCE	< 1
10/06/2020 12:41	S20-6660	Nesa Inasal, Pavillion Mall	7.48 / 30.1	0.24	ABSENCE	ABSENCE	< 1
10/08/2020 11:12	S20-6770	Drinking Fountain, Jacobo Gonzales Memorial National High School	7.42 / 29.1	0.15	ABSENCE	ABSENCE	5
10/06/2020 12:13	S20-6659	Cistern Tank, Pavillion Mall	7.58 / 29.7	0.27	ABSENCE	ABSENCE	< 1
10/13/2020 16:00	S20-6924	Faraon Health Center	7.30 / 28.9	0.46	ABSENCE	ABSENCE	< 1
10/13/2020 16:20	S20-6926	Drinking Fountain 2, Faraon Elementary School	7.26 / 27.9	0.38	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO NIÑO</b>							
10/06/2020 13:02	S20-6661	Jollibee National Hi-Way	7.44 / 29.6	0.25	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN VICENTE</b>							
10/06/2020 08:50	S20-6665	407 Water Pump, San Vicente Subdivision	7.39 / 29.7	0.12	ABSENCE	ABSENCE	< 1
10/13/2020 14:35	S20-6908	Drinking Fountain, San Vicente Elementary School	-	0.93	ABSENCE	ABSENCE	14
10/13/2020 17:09	S20-6909	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	-	0.89	ABSENCE	ABSENCE	< 1
10/13/2020 17:22	S20-6910	Cistern Tank, Central Mall	-	0.45	ABSENCE	ABSENCE	18
10/06/2020 10:39	S20-6655	Biñan Doctor's Hospital	7.35 / 29.8	0.04	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO TOMAS</b>							
10/06/2020 08:36	S20-6653	Water Pump, Adelina Subdivision	7.45 / 30.3	0.12	ABSENCE	ABSENCE	< 1
10/13/2020 16:46	S20-6915	Water Pump, Pragmatic Subdivision	-	0.04	ABSENCE	ABSENCE	12
10/13/2020 13:54	S20-6988	Block 1 Lot 5, Bais St., Pragmatic	8.12 / 27.1	0.02	ABSENCE	ABSENCE	6
10/13/2020 16:04	S20-6905	Tawi Tawi St., Phase 6, South City Homes	-	0.90	ABSENCE	ABSENCE	< 1
10/13/2020 16:32	S20-6903	Water Pump, South Plains II Subdivision	-	0.22	ABSENCE	ABSENCE	< 1
10/13/2020 16:23	S20-6904	Block 11 Lot 2, South Plains II Subdivision	-	0.33	ABSENCE	ABSENCE	1
10/13/2020 15:00	S20-6911	Water Pump, Town & Country, Amsterdam	-	0.24	ABSENCE	ABSENCE	3
10/13/2020 15:13	S20-6912	Blk 35 Lt 21, Southville Town & Country	-	0.23	ABSENCE	ABSENCE	< 1
10/13/2020 15:20	S20-6913	Blk 2 Lt 5, Town & Country, Pennsylvania	-	0.92	ABSENCE	ABSENCE	23
10/13/2020 15:48	S20-6914	Blk 1 Lt 16, Phase 4, Olivarez Home South	-	0.84	ABSENCE	ABSENCE	11
<b>BRGY. SORO – SORO</b>							
10/13/2020 14:15	S20-6919	Water Pump, 9067 Manila S Road	7.26 / 27.8	0.38	ABSENCE	ABSENCE	15
10/13/2020 14:20	S20-6920	#76 Manila S Road	7.38 / 29.0	0.26	ABSENCE	ABSENCE	10

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PAC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)  MDL: NA LOQ: NA	RESIDUAL CHLORINE <sup>B</sup> (mg/L)  MDL: 0.06 LOQ: 0.20	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
				TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)		
<b>BRGY. TUBIGAN</b>							
10/13/2020 14:48	S20-6906	#60 Florinda Compound	-	0.47	ABSENCE	ABSENCE	<1
<b>BRGY. ZAPOTE</b>							
10/08/2020 11:30	S20-6773	Water Pump, Summer Breeze	7.65 / 27.9	0.16	ABSENCE	ABSENCE	5
10/08/2020 11:41	S20-6774	Clubhouse, Summer Breeze	7.55 / 27.8	0.12	ABSENCE	ABSENCE	< 1
10/08/2020 12:00	S20-6775	Elevated Water Tank, Evergreen	7.40 / 27.7	0.18	ABSENCE	ABSENCE	1
10/08/2020 12:15	S20-6776	Clubhouse, Evergreen	7.48 / 28.8	0.14	ABSENCE	ABSENCE	2
10/06/2020 08:50	S20-6664	Clubhouse, Althea	7.38 / 30.6	0.28	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable  
DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.