

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 79

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 10/04/2021 – 10/27/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
10/06/2021 11:33	S21-6949	Laguna Wellfield 1	7.22 / 28.6	0.95	ABSENCE	ABSENCE	< 1
10/04/2021 13:06	S21-6864	Guardhouse Entrance, Phase 4C, San Jose Village I	7.50 / 27.5	0.30	ABSENCE	ABSENCE	< 1
10/04/2021 12:45	S21-6865	Clubhouse, Phase 3B, San Jose Village II	7.40 / 28.1	0.25	ABSENCE	ABSENCE	< 1
10/04/2021 12:20	S21-6866	Pump 11, Phase 5, San Jose Village II	7.55 / 28.6	0.30	ABSENCE	ABSENCE	< 1
10/04/2021 11:57	S21-6867	Clubhouse, Phase 5, San Jose Village II	7.48 / 29.1	0.19	ABSENCE	ABSENCE	< 1
10/04/2021 11:41	S21-6868	Clubhouse, Phase 6, San Jose Village III	7.58 / 28.6	0.21	ABSENCE	ABSENCE	< 1
10/04/2021 13:21	S21-6869	Main Gate, AVIDA Shophouse	7.60 / 27.5	0.40	ABSENCE	ABSENCE	< 1
10/04/2021 11:30	S21-6870	DLSU Science and Technology Complex, LTI Spine Road	7.48 / 27.0	0.28	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
10/14/2021 13:34	S21-7165	Clubhouse, Golden City Subdivision	-	0.25	ABSENCE	ABSENCE	40
10/14/2021 13:50	S21-7166	Drinking Fountain, Canlalay Elementary School	-	0.27	ABSENCE	ABSENCE	55
BRGY. DELA PAZ							
10/14/2021 12:37	S21-7171	Water Pump, Almeda Subdivision	-	0.51	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
10/11/2021 12:30	S21-7067	Ganado Elementary School	7.24 / 28.7	0.32	ABSENCE	ABSENCE	3
BRGY. HALANG							
10/14/2021 14:14	S21-7161	9999 Water Pump Metroville Complex	-	0.22	ABSENCE	ABSENCE	< 1
10/14/2021 14:32	S21-7162	Block 30 Lot 17, Metroville Complex	-	0.23	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
10/07/2021 12:39	S21-7001	Gomez Residence, Phase II, Southville	7.22 / 28.3	0.35	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
10/04/2021 10:15	S21-6874	Drinking Fountain, Southville 5A National High School	7.60 / 28.1	0.20	ABSENCE	ABSENCE	< 1
10/04/2021 10:28	S21-6875	Drinking Fountain, Langkiwa Elementary School	7.65 / 27.1	0.18	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
10/04/2021 10:59	S21-6871	Block 43 Lot 13, Celina Technopark	7.48 / 27.6	0.30	ABSENCE	ABSENCE	< 1
10/05/2021 11:15	S21-6887	Brenna Model House, Laguna Bel-Air III	7.37 / 28.4	0.23	ABSENCE	ABSENCE	< 1
10/05/2021 11:35	S21-6888	Hilcrest Road, Block 2 Laguna Bel-Air III	7.22 / 28.3	0.22	ABSENCE	ABSENCE	< 1
10/05/2021 11:52	S21-6889	Clubhouse, Laguna Bel-Air III	7.35 / 28.5	0.25	ABSENCE	ABSENCE	< 1
10/04/2021 10:31	S21-6873	Drinking Fountain, Loma Elementary	7.36 / 28.5	0.38	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
10/04/2021 10:45	S21-6872	Clubhouse, Verdana Homes Subdivision	7.50 / 27.4	0.35	ABSENCE	ABSENCE	< 1
10/11/2021 12:16	S21-7068	United Laboratories (UNILAB) Inc.	7.25 / 28.3	0.27	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
10/14/2021 13:15	S21-7174	Pump Station	-	0.54	ABSENCE	ABSENCE	< 1
10/14/2021 13:01	S21-7172	Barangay Hall	-	0.15	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
10/04/2021 11:41	S21-6835	Elevated Water Tank, Mondo Bambini	-	0.41	ABSENCE	ABSENCE	< 1
10/04/2021 11:56	S21-6836	Clubhouse, Mondo Bambini	-	0.35	ABSENCE	ABSENCE	< 1
10/04/2021 12:56	S21-6837	Elevated Water Tank, Prima Casa	-	0.37	ABSENCE	ABSENCE	1
10/04/2021 13:06	S21-6838	Clubhouse, Prima Casa	-	0.36	ABSENCE	ABSENCE	2
10/04/2021 13:21	S21-6839	Water Pump, Spring Time	-	0.41	ABSENCE	ABSENCE	< 1
10/04/2021 13:32	S21-6840	Block 7 Lot 10, Spring Time	-	0.29	ABSENCE	ABSENCE	< 1
10/11/2021 12:28	S21-7070	Sea-oil, National Road	7.27 / 28.3	0.30	ABSENCE	ABSENCE	< 1
10/11/2021 13:01	S21-7072	Drinking Fountain, St. Michael School	7.24 / 29.6	0.17	ABSENCE	ABSENCE	< 1
10/04/2021 13:47	S21-6841	Tank 2, Jubilation Village - West	-	0.20	ABSENCE	ABSENCE	< 1
10/04/2021 13:56	S21-6842	Clubhouse, Jubilation Village - West	-	0.10	ABSENCE	ABSENCE	< 1
10/04/2021 12:34	S21-6845	Water Pump, Jubilation Village - East	-	0.27	ABSENCE	ABSENCE	< 1
10/04/2021 12:43	S21-6846	Clubhouse, Jubilation Village - East	-	0.14	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN ANTONIO							
10/11/2021 13:22	S21-7078	Water Pump, Biñan City Hall	7.25 / 29.6	0.47	ABSENCE	ABSENCE	< 1
10/11/2021 13:40	S21-7079	Alonte Stadium	7.25 / 28.6	0.50	ABSENCE	ABSENCE	< 1
10/11/2021 11:23	S21-7073	Water Pump, Margarita Homes Subdivision	7.25 / 28.7	0.39	ABSENCE	ABSENCE	< 1
10/11/2021 11:21	S21-7074	Ibanez Residence, Margarita Homes	7.31 / 28.3	0.35	ABSENCE	ABSENCE	< 1
10/14/2021 11:42	S21-7167	9022 Water Pump, Faraon Subdivision	-	1.04	ABSENCE	ABSENCE	< 1
10/14/2021 11:25	S21-7173	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	-	0.23	ABSENCE	ABSENCE	< 1
10/11/2021 10:11	S21-7075	Cistern Tank, Pavilion Mall	7.22 / 29.1	0.18	ABSENCE	ABSENCE	< 1
10/11/2021 10:17	S21-7076	Reyes Barbecue, Pavilion Mall	7.23 / 28.9	0.15	ABSENCE	ABSENCE	< 1
10/14/2021 12:14	S21-7168	Malaban Health Center	-	0.74	ABSENCE	ABSENCE	< 1
10/14/2021 12:04	S21-7170	Wash Area 2, Malaban Elementary School	-	0.93	ABSENCE	ABSENCE	< 1
10/14/2021 11:58	S21-7169	Wash Area 1, Malaban Elementary School	-	0.86	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
10/11/2021 11:47	S21-7077	Jollibee National Hi-Way	7.27 / 29.6	0.35	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
10/11/2021 11:03	S21-7080	407 Water Pump, San Vicente Subdivision	7.22 / 28.8	0.12	ABSENCE	ABSENCE	< 1
10/07/2021 09:16	S21-7002	Drinking Fountain, San Vicente Elementary School	7.20 / 29.6	0.15	ABSENCE	ABSENCE	< 1
10/07/2021 10:17	S21-7003	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.35 / 28.6	0.23	ABSENCE	ABSENCE	< 1
10/07/2021 09:00	S21-7004	Cistern Tank, Central Mall	7.35 / 29.6	0.29	ABSENCE	ABSENCE	< 1
10/11/2021 12:40	S21-7071	Biñan Doctor's Hospital	7.71 / 29.6	0.28	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
10/11/2021 14:15	S21-7069	Water Pump, Adelina Complex 3	7.21 / 28.3	0.25	ABSENCE	ABSENCE	< 1
10/11/2021 10:40	S21-7081	HOA Office, Adelina Complex	7.40 / 29.1	0.23	ABSENCE	ABSENCE	2
10/07/2021 10:59	S21-7010	Water Pump, Pragmatic Subdivision	7.32 / 28.1	0.16	ABSENCE	ABSENCE	< 1
10/07/2021 11:12	S21-7011	Block 1 Lot 5, Bais St., Pragmatic	7.22 / 28.3	0.10	ABSENCE	ABSENCE	< 1
10/07/2021 10:03	S21-6999	Tawi Tawi St., Phase 6, South City Homes	7.33 / 27.1	0.25	ABSENCE	ABSENCE	3
10/07/2021 12:01	S21-6997	Water Pump, South Plains II Subdivision	7.22 / 28.6	0.35	ABSENCE	ABSENCE	5
10/07/2021 12:14	S21-6998	Block 11 Lot 2, South Plains II Subdivision	7.25 / 28.3	0.27	ABSENCE	ABSENCE	1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
10/07/2021 10:33	S21-7005	Water Pump, Town & Country, Amsterdam	7.35 / 29.4	0.35	ABSENCE	ABSENCE	< 1
10/07/2021 10:44	S21-7006	Blk 35 Lot 21, Southville Town & Country	7.32 / 29.6	0.32	ABSENCE	ABSENCE	< 1
10/07/2021 12:24	S21-7007	Blk 2 Lot 5, Town & Country, Pennsylvania	7.37 / 28.4	0.32	ABSENCE	ABSENCE	< 1
10/07/2021 11:31	S21-7008	Water Pump, Phase 4, Olivarez Homes South	7.30 / 28.9	0.37	ABSENCE	ABSENCE	< 1
10/07/2021 11:43	S21-7009	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.35 / 29.1	0.25	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
10/14/2021 15:16	S21-7163	Water Pump, 9067 Manila S Road	-	0.86	ABSENCE	ABSENCE	< 1
10/14/2021 15:04	S21-7164	#76 Manila S Road	-	0.71	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
10/04/2021 09:56	S21-6876	Water Pump, San Antonio South	7.61 / 28.5	0.30	ABSENCE	ABSENCE	< 1
10/04/2021 09:40	S21-6877	Block 3 Lot 23, San Antonio South	7.63 / 28.9	0.28	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
10/07/2021 09:38	S21-7000	#60 Florinda Compound	7.35 / 28.3	0.18	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
10/04/2021 10:51	S21-6831	Water Pump, Summer Breeze	-	0.40	ABSENCE	ABSENCE	< 1
10/04/2021 11:02	S21-6832	Clubhouse, Summer Breeze	-	0.41	ABSENCE	ABSENCE	< 1
10/04/2021 11:16	S21-6833	Elevated Water Tank, Evergreen	-	0.91	ABSENCE	ABSENCE	< 1
10/04/2021 11:27	S21-6834	Clubhouse, Evergreen	-	0.40	ABSENCE	ABSENCE	< 1
10/04/2021 12:10	S21-6843	Water Pump, Jubilation Village - South	-	0.39	ABSENCE	ABSENCE	< 1
10/04/2021 12:23	S21-6844	Clubhouse, Jubilation Village - South	-	0.28	ABSENCE	ABSENCE	< 1
10/25/2021 15:12	S21-7378	Clubhouse, Althea Residences	-	0.17	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable


DEVIATIONS: No deviation noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.