

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : BIÑAN CITY HEALTH OFFICE**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 79**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 09/01/2021 – 09/27/2021**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>							
09/06/2021 15:20	S21-6331	Laguna Wellfield 1	7.15 / 28.3	0.40	ABSENCE	ABSENCE	< 1
09/01/2021 14:28	S21-6234	Guardhouse Entrance, Phase 4C, San Jose Village I	7.46 / 27.2	0.41	ABSENCE	ABSENCE	1
09/01/2021 14:16	S21-6235	Clubhouse, Phase 3B, San Jose Village II	7.48 / 28.5	0.38	ABSENCE	ABSENCE	< 1
09/01/2021 13:45	S21-6236	Pump 11, Phase 5, San Jose Village II	7.50 / 28.6	0.35	ABSENCE	ABSENCE	< 1
09/01/2021 13:26	S21-6237	Clubhouse, Phase 5, San Jose Village II	7.40 / 29.0	0.28	ABSENCE	ABSENCE	< 1
09/01/2021 13:10	S21-6238	Clubhouse, Phase 6, San Jose Village III	7.60 / 28.5	0.26	ABSENCE	ABSENCE	< 1
09/01/2021 14:01	S21-6239	Main Gate, AVIDA Shophouse	7.48 / 26.5	0.34	ABSENCE	ABSENCE	< 1
09/01/2021 12:38	S21-6240	DLSU Science and Technology Complex, LTI Spine Road	7.49 / 29.0	0.40	ABSENCE	ABSENCE	< 1
<b>BRGY. CANLALAY</b>							
09/09/2021 13:24	S21-6400	Clubhouse, Golden City Subdivision	-	0.09	ABSENCE	ABSENCE	< 1
09/09/2021 13:37	S21-6401	Drinking Fountain, Canlalay Elementary School	-	0.07	ABSENCE	ABSENCE	24
<b>BRGY. DELA PAZ</b>							
09/26/2021 14:08	S21-6804	Water Pump, Almeda Subdivision	-	1.01	ABSENCE	ABSENCE	-
<b>BRGY. GANADO</b>							
09/09/2021 09:52	S21-6407	Ganado Elementary School	-	0.30	ABSENCE	ABSENCE	< 1
<b>BRGY. HALANG</b>							
09/09/2021 13:50	S21-6402	9999 Water Pump Metroville Complex	-	0.26	ABSENCE	ABSENCE	100
09/09/2021 14:10	S21-6403	Block 20 Lot 17, Metroville Complex	-	0.17	ABSENCE	ABSENCE	8
<b>BRGY. LANGKIWA</b>							
09/09/2021 15:16	S21-6366	Reyes Residence, Phase II, Southville	7.21 / 28.3	0.30	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



*[Signature]*  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

*[Signature]*  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)  MDL: NA LOQ: NA	RESIDUAL CHLORINE <sup>B</sup> (mg/L)  MDL: 0.06 LOQ: 0.20	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
09/01/2021 11:18	S21-6244	Drinking Fountain, Southville 5A National High School	7.64 / 28.5	0.21	ABSENCE	ABSENCE	< 1
09/01/2021 10:59	S21-6245	Drinking Fountain, Langkiwa Elementary School	7.61 / 29.0	0.26	ABSENCE	ABSENCE	< 1
<b>BRGY. LOMA</b>							
09/01/2021 11:55	S21-6241	Block 43 Lot 13, Celina Technopark	7.45 / 27.6	0.29	ABSENCE	ABSENCE	< 1
09/01/2021 12:50	S21-6225	Brenna Model House, Laguna Bel-Air III	7.61 / 29.7	0.27	ABSENCE	ABSENCE	< 1
09/01/2021 13:14	S21-6226	Hilcrest Road, Block 2 Laguna Bel-Air III	7.47 / 30.1	0.35	ABSENCE	ABSENCE	< 1
09/01/2021 13:34	S21-6227	Clubhouse, Laguna Bel-Air III	7.45 / 30.3	0.34	ABSENCE	ABSENCE	< 1
09/01/2021 11:29	S21-6243	Drinking Fountain, Loma Elementary	7.65 / 28.5	0.36	ABSENCE	ABSENCE	< 1
<b>BRGY. MAMPLASAN</b>							
09/01/2021 12:16	S21-6242	Clubhouse, Verdana Homes Subdivision	7.40 / 27.5	0.39	ABSENCE	ABSENCE	< 1
09/09/2021 10:14	S21-6408	United Laboratories (UNILAB) Inc.	-	0.25	ABSENCE	ABSENCE	< 1
<b>BRGY. POBLACION</b>							
09/26/2021 14:08	S21-6804	Pump Station	-	0.46	ABSENCE	ABSENCE	-
09/09/2021 14:58	S21-6406	Barangay Hall	-	0.15	ABSENCE	ABSENCE	< 1
<b>BRGY. PLATERO</b>							
09/01/2021 13:24	S21-6252	Elevated Water Tank, Mondo Bambini	-	0.26	ABSENCE	ABSENCE	< 1
09/01/2021 13:32	S21-6253	Clubhouse, Mondo Bambini	-	0.24	ABSENCE	ABSENCE	8
09/01/2021 14:29	S21-6254	Elevated Water Tank, Prima Casa	-	0.21	ABSENCE	ABSENCE	38
09/01/2021 14:38	S21-6255	Clubhouse, Prima Casa	-	0.21	ABSENCE	ABSENCE	< 1
09/01/2021 14:49	S21-6256	Water Pump, Spring Time	-	0.29	ABSENCE	ABSENCE	< 1
09/01/2021 14:57	S21-6257	Block 10 Lot 7, Spring Time	-	0.19	ABSENCE	ABSENCE	< 1
09/09/2021 08:30	S21-6410	Sea-oil, National Road	-	0.35	ABSENCE	ABSENCE	< 1
09/09/2021 09:01	S21-6411	Drinking Fountain, St. Michael School	-	0.15	ABSENCE	ABSENCE	< 1
09/01/2021 15:11	S21-6258	Tank 2, Jubilation Village - West	-	0.14	ABSENCE	ABSENCE	< 1
09/01/2021 15:18	S21-6259	Clubhouse, Jubilation Village - West	-	0.16	ABSENCE	ABSENCE	< 1
09/01/2021 14:09	S21-6262	Water Pump, Jubilation Village - East	-	0.20	ABSENCE	ABSENCE	< 1
09/01/2021 14:17	S21-6263	Clubhouse, Jubilation Village - East	-	0.17	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. SAN ANTONIO</b>							
09/09/2021 12:18	S21-6418	Water Pump, Biñan City Hall	-	0.55	ABSENCE	ABSENCE	3
09/09/2021 12:31	S21-6419	Alonte Stadium	-	0.48	ABSENCE	ABSENCE	2
09/09/2021 09:17	S21-6413	Water Pump, Margarita Homes Subdivision	-	0.42	ABSENCE	ABSENCE	< 1
09/09/2021 09:32	S21-6414	Block 5 Lot 2, Margarita Homes	-	0.41	ABSENCE	ABSENCE	< 1
09/09/2021 15:54	S21-6399	9022 Water Pump, Faraon Subdivision	-	0.24	ABSENCE	ABSENCE	< 1
09/09/2021 16:34	S21-6395	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	-	0.04	ABSENCE	ABSENCE	< 1
09/09/2021 10:36	S21-6415	Cistern Tank, Pavilion Mall	-	0.17	ABSENCE	ABSENCE	< 1
09/09/2021 10:59	S21-6416	Bonchon, Pavilion Mall	-	0.15	ABSENCE	ABSENCE	1
09/09/2021 15:35	S21-6398	Malaban Health Center	-	0.17	ABSENCE	ABSENCE	18
09/09/2021 15:26	S21-6397	Wash Area 2, Malaban Elementary School	-	0.08	ABSENCE	ABSENCE	< 1
09/09/2021 15:22	S21-6396	Wash Area 1, Malaban Elementary School	-	0.11	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO NIÑO</b>							
09/09/2021 11:16	S21-6417	Jollibee National Hi-Way	-	0.28	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN VICENTE</b>							
09/09/2021 11:40	S21-6420	407 Water Pump, San Vicente Subdivision	-	0.20	ABSENCE	ABSENCE	< 1
09/09/2021 14:12	S21-6367	Drinking Fountain, San Vicente Elementary School	7.37 / 29.6	0.22	ABSENCE	ABSENCE	1
09/09/2021 14:32	S21-6368	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.41 / 28.7	0.25	ABSENCE	ABSENCE	8
09/09/2021 14:32	S21-6369	Cistern Tank, Central Mall	7.30 / 28.3	0.21	ABSENCE	ABSENCE	< 1
09/09/2021 08:47	S21-6412	Biñan Doctor's Hospital	-	0.12	ABSENCE	ABSENCE	61
<b>BRGY. SANTO TOMAS</b>							
09/09/2021 12:53	S21-6409	Water Pump, Adelina Complex 3	-	0.37	ABSENCE	ABSENCE	< 1
09/09/2021 12:01	S21-6421	HOA Office, Adelina Complex	-	0.17	ABSENCE	ABSENCE	< 1
09/09/2021 12:13	S21-6375	Water Pump, Pragmatic Subdivision	7.13 / 29.7	0.09	ABSENCE	ABSENCE	< 1
09/09/2021 12:20	S21-6376	Block 1 Lot 5, Bais St., Pragmatic	7.22 / 28.1	0.05	ABSENCE	ABSENCE	< 1
09/09/2021 12:46	S21-6364	Tawi Tawi St., Phase 6, South City Homes	7.25 / 28.6	0.28	ABSENCE	ABSENCE	3
09/09/2021 13:01	S21-6362	Water Pump, South Plains II Subdivision	7.44 / 29.7	0.33	ABSENCE	ABSENCE	< 1
09/09/2021 13:15	S21-6363	Block 11 Lot 2, South Plains II Subdivision	7.35 / 29.7	0.30	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

*[Signature]*  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

*[Signature]*  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
09/09/2021 10:42	S21-6370	Water Pump, Town & Country, Amsterdam	7.32 / 29.2	0.37	ABSENCE	ABSENCE	< 1
09/09/2021 10:51	S21-6371	Blk 35 Lot 21, Southville Town & Country	7.31 / 29.6	0.33	ABSENCE	ABSENCE	< 1
09/09/2021 11:14	S21-6372	Blk 2 Lot 5, Town & Country, Pennsylvania	7.47 / 29.7	0.25	ABSENCE	ABSENCE	< 1
09/09/2021 11:33	S21-6373	Water Pump, Phase 4, Olivarez Homes South	7.30 / 28.5	0.30	ABSENCE	ABSENCE	< 1
09/09/2021 11:49	S21-6374	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.16 / 29.7	0.25	ABSENCE	ABSENCE	< 1
<b>BRGY. SORO – SORO</b>							
09/13/2021 11:56	S21-6484	Water Pump, 9067 Manila S Road	-	0.48	ABSENCE	ABSENCE	< 1
09/09/2021 14:28	S21-6405	#76 Manila S Road	-	0.42	ABSENCE	ABSENCE	94
<b>BRGY. TIMBAO</b>							
09/01/2021 10:42	S21-6246	Water Pump, San Antonio South	7.48 / 28.5	0.28	ABSENCE	ABSENCE	< 1
09/01/2021 10:31	S21-6247	Block 3 Lot 23, San Antonio South	7.45 / 27.6	0.26	ABSENCE	ABSENCE	< 1
<b>BRGY. TUBIGAN</b>							
09/09/2021 13:49	S21-6365	#60 Florinda Compound	7.22 / 29.1	0.20	ABSENCE	ABSENCE	< 1
<b>BRGY. ZAPOTE</b>							
09/01/2021 12:39	S21-6248	Water Pump, Summer Breeze	-	0.51	ABSENCE	ABSENCE	< 1
09/01/2021 12:45	S21-6249	Clubhouse, Summer Breeze	-	0.78	ABSENCE	ABSENCE	< 1
09/01/2021 12:58	S21-6250	Elevated Water Tank, Evergreen	-	0.80	ABSENCE	ABSENCE	4
09/01/2021 13:06	S21-6251	Clubhouse, Evergreen	-	0.41	ABSENCE	ABSENCE	< 1
09/01/2021 13:51	S21-6260	Water Pump, Jubilation Village - South	-	0.28	ABSENCE	ABSENCE	45
09/01/2021 13:57	S21-6261	Clubhouse, Jubilation Village - South	-	0.28	ABSENCE	ABSENCE	< 1
09/26/2021 14:43	S21-6805	Clubhouse, Althea Residences	-	0.21	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.