

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 68

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 02/04/2020-02/26/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
02/06/2020 13:07	S20-0844	Guardhouse Entrance, Phase 4C, San Jose Village I	6.92 / 27.3	0.61	ABSENCE	ABSENCE	-
02/06/2020 12:53	S20-0845	Clubhouse, Phase 3B, San Jose Village I	6.77 / 27.2	0.65	ABSENCE	ABSENCE	-
02/06/2020 12:03	S20-0846	Pump 11, Phase 5, San Jose Village II	7.09 / 27.7	0.62	ABSENCE	ABSENCE	-
02/06/2020 12:13	S20-0847	Clubhouse, Phase 5, San Jose Village II	7.09 / 28.1	0.89	ABSENCE	ABSENCE	-
02/06/2020 11:48	S20-0848	Clubhouse, Phase 6, San Jose Village III	7.04 / 27.8	0.90	ABSENCE	ABSENCE	-
02/06/2020 13:17	S20-0849	Lot 21 Block 1, AVIDA Shophouse	6.83 / 27.6	0.62	ABSENCE	ABSENCE	-
02/06/2020 13:40	S20-0850	De La Salle University and Technology Complex	7.34 / 28.4	0.59	ABSENCE	ABSENCE	-
BRGY. CANLALAY							
02/24/2020 14:18	S20-1144	Clubhouse, Golden City Canlalay	7.44 / 31.4	0.24	ABSENCE	ABSENCE	< 1
02/24/2020 14:33	S20-1145	Drinking Fountain, Canlalay Elementary School	7.43 / 30.4	0.49	ABSENCE	ABSENCE	41
BRGY. DELA PAZ							
02/24/2020 13:47	S20-1150	Water Pump, Almeda Subdivision	7.71 / 30.5	2.02	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
02/04/2020 11:40	S20-0719	Ganado Elementary School	7.15 / 27.6	1.05	ABSENCE	ABSENCE	13
BRGY. HALANG							
02/24/2020 14:51	S20-1140	9999 WP Metroville Complex	7.40 / 29.5	0.87	ABSENCE	ABSENCE	2
02/24/2020 14:59	S20-1141	Clubhouse, Metroville Complex	7.46 / 30.3	0.84	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
02/12/2020 09:47	S20-1042	Block 3 Lot 9, Phase II, Southville	7.27 / 27.7	0.60	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR STAMP

ANALYZED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/06/2020 11:19	S20-0854	Drinking Fountain, Southville 5A National High School	7.11 / 28.8	0.70	ABSENCE	ABSENCE	-
02/06/2020 11:25	S20-0855	Drinking Fountain, Langkiwa Elementary School	7.12 / 27.6	0.93	ABSENCE	ABSENCE	-
BRGY. LOMA							
02/06/2020 10:23	S20-0851	Block 43 Lot 13, Celina Technopark	6.95 / 27.1	0.98	ABSENCE	ABSENCE	-
02/06/2020 10:16	S20-0853	Drinking Fountain, Loma Elementary School	7.03 / 26.9	1.05	ABSENCE	ABSENCE	-
02/26/2020 13:58	S20-1222	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air III	7.28 / 26.0	0.36	ABSENCE	ABSENCE	-
02/26/2020 13:10	S20-1223	Hilcrest Road, Block 2, Laguna Bel-Air III	7.25 / 24.5	0.28	ABSENCE	ABSENCE	-
02/26/2020 13:10	S20-1224	Clubhouse, Laguna Bel-Air III	7.30 / 26.6	0.30	ABSENCE	ABSENCE	-
BRGY. MAMPLASAN							
02/06/2020 10:58	S20-0852	Clubhouse, Verdana Homes Subdivision	6.87 / 27.4	0.92	ABSENCE	ABSENCE	-
02/04/2020 11:22	S20-0720	United Laboratories (UNILAB) Inc.	7.39 / 27.6	0.90	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
02/24/2020 12:18	S20-1151	Water Pump, Poblacion	7.48 / 30.9	0.05	ABSENCE	ABSENCE	36
02/24/2020 12:25	S20-1152	Barangay Hall, Poblacion	7.63 / 30.7	1.34	ABSENCE	ABSENCE	23
BRGY. PLATERO							
02/06/2020 12:35	S20-0860	Elevated Water Tank, Mondo Bambini	7.24 / 27.3	0.18	ABSENCE	ABSENCE	-
02/06/2020 12:40	S20-0861	Clubhouse, Mondo Bambini	7.25 / 26.8	0.12	ABSENCE	ABSENCE	-
02/06/2020 14:10	S20-0862	Elevated Water Tank, Prima Casa	7.67 / 28.2	0.14	ABSENCE	ABSENCE	-
02/06/2020 14:15	S20-0863	Clubhouse, Prima Casa	7.50 / 27.8	0.08	ABSENCE	ABSENCE	-
02/06/2020 14:25	S20-0864	Water Pump, Spring Time	7.76 / 28.0	1.09	ABSENCE	ABSENCE	-
02/04/2020 09:27	S20-0724	Drinking Fountain, St. Michael School of Biñan	6.79 / 27.9	0.97	ABSENCE	ABSENCE	< 1
02/04/2020 09:50	S20-0722	Sea-oil, National Road	7.15 / 28.2	0.94	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO							
02/04/2020 12:25	S20-0730	Biñan City Hall	7.17 / 29.9	1.35	ABSENCE	ABSENCE	9
02/04/2020 12:31	S20-0731	Alonte Stadium	7.26 / 29.7	2.01	ABSENCE	ABSENCE	< 1
02/04/2020 10:07	S20-0725	Water Pump, Margarita Homes Subdivision	7.43 / 29.0	0.75	ABSENCE	ABSENCE	< 1
02/04/2020 10:22	S20-0726	Block 1 Lot 19, Margarita Homes Subdivision	7.44 / 27.3	0.49	ABSENCE	ABSENCE	< 1
02/24/2020 12:33	S20-1146	9022 Water Pump, Faraon Subdivision	7.78 / 32.5	1.07	ABSENCE	ABSENCE	9
02/24/2020 12:58	S20-1147	Malaban Health Center	7.68 / 30.5	0.97	ABSENCE	ABSENCE	23
02/24/2020 13:09	S20-1148	Drinking Fountain 1, Malaban Elementary School	7.85 / 33.4	1.18	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR STAMP

ANALYZED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/04/2020 11:08	S20-0728	Mesa Inasal, Pavillion Mall	7.32 / 27.1	0.90	ABSENCE	ABSENCE	< 1
02/24/2020 13:14	S20-1149	Drinking Fountain 2, Malaban Elementary School	7.76 / 30.4	1.37	ABSENCE	ABSENCE	7
02/24/2020 12:02	S20-1153	Jacobo Integrated National High School	7.47 / 30.1	0.45	ABSENCE	ABSENCE	< 1
02/04/2020 10:58	S20-0727	Cistern Tank, Pavillion Mall	7.30 / 28.4	0.88	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
02/04/2020 10:46	S20-0729	Jollibee National Hi-Way	7.10 / 28.0	0.97	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
02/04/2020 13:03	S20-0733	407 Water Pump, San Vicente Subdivision	7.25 / 30.6	0.25	ABSENCE	ABSENCE	< 1
02/12/2020 10:14	S20-1044	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.25 / 21.6	0.38	ABSENCE	ABSENCE	-
02/04/2020 09:42	S20-0723	Biñan Doctors Hospital	7.02 / 27.2	1.01	ABSENCE	ABSENCE	< 1
02/12/2020 10:20	S20-1045	Cistern Tank, Central Mall	7.26 / 27.9	0.20	ABSENCE	ABSENCE	-
02/12/2020 13:30	S20-1043	Drinking Fountain, San Vicente Elementary School	7.24 / 27.5	0.25	ABSENCE	ABSENCE	-
BRGY. SANTO TOMAS							
02/05/2020 16:06	S20-0825	Water Pump, Adelina Subdivision	7.01 / 28.9	0.22	ABSENCE	ABSENCE	24
02/05/2020 16:16	S20-0826	HOA Office, Adelina Subdivision	7.18 / 32.9	1.81	ABSENCE	ABSENCE	< 1
02/12/2020 11:40	S20-1050	Water Pump, Pragmatic	7.11 / 27.8	0.22	ABSENCE	ABSENCE	-
02/12/2020 10:51	S20-1051	Block 1 Lot 5, Bais St., Pragmatic	7.22 / 27.4	0.15	ABSENCE	ABSENCE	-
02/12/2020 12:51	S20-1040	Tawi Tawi St., Phase 6, South City Homes	7.26 / 26.8	0.32	ABSENCE	ABSENCE	-
02/12/2020 12:16	S20-1038	Pump, South Plains II Subdivision	7.28 / 27.9	0.53	ABSENCE	ABSENCE	-
02/12/2020 12:20	S20-1039	Block 11 Lot 2, South Plains II Subdivision	7.21 / 27.8	0.41	ABSENCE	ABSENCE	-
02/12/2020 10:46	S20-1046	Water Pump, Town & Country, Amsterdam	7.21 / 26.7	0.38	ABSENCE	ABSENCE	-
02/12/2020 10:10	S20-1047	Blk 35 Lt 21, Town & Country, Amsterdam	7.12 / 26.4	0.25	ABSENCE	ABSENCE	-
02/12/2020 10:28	S20-1048	Blk 2 Lt 5, Town & Country, Pennsylvania	7.15 / 26.3	0.35	ABSENCE	ABSENCE	-
02/12/2020 11:15	S20-1049	Blk 1 Lot 16, Phase 4, Olivarez Home South	7.25 / 27.9	0.42	ABSENCE	ABSENCE	-
BRGY. SORO – SORO							
02/24/2020 15:37	S20-1142	Water Pump, 9067 Manila S Road	7.44 / 29.8	0.05	ABSENCE	ABSENCE	< 1
02/24/2020 15:20	S20-1143	#76 Manila S Road	7.52 / 29.9	0.05	ABSENCE	ABSENCE	4
BRGY. TUBIGAN							
02/12/2020 10:50	S20-1041	#60 Florinda Compound	7.28 / 27.8	0.22	ABSENCE	ABSENCE	-
BRGY. ZAPOTE							
02/06/2020 13:20	S20-0856	Water Pump, Summer Breeze	7.40 / 27.4	0.39	ABSENCE	ABSENCE	-
02/06/2020 13:40	S20-0857	Clubhouse, Summer Breeze	7.26 / 27.0	0.25	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR STAMP

ANALYZED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/06/2020 13:00	S20-0858	Elevated Water Tank, Evergreen	7.52 / 27.8 MDL: NA LOQ: NA	0.38 MDL: 0.06 LOQ: 0.20	ABSENCE	ABSENCE	-
02/06/2020 13:10	S20-0859	Clubhouse, Evergreen	7.40 / 27.6	0.26	ABSENCE	ABSENCE	-
02/04/2020 13:38	S20-0734	Althea Residences	7.26 / 26.8	0.03	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP

ANALYZED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis