

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 68

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 04/07/2026-04/30/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/08/2026 12:57	S26-2074	Laguna Wellfield 1	ABSENCE	ABSENCE	1
04/24/2026 14:25	S26-2518	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
04/24/2026 14:18	S26-2519	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 13:19	S26-2520	Pump XI, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 12:48	S26-2521	Clubhouse, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 12:20	S26-2522	Clubhouse, Phase VI, San Jose Village III	ABSENCE	ABSENCE	< 1
04/24/2026 14:10	S26-2523	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
04/24/2026 13:50	S26-2524	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
04/21/2026 11:50	S26-2377	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	20
04/21/2026 11:30	S26-2378	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
04/21/2026 12:14	S26-2373	9999 Water Pump, Metroville Complex	ABSENCE	ABSENCE	< 1
04/21/2026 12:20	S26-2374	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	2
BRGY. GANADO					
04/21/2026 12:20	S26-2053	Canteen, Ganado Elementary School	ABSENCE	ABSENCE	15
BRGY. LANGKIWA					
04/24/2026 10:22	S26-2528	Barangay Hall	ABSENCE	ABSENCE	< 1
04/24/2026 10:11	S26-2530	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
04/30/2026 12:10	S26-2612	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
04/24/2026 10:51	S26-2529	Water Pump, Southville Phase 5A	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LOMA					
04/24/2026 11:49	S26-2525	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
04/16/2026 13:25	S26-2296	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
04/16/2026 13:33	S26-2297	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
04/24/2026 12:10	S26-2527	Drinking Fountain, Loma Elementary School	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN					
04/24/2026 11:30	S26-2526	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
04/07/2026 13:16	S26-2059	Amherst Laboratories (UNILAB)	ABSENCE	ABSENCE	14
BRGY. POBLACION					
04/21/2026 11:49	S26-2384	Barangay Hall	ABSENCE	ABSENCE	1
BRGY. PLATERO					
04/13/2026 12:13	S26-2186	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	7
04/13/2026 13:51	S26-2188	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
04/13/2026 12:29	S26-2187	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
04/13/2026 13:58	S26-2189	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	< 1
04/16/2026 12:57	S26-2300	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	< 1
04/07/2026 10:12	S26-2055	Sea Oil, National Road	ABSENCE	ABSENCE	< 1
04/07/2026 10:02	S26-2057	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	490
04/13/2026 14:30	S26-2193	Water Pump, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
04/13/2026 13:25	S26-2194	Clubhouse, Jubilation Home Village - East	ABSENCE	ABSENCE	1
BRGY. SAN ANTONIO					
04/07/2026 12:29	S26-2063	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
04/07/2026 12:35	S26-2064	Alonte Stadium	ABSENCE	ABSENCE	< 1
04/07/2026 10:32	S26-2058	Block 1 Lot 13, Margarita Homes	ABSENCE	ABSENCE	97
04/21/2026 10:00	S26-2379	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
04/21/2026 09:04	S26-2385	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	170
04/07/2026 11:00	S26-2060	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
04/07/2026 11:08	S26-2061	Dunkin Donut, Pavilion Mall	ABSENCE	ABSENCE	2
04/21/2026 09:45	S26-2380	Malaban Health Center	ABSENCE	ABSENCE	< 1
04/21/2026 09:27	S26-2381	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	22
04/21/2026 09:34	S26-2382	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	14
BRGY. SANTO NIÑO					
04/07/2026 10:51	S26-2062	Jollibee National Hi-Way	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN VICENTE					
04/27/2026 12:17	S26-2559	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 13:12	S26-2562	Cistern Tank, Central Mall	ABSENCE	ABSENCE	3
04/07/2026 09:49	S26-2056	Biñan Doctors Hospital	ABSENCE	ABSENCE	6
BRGY. SANTO TOMAS					
04/07/2026 11:53	S26-2054	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	1
04/27/2026 11:30	S26-2568	Block 1 Lot 5, Bais St., Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 13:20	S26-2558	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	2
04/27/2026 11:14	S26-2556	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 11:20	S26-2557	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
04/30/2026 12:21	S26-2614	Water Pump, Amsterdam St., Town & Country	ABSENCE	ABSENCE	< 1
04/30/2026 12:32	S26-2615	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
04/27/2026 10:08	S26-2565	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	87
04/27/2026 10:40	S26-2566	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	33
04/27/2026 10:51	S26-2567	Block 1 Lot 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	8
BRGY. SORO-SORO					
04/21/2026 13:34	S26-2375	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
04/21/2026 14:12	S26-2376	#76 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
04/24/2026 11:17	S26-2531	Guardhouse, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
04/21/2026 10:31	S26-2383	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	5
04/21/2026 10:57	S26-2387	Drinking fountain, Dela Paz Main Elementary School	ABSENCE	ABSENCE	87
BRGY. ZAPOTE					
04/13/2026 17:56	S26-2183	Gate Entrance, Summer Breeze	ABSENCE	ABSENCE	5
04/13/2026 17:56	S26-2185	Evergreen Clubhouse	ABSENCE	ABSENCE	< 1
04/13/2026 17:56	S26-2184	Evergreen Elevated Water Tank	ABSENCE	ABSENCE	< 1
04/13/2026 17:56	S26-2191	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	34
04/13/2026 17:56	S26-2192	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	13
04/07/2026 11:26	S26-2065	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2075

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 11:42

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.94	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2076

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:14

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 2, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.71	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2077

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:55

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 3, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.21	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. A. DAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2078

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 13:04

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 4, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.30	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ANDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2079

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 13:15

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUPERDOUGH FOOD AND CATERING CORP., LAGUNA TECHNOPARK INC., ANNEX, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.83	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2080

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 11:50

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LIFT STATION, PHASE 1, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.76	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2074

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:57

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LAGUNA WELL FIELD, LAGUNA TECHNOPARK INC. ANNEX, BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.30	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ANDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1984

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 11:39

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUTABA CORPORATION, 120 N. SCIENCE AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.62	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1985

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 11:04

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUJITSU DIE-TECH CORPORATION, 11 EAST SCIENCE AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.34	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	210	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1986

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 11:22

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : INTEGRATED MICRO-ELECTRONICS, NORTH SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.47	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	3	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1987

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 10:05

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : IK INABATA PHILIPPINES, CCMC COMPOUND 3, LOT 4 & 5, BLOCK 2 PHASE 7A, LAGUNA
TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.69	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTZEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1988

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 10:26

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PEZA LAGUNA TECHNOPARK, LOT 12 BLOCK 2, NORTH MAIN AVENUE LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.56	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1989

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 11:12

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PORTION FILLERS INC., 106 COMMERCE ROAD, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.38	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2082

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:10

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : ISUZU PHILIPPINES CORPORATION, 114 N. MAIN AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.43	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1991

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 10:17

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : RYONAN ELECTRIC PHILIPPINES CORPORATION, 105 EAST MAIN AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.76	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1992

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 11:32

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : F. TECH PHILIPPINES MANUFACTURING INC., 118 NORTH SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.90	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2083

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:02

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HONDA PARTS MANUFACTURING CORPORATION, 101 N. SCIENCE AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.49	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2081

DATE/TIME SUBMITTED : 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 12:49

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SANYO PLASTIC PHILIPPINES, INC. 110 EAST MAIN AVE., LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.56	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1990

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 10:50

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : TECHNO FREEZE INC., 114 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.50	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	30	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-1993

DATE/TIME SUBMITTED : 04/06/2026 11:48

DATE/TIME COLLECTION : 04/06/2026 10:37

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUNPOWER PHILIPPINES, 100 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.17	4500-Cl-G.DPD Colorimetric	04/06/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. A. DAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 68

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 04/07/2026-04/30/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/08/2026 12:57	S26-2074	Laguna Wellfield 1	ABSENCE	ABSENCE	1
04/24/2026 14:25	S26-2518	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
04/24/2026 14:18	S26-2519	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 13:19	S26-2520	Pump XI, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 12:48	S26-2521	Clubhouse, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
04/24/2026 12:20	S26-2522	Clubhouse, Phase VI, San Jose Village III	ABSENCE	ABSENCE	< 1
04/24/2026 14:10	S26-2523	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
04/24/2026 13:50	S26-2524	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
04/21/2026 11:50	S26-2377	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	20
04/21/2026 11:30	S26-2378	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
04/21/2026 12:14	S26-2373	9999 Water Pump, Metroville Complex	ABSENCE	ABSENCE	< 1
04/21/2026 12:20	S26-2374	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	2
BRGY. GANADO					
04/21/2026 12:20	S26-2053	Canteen, Ganado Elementary School	ABSENCE	ABSENCE	15
BRGY. LANGKIWA					
04/24/2026 10:22	S26-2528	Barangay Hall	ABSENCE	ABSENCE	< 1
04/24/2026 10:11	S26-2530	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
04/30/2026 12:10	S26-2612	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
04/24/2026 10:51	S26-2529	Water Pump, Southville Phase 5A	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LOMA					
04/24/2026 11:49	S26-2525	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
04/16/2026 13:25	S26-2296	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
04/16/2026 13:33	S26-2297	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
04/24/2026 12:10	S26-2527	Drinking Fountain, Loma Elementary School	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN					
04/24/2026 11:30	S26-2526	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
04/07/2026 13:16	S26-2059	Amherst Laboratories (UNILAB)	ABSENCE	ABSENCE	14
BRGY. POBLACION					
04/21/2026 11:49	S26-2384	Barangay Hall	ABSENCE	ABSENCE	1
BRGY. PLATERO					
04/13/2026 12:13	S26-2186	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	7
04/13/2026 13:51	S26-2188	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
04/13/2026 12:29	S26-2187	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
04/13/2026 13:58	S26-2189	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	< 1
04/16/2026 12:57	S26-2300	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	< 1
04/07/2026 10:12	S26-2055	Sea Oil, National Road	ABSENCE	ABSENCE	< 1
04/07/2026 10:02	S26-2057	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	490
04/13/2026 14:30	S26-2193	Water Pump, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
04/13/2026 13:25	S26-2194	Clubhouse, Jubilation Home Village - East	ABSENCE	ABSENCE	1
BRGY. SAN ANTONIO					
04/07/2026 12:29	S26-2063	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
04/07/2026 12:35	S26-2064	Alonte Stadium	ABSENCE	ABSENCE	< 1
04/07/2026 10:32	S26-2058	Block 1 Lot 13, Margarita Homes	ABSENCE	ABSENCE	97
04/21/2026 10:00	S26-2379	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
04/21/2026 09:04	S26-2385	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	170
04/07/2026 11:00	S26-2060	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
04/07/2026 11:08	S26-2061	Dunkin Donut, Pavilion Mall	ABSENCE	ABSENCE	2
04/21/2026 09:45	S26-2380	Malaban Health Center	ABSENCE	ABSENCE	< 1
04/21/2026 09:27	S26-2381	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	22
04/21/2026 09:34	S26-2382	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	14
BRGY. SANTO NIÑO					
04/07/2026 10:51	S26-2062	Jollibee National Hi-Way	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN VICENTE					
04/27/2026 12:17	S26-2559	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 13:12	S26-2562	Cistern Tank, Central Mall	ABSENCE	ABSENCE	3
04/07/2026 09:49	S26-2056	Biñan Doctors Hospital	ABSENCE	ABSENCE	6
BRGY. SANTO TOMAS					
04/07/2026 11:53	S26-2054	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	1
04/27/2026 11:30	S26-2568	Block 1 Lot 5, Bais St., Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 13:20	S26-2558	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	2
04/27/2026 11:14	S26-2556	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
04/27/2026 11:20	S26-2557	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
04/30/2026 12:21	S26-2614	Water Pump, Amsterdam St., Town & Country	ABSENCE	ABSENCE	< 1
04/30/2026 12:32	S26-2615	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
04/27/2026 10:08	S26-2565	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	87
04/27/2026 10:40	S26-2566	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	33
04/27/2026 10:51	S26-2567	Block 1 Lot 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	8
BRGY. SORO-SORO					
04/21/2026 13:34	S26-2375	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
04/21/2026 14:12	S26-2376	#76 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
04/24/2026 11:17	S26-2531	Guardhouse, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
04/21/2026 10:31	S26-2383	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	5
04/21/2026 10:57	S26-2387	Drinking fountain, Dela Paz Main Elementary School	ABSENCE	ABSENCE	87
BRGY. ZAPOTE					
04/13/2026 17:56	S26-2183	Gate Entrance, Summer Breeze	ABSENCE	ABSENCE	5
04/13/2026 17:56	S26-2185	Evergreen Clubhouse	ABSENCE	ABSENCE	< 1
04/13/2026 17:56	S26-2184	Evergreen Elevated Water Tank	ABSENCE	ABSENCE	< 1
04/13/2026 17:56	S26-2191	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	34
04/13/2026 17:56	S26-2192	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	13
04/07/2026 11:26	S26-2065	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.