

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : Biñan City Health Office

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 68

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 08/05/2026-08/27/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
08/05/2026 14:40	S26-4651	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
08/06/2026 15:17	S26-4695	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	1
08/06/2026 15:29	S26-4696	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	3
08/06/2026 14:00	S26-4697	Pump XI, Phase V, San Jose Village II	ABSENCE	ABSENCE	9
08/06/2026 13:46	S26-4698	Clubhouse, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
08/06/2026 13:31	S26-4699	Clubhouse, Phase VI, San Jose Village III	ABSENCE	ABSENCE	< 1
08/06/2026 15:10	S26-4700	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
08/06/2026 14:59	S26-4701	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
08/25/2026 11:23	S26-5136	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
08/25/2026 11:46	S26-5144	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
08/25/2026 12:03	S26-5133	Clubhouse, Metroville Complex	ABSENCE	ABSENCE	< 1
BRGY. GANADO					
08/10/2026 10:50	S26-4761	Canteen, Ganado Elementary School	ABSENCE	ABSENCE	3
BRGY. LANGKIWA					
08/06/2026 10:48	S26-4705	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	3
08/06/2026 11:16	S26-4707	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
08/24/2026 12:59	S26-5108	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
08/06/2026 10:41	S26-4706	Water Pump, Southville Phase 5A	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
 Laboratory Service Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
 CONTACT NO.: (+63) 9177179465 / (+63) 9525919576
 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LOMA					
08/06/2026 11:41	S26-4702	Petron Fuel Gas Station, Celina Technopark	ABSENCE	ABSENCE	148
08/11/2026 12:55	S26-4789	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
08/11/2026 12:34	S26-4790	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
08/06/2026 12:53	S26-4704	Drinking Fountain, Loma Elementary School	ABSENCE	ABSENCE	261
BRGY. MAMPLASAN					
08/24/2026 14:38	S26-5121	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
08/10/2026 14:32	S26-4767	Amherst Laboratories (UNILAB)	ABSENCE	ABSENCE	27
08/24/2026 13:58	S26-5087	Mamplasan Elementary School	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
08/25/2026 10:31	S26-5140	Barangay Hall	ABSENCE	ABSENCE	< 1
BRGY. PLATERO					
08/06/2026 13:18	S26-4683	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	< 1
08/06/2026 11:18	S26-4685	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
08/06/2026 11:05	S26-4684	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
08/06/2026 11:33	S26-4686	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	318
08/06/2026 11:53	S26-4687	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	< 1
08/10/2026 13:21	S26-4763	Sea Oil, National Road	ABSENCE	ABSENCE	1
08/10/2026 13:59	S26-4765	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	5
08/06/2026 10:30	S26-4690	Water Pump, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
08/06/2026 10:45	S26-4691	Clubhouse, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO					
08/10/2026 11:52	S26-4770	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
08/10/2026 12:30	S26-4771	Alonte Stadium	ABSENCE	ABSENCE	< 1
08/10/2026 13:59	S26-4765	Block 1 Lot 13, Margarita Homes	ABSENCE	ABSENCE	5
08/25/2026 09:08	S26-5141	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	< 1
08/10/2026 14:32	S26-4767	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	27
08/10/2026 14:44	S26-4768	Jollibee, Pavilion Mall	ABSENCE	ABSENCE	< 1
08/25/2026 10:15	S26-5137	Malaban Health Center	ABSENCE	ABSENCE	< 1
08/25/2026 10:03	S26-5138	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	< 1
08/25/2026 09:54	S26-5139	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO					
08/10/2026 14:22	S26-4769	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh
 Laboratory Service Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN VICENTE					
08/24/2026 12:46	S26-5107	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	< 1
08/24/2026 11:19	S26-5109	Block 8 Lot 6, Olivarez Homes Subdivision	ABSENCE	ABSENCE	< 1
08/27/2026 08:38	S26-5192	Cistern Tank, Central Mall	ABSENCE	ABSENCE	< 1
08/10/2026 13:21	S26-4763	Biñan Doctors Hospital	ABSENCE	ABSENCE	1
BRGY. SANTO TOMAS					
08/10/2026 10:50	S26-4761	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	3
08/24/2026 11:58	S26-5116	Block 1 Lot 5, Bais St., Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
08/24/2026 12:29	S26-5106	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	< 1
08/24/2026 12:12	S26-5104	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
08/24/2026 12:18	S26-5105	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
08/24/2026 10:22	S26-5111	Water Pump, Amsterdam St., Town & Country	ABSENCE	ABSENCE	< 1
08/24/2026 10:30	S26-5112	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
08/24/2026 10:56	S26-5113	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
08/24/2026 11:29	S26-5114	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
08/24/2026 11:34	S26-5115	Block 1 Lot 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
BRGY. SORO-SORO					
08/25/2026 12:59	S26-5134	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
08/25/2026 12:41	S26-5135	#76 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
08/25/2026 12:41	S26-5120	Guardhouse, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
08/25/2026 10:53	S26-5142	Drinking fountain, Dela Paz Main Elementary School	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE					
08/06/2026 13:34	S26-4679	Gate Entrance, Summer Breeze	ABSENCE	ABSENCE	4
08/06/2026 13:48	S26-4680	Water Pump, Summer Breeze	ABSENCE	ABSENCE	43
08/06/2026 12:54	S26-4682	Evergreen Clubhouse	ABSENCE	ABSENCE	< 1
08/06/2026 12:39	S26-4681	Evergreen Elevated Water Tank	ABSENCE	ABSENCE	< 1
08/06/2026 09:41	S26-4688	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	< 1
08/06/2026 10:02	S26-4689	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	< 1
08/10/2026 11:38	S26-4772	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh
 Laboratory Service Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**– Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4651

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 14:40

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LAGUNA WELL FIELD, LAGUNA TECHNOPARK INC., - ANNEX, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
 Laboratory Services Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4652

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 13:17

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.67	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4653

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 13:50

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 2, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.98	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR

REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh.
 Laboratory Services Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4654

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 14:16

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 3, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4655

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 14:53

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 4, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.46	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4656

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 15:01

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUPERDOUGH FOOD AND CATERING CORP., LAGUNA TECHNOPARK INC., ANNEX, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4657

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 13:25

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LIFT STATION, PHASE 1, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.88	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4658

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 14:25

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SANYO PLASTIC PHILIPPINES INC., 110 EAST MAIN AVENUE., LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.58	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4659

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 14:00

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : ISUZU PHILIPPINES CORPORATION, 114 N MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.60	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4660

DATE/TIME SUBMITTED : 08/05/2026 15:12

DATE/TIME COLLECTION : 08/05/2026 13:34

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HONDA PARTS MANUFACTURING CORPORATION, 101 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.51	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/05/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/05/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/05/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/05/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4620

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:13

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUTABA CORP., 120 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.41	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:

Mabengjan
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4621

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 11:43

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUJITSU DIE-TECH CORP., 113 EAST SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4622

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:01

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : INTEGRATED MICRO-ELECTRONICS, N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.64	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4623

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:38

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : IK INABATA PHILIPPINES, CCMC COMPOUND 3, LOT 4 & 5, BLOCK 2 PHASE 7A, LAGUNA
TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.37	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4624

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:48

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PEZA LAGUNA TECHNOPARK, LOT 12 BLOCK 2 N. MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.70	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4625

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 11:54

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PORTION FILLERS INC., 106 COMMERCE ROAD, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.60	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4626

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 11:36

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : TECHNO FREEZE INC., 114 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.31	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR

REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEN Y. ALDAY, RCh.
 Laboratory Services Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4627

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:30

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : RYONAN ELECTRIC PHILIPPINES CORPORATION, 105 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.35	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR

REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh.
 Laboratory Services Manager
 License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4628

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 12:08

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : F. TECH PHILIPPINES MFG., INC., 118 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (+63) 9177179465 / (+63) 9525919576

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4629

DATE/TIME SUBMITTED : 08/04/2026 12:52

DATE/TIME COLLECTION : 08/04/2026 11:25

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUNPOWER PHILIPPINES, 100 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.33	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	08/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	08/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis