

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** LAGUNA AAAWATER CORPORATION

**ADDRESS :** G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

**ATTENTION :** BIÑAN CITY HEALTH OFFICE

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES :** 69

**TOTAL PARAMETERS TESTED:** 3

**ANALYSIS DATE(S) :** 02/05/2026-02/24/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>					
02/09/2026 13:46	S26-0874	Laguna Wellfield 1	ABSENCE	ABSENCE	310
02/19/2026 12:10	S26-1120	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	2
02/19/2026 12:19	S26-1121	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
02/19/2026 11:20	S26-1122	Pump XI, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
02/24/2026 11:43	S26-1217	Clubhouse, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
02/19/2026 11:01	S26-1124	Clubhouse, Phase VI, San Jose Village III	ABSENCE	ABSENCE	< 1
02/19/2026 12:30	S26-1125	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
02/19/2026 13:39	S26-1126	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	1
<b>BRGY. CANLALAY</b>					
02/11/2026 12:39	S26-0960	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	6
02/11/2026 10:53	S26-0961	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. HALANG</b>					
02/11/2026 11:14	S26-0956	9999 Water Pump, Metroville Complex	ABSENCE	ABSENCE	< 1
02/11/2026 11:29	S26-0957	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	< 1
<b>BRGY. GANADO</b>					
02/10/2026 13:27	S26-0909	Canteen, Ganado Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. LANGKIWA</b>					
02/19/2026 09:16	S26-1130	Drinking Fountain, Southville Elementary School	ABSENCE	ABSENCE	< 1
02/19/2026 09:29	S26-1132	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	1
02/18/2026 11:20	S26-1064	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
02/24/2026 11:25	S26-1218	Water Pump, Southville Phase 5A	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. LOMA</b>					
02/19/2026 10:21	S26-1127	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
02/05/2026 13:29	S26-0831	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
02/05/2026 13:20	S26-0832	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
02/19/2026 10:38	S26-1129	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	< 1
<b>BRGY. MAMPLASAN</b>					
02/19/2026 10:12	S26-1128	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	3
02/10/2026 13:55	S26-0916	Amherst Laboratories (UNILAB)	ABSENCE	ABSENCE	< 1
<b>BRGY. POBLACION</b>					
02/11/2026 09:59	S26-0967	Barangay Hall	ABSENCE	ABSENCE	< 1
<b>BRGY. PLATERO</b>					
02/09/2026 14:10	S26-0888	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	< 1
02/10/2026 10:27	S26-0927	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
02/10/2026 10:16	S26-0926	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
02/10/2026 10:42	S26-0928	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	< 1
02/24/2026 09:01	S26-1211	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	47
02/10/2026 11:34	S26-0913	Sea Oil, National Road	ABSENCE	ABSENCE	2
02/10/2026 12:00	S26-0914	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	9
02/10/2026 09:44	S26-0924	Water Pump, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
02/24/2026 09:17	S26-1212	Clubhouse, Jubilation Home Village - East	ABSENCE	ABSENCE	2
<b>BRGY. SAN ANTONIO</b>					
02/10/2026 08:34	S26-0920	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
02/10/2026 08:42	S26-0921	Alonte Stadium	ABSENCE	ABSENCE	< 1
02/10/2026 11:21	S26-0915	Block 5 Lot 1, Margarita Homes	ABSENCE	ABSENCE	6
02/11/2026 08:16	S26-0962	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
02/11/2026 07:53	S26-0968	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	< 1
02/10/2026 10:51	S26-0917	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	150
02/10/2026 10:58	S26-0918	Reyes Barbeque, Pavilion Mall	ABSENCE	ABSENCE	2
02/11/2026 08:44	S26-0963	Malaban Health Center	ABSENCE	ABSENCE	1
02/11/2026 08:36	S26-0964	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	1
02/24/2026 08:11	S26-1210	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO NIÑO</b>					
02/10/2026 11:08	S26-0919	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

*Marvin Jasper G. Abenojar*  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

*Kristeen Y. Alday*  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. SAN VICENTE</b>					
02/18/2026 10:01	S26-1065	Block 8 Lot 6 Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	< 1
02/18/2026 11:39	S26-1066	Cistern Tank, Central Mall	ABSENCE	ABSENCE	13
02/10/2026 11:52	S26-0912	Biñan Doctor's Hospital	ABSENCE	ABSENCE	19
<b>BRGY. SANTO TOMAS</b>					
02/10/2026 11:52	S26-0910	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	1
02/18/2026 11:55	S26-1072	Block 1 Lot 5, Bais St., Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
02/18/2026 11:11	S26-1063	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	5
02/18/2026 10:03	S26-1061	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
02/18/2026 10:50	S26-1062	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
02/18/2026 08:40	S26-1067	Water Pump, Amsterdam St., Town & Country	ABSENCE	ABSENCE	1
02/18/2026 08:59	S26-1068	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	3
02/18/2026 09:16	S26-1069	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
02/18/2026 09:27	S26-1070	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
02/18/2026 09:42	S26-1071	Block 1 Lot 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
<b>BRGY. SORO-SORO</b>					
02/11/2026 12:25	S26-0958	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	1
02/11/2026 12:13	S26-0959	#76 Manila S Road	ABSENCE	ABSENCE	< 1
<b>BRGY. TIMBAO</b>					
02/19/2026 09:41	S26-1133	Guardhouse, San Antonio South	ABSENCE	ABSENCE	< 1
<b>BRGY. DELA PAZ</b>					
02/11/2026 09:36	S26-0966	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	< 1
02/11/2026 10:03	S26-0969	Dela Paz National High School	ABSENCE	ABSENCE	< 1
<b>BRGY. ZAPOTE</b>					
02/09/2026 14:18	S26-0884	Water Pump, Summer Breeze	ABSENCE	ABSENCE	< 1
02/09/2026 14:28	S26-0885	Gate Entrance, Summer Breeze	ABSENCE	ABSENCE	1
02/09/2026 14:01	S26-0887	Clubhouse, Evergreen	ABSENCE	ABSENCE	< 1
02/09/2026 13:50	S26-0886	Evergreen Elevated Water Tank	ABSENCE	ABSENCE	< 1
02/09/2026 14:37	S26-0889	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	< 1
02/09/2026 14:43	S26-0890	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	< 1
02/10/2026 08:53	S26-0922	Clubhouse, Althea Residences	ABSENCE	ABSENCE	4

NOT VALID WITHOUT QR CODE



REVIEWED BY:

*Marvin Jasper G. Abenojar*  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

*Kristen Y. Alday*  
KRISTEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**REMARKS:** Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.

**METHODS:** **A**- Enzyme Substrate; **B**– Pour Plate

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0875

**DATE/TIME SUBMITTED** : 02/09/2026 14:49

**DATE/TIME COLLECTION** : 02/09/2026 12:43

**COLLECTED BY** : Jonnel S. Mercado

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.50	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN V. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0876

**DATE/TIME SUBMITTED** : 02/09/2026 14:49

**DATE/TIME COLLECTION** : 02/09/2026 13:06

**COLLECTED BY** : Jonnel S. Mercado

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BOOSTER 2, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.30</b>	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0877

**DATE/TIME SUBMITTED :** 02/09/2026 14:49

**DATE/TIME COLLECTION :** 02/09/2026 13:30

**COLLECTED BY :** Jonnel S. Mercado

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** BOOSTER 3, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.63</b>	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0878

**DATE/TIME SUBMITTED :** 02/09/2026 14:49

**DATE/TIME COLLECTION :** 02/09/2026 13:55

**COLLECTED BY :** Jonnel S. Mercado

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** BOOSTER 4, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.30</b>	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>1</b>	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0879

**DATE/TIME SUBMITTED** : 02/09/2026 14:49

**DATE/TIME COLLECTION** : 02/09/2026 14:10

**COLLECTED BY** : Jonnel S. Mercado

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : SUPERDOUGH FOOD AND CATERING CORP., LAGUNA TECHNOPARK INC., ANNEX, BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.33	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0880

**DATE/TIME SUBMITTED :** 02/09/2026 14:49

**DATE/TIME COLLECTION :** 02/09/2026 12:50

**COLLECTED BY :** Jonnel S. Mercado

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** LIFT STATION, PHASE 1, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.50	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0874

**DATE/TIME SUBMITTED :** 02/09/2026 14:49

**DATE/TIME COLLECTION :** 02/09/2026 13:46

**COLLECTED BY :** Jonnel S. Mercado

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** LAGUNA WELL FIELD, LAGUNA TECHNOPARK INC. ANNEX, BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.30</b>	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>310</b>	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0663

**DATE/TIME SUBMITTED** : 02/02/2026 12:04

**DATE/TIME COLLECTION** : 02/02/2026 11:55

**COLLECTED BY** : Elmer P. Palmares, Jr.

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : FUTABA CORPORATION, 120 N. SCIENCE AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.50	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)





**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0666

**DATE/TIME SUBMITTED :** 02/02/2026 12:04

**DATE/TIME COLLECTION :** 02/02/2026 10:01

**COLLECTED BY :** Elmer P. Palmares, Jr.

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** IK INABATA PHILIPPINES, CCMC COMPOUND 3, LOT 4 & 5, BLOCK 2 PHASE 7A, LAGUNA  
TECHNOPARK INC, BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.30	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0667

**DATE/TIME SUBMITTED :** 02/02/2026 12:04

**DATE/TIME COLLECTION :** 02/02/2026 10:58

**COLLECTED BY :** Elmer P. Palmares, Jr.

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** PEZA LAGUNA TECHNOPARK, LOT 12 BLOCK 2, NORTH MAIN AVENUE LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.43	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0668

**DATE/TIME SUBMITTED :** 02/02/2026 12:04

**DATE/TIME COLLECTION :** 02/02/2026 11:21

**COLLECTED BY :** Elmer P. Palmares, Jr.

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** PORTION FILLERS INC., 106 COMMERCE ROAD, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.95	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0670

**DATE/TIME SUBMITTED** : 02/02/2026 12:04

**DATE/TIME COLLECTION** : 02/02/2026 09:48

**COLLECTED BY** : Elmer P. Palmares, Jr.

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : RYONAN ELECTRIC PHILIPPINES CORPORATION, 105 EAST MAIN AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.30	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0671

**DATE/TIME SUBMITTED** : 02/02/2026 12:04

**DATE/TIME COLLECTION** : 02/02/2026 11:50

**COLLECTED BY** : Elmer P. Palmares, Jr.

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : F. TECH PHILIPPINES MANUFACTURING INC., 118 NORTH SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.52	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0883 **DATE/TIME SUBMITTED** : 02/09/2026 14:49

**DATE/TIME COLLECTION** : 02/09/2026 12:57 **COLLECTED BY** : Jonnel S. Mercado

**NO. OF SAMPLES** : 1 **TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : HONDA PARTS MANUFACTURING CORPORATION, 101 N. SCIENCE AVE., LAGUNA TECHNOPARK INC, BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.30	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/09/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-0669

**DATE/TIME SUBMITTED :** 02/02/2026 12:04

**DATE/TIME COLLECTION :** 02/02/2026 11:38

**COLLECTED BY :** Elmer P. Palmares, Jr.

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** A. LOGIS ARTICO, 114 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.87</b>	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-0672

**DATE/TIME SUBMITTED** : 02/02/2026 12:04

**DATE/TIME COLLECTION** : 02/02/2026 11:09

**COLLECTED BY** : Elmer P. Palmares, Jr.

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : SUNPOWER PHILIPPINES, 100 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BINAN CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.57	4500-Cl-G.DPD Colorimetric	02/02/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/02/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	170	9215B. Pour Plate Method	02/02/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)