

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : Biñan City Health Office

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 69

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 06/03/2026-06/25/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
06/04/2026 15:11	S26-3450	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
06/22/2026 13:37	S26-3815	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
06/22/2026 13:49	S26-3816	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
06/22/2026 12:25	S26-3817	Pump XI, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
06/22/2026 12:16	S26-3818	Clubhouse, Phase V, San Jose Village II	ABSENCE	ABSENCE	< 1
06/22/2026 11:59	S26-3819	Clubhouse, Phase VI, San Jose Village III	ABSENCE	ABSENCE	8
06/22/2026 13:25	S26-3820	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
06/22/2026 13:14	S26-3821	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
06/03/2026 13:06	S26-3416	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
06/03/2026 13:18	S26-3417	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
06/03/2026 13:35	S26-3413	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	< 1
BRGY. GANADO					
06/23/2026 08:36	S26-3860	Wash Area, Ganado Elementary School	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA					
06/25/2026 11:25	S26-3911	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	< 1
06/22/2026 10:10	S26-3827	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
06/15/2026 10:52	S26-3618	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	1
06/22/2026 09:42	S26-3826	Water Pump, Southville Phase 5A	ABSENCE	ABSENCE	73

NOT VALID WITHOUT QR CODE



REVIEWED BY:

MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LOMA					
06/22/2026 11:08	S26-3822	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
06/15/2026 14:26	S26-3659	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	1
06/15/2026 14:11	S26-3660	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	31
06/22/2026 10:59	S26-3824	Drinking Fountain, Loma Elementary School	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN					
06/22/2026 11:31	S26-3823	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
06/23/2026 09:08	S26-3866	Amherst Laboratories (UNILAB)	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
06/03/2026 12:11	S26-3423	Barangay Hall	ABSENCE	ABSENCE	< 1
BRGY. PLATERO					
06/08/2026 10:55	S26-3507	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	< 1
06/08/2026 12:21	S26-3509	Clubhouse, Prima Casa	ABSENCE	ABSENCE	< 1
06/23/2026 11:17	S26-3875	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	1
06/08/2026 12:34	S26-3510	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	7
06/08/2026 12:47	S26-3511	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	< 1
06/23/2026 12:45	S26-3862	Sea Oil, National Road	ABSENCE	ABSENCE	< 1
06/23/2026 13:14	S26-3864	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	5
06/08/2026 11:56	S26-3514	Water Pump, Jubilation Home Village - East	ABSENCE	ABSENCE	3
06/08/2026 11:42	S26-3515	Clubhouse, Jubilation Home Village - East	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO					
06/23/2026 09:51	S26-3870	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	31
06/23/2026 09:58	S26-3871	Alonte Stadium	ABSENCE	ABSENCE	1
06/23/2026 12:19	S26-3865	Block 1 Lot 13, Margarita Homes	ABSENCE	ABSENCE	30
06/03/2026 11:14	S26-3418	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
06/03/2026 10:55	S26-3424	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	< 1
06/23/2026 11:38	S26-3867	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
06/23/2026 11:47	S26-3868	Army Navy, Pavilion Mall	ABSENCE	ABSENCE	3
06/03/2026 11:38	S26-3419	Malaban Health Center	ABSENCE	ABSENCE	< 1
06/03/2026 11:56	S26-3420	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	< 1
06/03/2026 11:51	S26-3421	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO					
06/23/2026 12:03	S26-3869	Jollibee National Hi-Way	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
 Laboratory Service Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN VICENTE					
06/15/2026 10:45	S26-3617	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	1
06/15/2026 09:48	S26-3619	Block 8 Lot 6, Olivarez Homes Subdivision	ABSENCE	ABSENCE	< 1
06/15/2026 11:09	S26-3620	Cistern Tank, Central Mall	ABSENCE	ABSENCE	1
06/23/2026 13:01	S26-3863	Biñan Doctors Hospital	ABSENCE	ABSENCE	275
BRGY. SANTO TOMAS					
06/23/2026 10:34	S26-3861	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	25
06/15/2026 12:40	S26-3626	Block 1 Lot 5, Bais St., Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
06/15/2026 11:29	S26-3616	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	< 1
06/15/2026 10:14	S26-3614	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	1
06/15/2026 10:21	S26-3615	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
06/15/2026 08:29	S26-3621	Water Pump, Amsterdam St., Town & Country	ABSENCE	ABSENCE	3
06/15/2026 08:39	S26-3622	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	3
06/15/2026 08:54	S26-3623	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
06/15/2026 09:15	S26-3624	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
06/15/2026 09:19	S26-3625	Block 1 Lot 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
BRGY. SORO-SORO					
06/03/2026 14:21	S26-3414	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
06/03/2026 14:09	S26-3415	#76 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
06/22/2026 10:39	S26-3828	Guardhouse, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
06/03/2026 12:30	S26-3422	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	< 1
06/03/2026 12:45	S26-3426	Drinking fountain, Dela Paz Main Elementary School	ABSENCE	ABSENCE	48
BRGY. ZAPOTE					
06/08/2026 10:03	S26-3504	Gate Entrance, Summer Breeze	ABSENCE	ABSENCE	< 1
06/08/2026 09:52	S26-3503	Water Pump, Summer Breeze	ABSENCE	ABSENCE	< 1
06/23/2026 09:29	S26-3874	Evergreen Clubhouse	ABSENCE	ABSENCE	< 1
06/08/2026 10:30	S26-3505	Evergreen Elevated Water Tank	ABSENCE	ABSENCE	2
06/08/2026 11:10	S26-3512	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	21
06/08/2026 11:20	S26-3513	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	< 1
06/23/2026 10:09	S26-3872	Clubhouse, Althea Residences	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR CODE

REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
 Laboratory Service Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**– Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3295

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 10:29

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUTABA CORP., 120 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.41	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR

REVIEWED BY:

MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

KRISTEEN Y. ALDAY, RCh.
 Laboratory Services Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3296

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 11:00

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FUJITSU DIE-TECH CORP., 113 EAST SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.31	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3297

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 11:17

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : INTEGRATED MICRO-ELECTRONICS, N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.08	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3298

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 11:58

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PEZA LAGUNA TECHNOPARK, LOT 12 BLOCK 2 N. MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.92	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3299

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 11:09

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PORTION FILLERS INC., 106 COMMERCE ROAD, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.84	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3300

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 10:48

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : TECHNO FREEZE INC., 114 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.29	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3302

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 11:25

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : F. TECH PHILIPPINES MFG., INC., 118 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.73	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3303

DATE/TIME SUBMITTED : 06/01/2026 12:08

DATE/TIME COLLECTION : 06/01/2026 10:32

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUNPOWER PHILIPPINES, 100 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.90	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/01/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/01/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/01/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3438

DATE/TIME SUBMITTED : 06/04/2026 14:45

DATE/TIME COLLECTION : 06/04/2026 14:19

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : RYONAN ELECTRIC PHILIPPINES CORPORATION, 105 EAST MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.94	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	EPP
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	18	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3450

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 15:11

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LAGUNA WELL FIELD, LAGUNA TECHNOPARK INC., - ANNEX, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.32	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3451

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 13:25

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.60	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3452

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 14:04

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 2, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.14	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3455

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 14:57

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SUPERDOUGH FOOD AND CATERING CORP., LAGUNA TECHNOPARK INC., ANNEX, BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.36	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3456

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 13:37

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : LIFT STATION, PHASE 1, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.70	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	38	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3457

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 14:40

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SANYO PLASTIC PHILIPPINES INC., 110 EAST MAIN AVENUE., LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.52	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3458

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 14:15

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : ISUZU PHILIPPINES CORPORATION, 114 N MAIN AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.61	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3459

DATE/TIME SUBMITTED : 06/04/2026 15:36

DATE/TIME COLLECTION : 06/04/2026 13:50

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HONDA PARTS MANUFACTURING CORPORATION, 101 N. SCIENCE AVENUE, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/04/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/04/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/04/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3740

DATE/TIME SUBMITTED : 06/17/2026 14:21

DATE/TIME COLLECTION : 06/17/2026 14:12

COLLECTED BY : Elmer P. Palmares, Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : IK INABATA PHILIPPINES, CCMC COMPOUND 3, LOT 4 & 5, BLOCK 2 PHASE 7A, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/17/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/17/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/17/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/17/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3912

DATE/TIME SUBMITTED : 06/25/2026 13:30

DATE/TIME COLLECTION : 06/25/2026 13:24

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 3, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.05	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/25/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/25/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/25/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/25/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-3913

DATE/TIME SUBMITTED : 06/25/2026 13:30

DATE/TIME COLLECTION : 06/25/2026 13:08

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 4, LAGUNA TECHNOPARK INC., BIÑAN CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.32	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	06/25/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/25/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	06/25/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	06/25/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*-Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis