

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 68

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 06/02/2020-06/25/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
06/02/2020 11:19	S20-3503	Laguna Wellfield 1	7.40 / 28.0	0.32	ABSENCE	ABSENCE	< 1
06/22/2020 08:39	S20-3952	Guardhouse Entrance, Phase 4C, San Jose Village I	7.16 / 31.2	0.38	ABSENCE	ABSENCE	1
06/22/2020 08:58	S20-3953	Clubhouse, Phase 3B, San Jose Village I	7.21 / 30.5	0.42	ABSENCE	ABSENCE	< 1
06/22/2020 09:16	S20-3954	Pump 11, Phase 5, San Jose Village II	7.11 / 29.6	0.37	ABSENCE	ABSENCE	< 1
06/22/2020 09:29	S20-3955	Clubhouse, Phase 5, San Jose Village II	7.13 / 30.1	0.25	ABSENCE	ABSENCE	< 1
06/22/2020 09:49	S20-3956	Clubhouse, Phase 6, San Jose Village III	7.16 / 29.6	0.24	ABSENCE	ABSENCE	< 1
06/22/2020 10:01	S20-3957	Main Gate, AVIDA Shophouse	7.13 / 30.1	0.34	ABSENCE	ABSENCE	< 1
06/22/2020 10:17	S20-3958	De La Salle University and Technology Complex	7.20 / 30.5	0.32	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
06/23/2020 11:20	S20-4242	Clubhouse, Golden City Canlalay	7.14 / 29.0	0.27	ABSENCE	ABSENCE	< 1
06/23/2020 11:36	S20-4243	Drinkinf Fountain, Canlalay Elementary School	7.18 / 27.5	0.28	ABSENCE	ABSENCE	1
BRGY. DELA PAZ							
06/23/2020 13:10	S20-4248	Water Pump, Almeda Subdivision	7.46 / 29.0	0.65	ABSENCE	ABSENCE	< 1
06/23/2020 13:20	S20-4249	Barangay Hall	7.29 / 29.6	0.55	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
06/23/2020 11:00	S20-4238	9999 Water Pump Metroville Complex	7.09 / 28.7	0.48	ABSENCE	ABSENCE	< 1
06/23/2020 11:18	S20-4239	Clubhouse, Metroville Complex	7.89 / 30.2	0.37	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
06/24/2020 14:35	S20-4269	Block 65 Lot 3, Phase II, Southville	7.20 / 30.2	0.75	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060958)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
06/22/2020 12:11	S20-3963	Drinking Fountain, Southville 5A National High School	7.21 / 30.6	0.25	ABSENCE	ABSENCE	< 1
06/22/2020 11:45	S20-3964	Drinking Fountain, Langkiwa Elementary School	7.14 / 30.3	0.29	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
06/22/2020 10:40	S20-3959	Block 43 Lot 13, Celina Technopark	7.11 / 30.1	0.41	ABSENCE	ABSENCE	< 1
06/22/2020 11:16	S20-3961	Drinking Fountain, Loma Elementary School	7.18 / 30.2	0.27	ABSENCE	ABSENCE	< 1
06/23/2020 12:23	S20-4024	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air III	6.48 / 27.1	0.96	ABSENCE	ABSENCE	4
06/23/2020 12:30	S20-4025	Hilcrest Road, Block 10 Lot 24, Laguna Bel-Air III	6.89 / 28.1	0.85	ABSENCE	ABSENCE	2
06/23/2020 12:39	S20-4026	Clubhouse, Laguna Bel-Air III	6.74 / 31.0	0.82	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
06/22/2020 11:09	S20-3960	Clubhouse, Verdana Homes Subdivision	7.16 / 29.7	0.30	ABSENCE	ABSENCE	< 1
06/22/2020 14:23	S20-3969	United Laboratories (UNILAB) Inc.	7.31 / 27.8	0.88	ABSENCE	ABSENCE	1
BRGY. POBLACION							
06/23/2020 14:15	S20-4250	Water Pump, Poblacion	7.30 / 29.8	0.40	ABSENCE	ABSENCE	1
06/23/2020 14:59	S20-4251	Barangay Hall, Poblacion	7.29 / 30.2	0.30	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
06/23/2020 10:01	S20-4232	Elevated Water Tank, Mondo Bambini	7.27 / 30.1	0.20	ABSENCE	ABSENCE	< 1
06/23/2020 10:20	S20-4233	Clubhouse, Mondo Bambini	7.18 / 30.6	0.12	ABSENCE	ABSENCE	3
06/24/2020 11:26	S20-4228	Elevated Water Tank, Prima Casa	7.30 / 30.4	0.26	ABSENCE	ABSENCE	110
06/23/2020 12:48	S20-4235	Clubhouse, Prima Casa	7.25 / 29.8	0.10	ABSENCE	ABSENCE	< 1
06/23/2020 11:58	S20-4236	Water Pump, Spring Time	7.16 / 29.5	0.10	ABSENCE	ABSENCE	2
06/23/2020 12:10	S20-4237	Block 1 Lot 7, Spring Time	7.16 / 30.5	0.18	ABSENCE	ABSENCE	< 1
06/22/2020 12:26	S20-3971	Sea-oil, National Road	7.16 / 31.7	0.82	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO							
06/22/2020 14:11	S20-3977	Biñan City Hall	7.22 / 29.6	1.23	ABSENCE	ABSENCE	< 1
06/22/2020 14:06	S20-3978	Alonte Stadium	7.27 / 30.7	1.06	ABSENCE	ABSENCE	< 1
06/22/2020 12:53	S20-3972	Water Pump, Margarita Homes Subdivision	7.37 / 29.5	1.19	ABSENCE	ABSENCE	15
06/22/2020 13:02	S20-3973	Block 15 Lot 18, Margarita Homes Subdivision	7.38 / 33.0	0.77	ABSENCE	ABSENCE	< 1
06/23/2020 11:40	S20-4244	9022 Water Pump, Faraon Subdivision	7.09 / 29.0	0.38	ABSENCE	ABSENCE	< 1
06/22/2020 13:50	S20-3975	Army Navy, Pavillion Mall	7.35 / 31.1	0.58	ABSENCE	ABSENCE	3

NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No.(s) (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
06/22/2020 12:32	S20-3962	Jacobo Integrated National High School	7.14 / 24.7	0.35	ABSENCE	ABSENCE	1
06/22/2020 13:36	S20-3974	Cistern Tank, Pavillion Mall	7.38 / 29.3	0.68	ABSENCE	ABSENCE	< 1
06/23/2020 12:00	S20-4245	Faraon Health Center	7.69 / 30.1	0.51	ABSENCE	ABSENCE	< 1
06/23/2020 12:15	S20-4246	Malabanan St.	7.76 / 30.1	0.36	ABSENCE	ABSENCE	< 1
06/23/2020 12:37	S20-4247	Lumibaw St.	7.18 / 27.5	0.31	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
06/22/2020 13:23	S20-3976	Jollibee National Hi-Way	7.30 / 29.2	0.75	ABSENCE	ABSENCE	1
BRGY. SAN VICENTE							
06/22/2020 11:32	S20-3980	407 Water Pump, San Vicente Subdivision	7.07 / 29.9	0.04	ABSENCE	ABSENCE	6
06/24/2020 12:17	S20-4270	Drinking Fountain, San Vicente Elementary School	7.23 / 32.1	0.78	ABSENCE	ABSENCE	3
06/24/2020 12:48	S20-4271	Block 8 Lot 6, Bayabas St., Phase 7 Olivarez Homes	7.12 / 29.2	0.82	ABSENCE	ABSENCE	3
06/24/2020 11:59	S20-4272	Cistern Tank, Central Mall	7.37 / 34.7	0.39	ABSENCE	ABSENCE	6
BRGY. SANTO TOMAS							
06/22/2020 10:57	S20-3970	Water Pump, Adelina Subdivision	6.90 / 28.3	0.06	ABSENCE	ABSENCE	< 1
06/23/2020 15:46	S20-4253	HOA Office, Adelina Subdivision	6.77 / 31.1	1.05	ABSENCE	ABSENCE	1
06/24/2020 10:41	S20-4277	Water Pump, Pragmatic	7.08 / 39.0	0.25	ABSENCE	ABSENCE	8
06/24/2020 10:50	S20-4278	Block 1 Lot 5, Bais St., Pragmatic	7.25 / 29.1	0.08	ABSENCE	ABSENCE	1
06/24/2020 13:10	S20-4267	Block 42 Lot 16 Tawi Tawi St., Phase 6, South City Homes	7.07 / 28.7	0.80	ABSENCE	ABSENCE	< 1
06/24/2020 11:20	S20-4265	Pump, South Plains II Subdivision	7.21 / 28.7	0.21	ABSENCE	ABSENCE	1
06/24/2020 11:02	S20-4266	Block 11 Lot 2, South Plains II Subdivision	7.23 / 29.5	0.06	ABSENCE	ABSENCE	2
06/24/2020 14:02	S20-4273	Water Pump, Town & Country, Amsterdam	7.18 / 32.8	0.24	ABSENCE	ABSENCE	4
06/24/2020 14:09	S20-4274	Blk 35 Lt 21, Town & Country, Amsterdam	7.24 / 31.9	0.22	ABSENCE	ABSENCE	2
06/24/2020 14:16	S20-4275	Blk 2 Lt 5, Town & Country, Pennsylvania	7.39 / 28.9	0.64	ABSENCE	ABSENCE	2
06/24/2020 13:38	S20-4276	Blk 1 Lt 13, Phase 4, Olivarez Home South	7.19 / 28.5	0.82	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
06/23/2020 10:30	S20-4240	Water Pump, 9067 Manila S Road	7.08 / 27.6	0.32	ABSENCE	ABSENCE	3
06/23/2020 10:41	S20-4241	#76 Manila S Road	7.90 / 29.8	0.28	ABSENCE	ABSENCE	3
BRGY. TUBIGAN							
06/24/2020 12:31	S20-4268	#60 Florinda Compound	7.14 / 31.2	0.05	ABSENCE	ABSENCE	2
BRGY. ZAPOTE							
06/23/2020 11:16	S20-4228	Water Pump, Summer Breeze	7.24 / 30.6	0.15	ABSENCE	ABSENCE	5

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



JETHRO D. ESCOBIN
Microbiology Unit Manager

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
06/23/2020 11:29	S20-4229	Clubhouse, Summer Breeze	7.20 / 30.1 MDL: NA LOQ: NA	0.08 MDL: 0.06 LOQ: 0.20	ABSENCE	ABSENCE	2
06/23/2020 10:47	S20-4230	Elevated Water Tank, Evergreen	7.18 / 30.7	0.17	ABSENCE	ABSENCE	3
06/23/2020 11:03	S20-4231	Clubhouse, Evergreen	7.16 / 30.1	0.07	ABSENCE	ABSENCE	2
06/22/2020 10:35	S20-3979	Clubhouse, Althea Residences	6.72 / 33.7	0.60	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060958)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.