

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 67

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 04/01/2020-04/23/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
04/01/2020 14:11	S20-2006	Laguna Wellfield 1	7.52 / 28.6	0.69	ABSENCE	ABSENCE	1
04/03/2020 10:12	S20-2067	Guardhouse Entrance, Phase 4C, San Jose Village I	7.28 / 30.2	0.42	ABSENCE	ABSENCE	< 1
04/03/2020 10:30	S20-2068	Clubhouse, Phase 3B, San Jose Village I	7.25 / 29.0	0.30	ABSENCE	ABSENCE	< 1
04/03/2020 10:53	S20-2069	Pump 11, Phase 5, San Jose Village II	7.25 / 30.4	0.38	ABSENCE	ABSENCE	< 1
04/03/2020 11:13	S20-2070	Clubhouse, Phase 5, San Jose Village II	7.27 / 30.6	0.47	ABSENCE	ABSENCE	< 1
04/03/2020 13:55	S20-2071	Clubhouse, Phase 6, San Jose Village III	7.22 / 30.2	0.42	ABSENCE	ABSENCE	< 1
04/03/2020 11:29	S20-2072	Main Gate, AVIDA Shophouse	7.23 / 29.8	0.40	ABSENCE	ABSENCE	< 1
04/03/2020 11:48	S20-2073	Parking Lot Faucet, De La Salle University and Technology Complex	7.27 / 27.3	0.55	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
04/17/2020 11:16	S20-2542	Clubhouse, Golden City Canlalay	7.18 / 28.7	0.30	ABSENCE	ABSENCE	48
04/17/2020 11:24	S20-2543	Drinking Fountain, Canlalay Elementary School	7.21/ 28.7	0.34	ABSENCE	ABSENCE	23
BRGY. DELA PAZ							
04/17/2020 12:58	S20-2548	Water Pump, Almeda Subdivision	7.13 / 29.7	0.32	ABSENCE	ABSENCE	350
04/17/2020 13:22	S20-2549	Barangay Hall	7.21 / 30.3	0.25	ABSENCE	ABSENCE	190
BRGY. HALANG							
04/17/2020 10:40	S20-2538	9999 WP Metroville Complex	7.14 / 29.3	0.45	ABSENCE	ABSENCE	120
04/17/2020 10:59	S20-2539	Clubhouse, Metroville Complex	7.25 / 29.7	0.40	ABSENCE	ABSENCE	47
BRGY. LANGKIWA							
04/03/2020 14:08	S20-2084	Block 3 Lot 9, Phase II, Southville	7.48 / 28.4	0.34	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
04/03/2020 12:39	S20-2078	Drinking Fountain, Southville 5A National High School	7.20 / 29.8	0.40	ABSENCE	ABSENCE	< 1
04/03/2020 12:17	S20-2079	Drinking Fountain, Langkiwa Elementary School	7.18 / 29.7	0.47	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
04/03/2020 12:01	S20-2074	Block 43 Lot 13, Celina Technopark	7.28 / 30.3	0.27	ABSENCE	ABSENCE	< 1
04/03/2020 12:16	S20-2076	Drinking Fountain, Loma Elementary School	7.25 / 30.3	0.30	ABSENCE	ABSENCE	16
04/16/2020 12:19	S20-2477	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air III	7.14 / 29.5	0.35	ABSENCE	ABSENCE	< 1
04/16/2020 12:25	S20-2478	Hilcrest Road, Block 24 Lot 10, Laguna Bel-Air III	7.11 / 29.8	0.38	ABSENCE	ABSENCE	3
04/16/2020 12:41	S20-2479	Clubhouse, Laguna Bel-Air III	7.21 / 29.8	0.27	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
04/03/2020 13:40	S20-2075	Clubhouse, Verdana Homes Subdivision	7.20 / 30.6	0.34	ABSENCE	ABSENCE	< 1
04/23/2020 12:52	S20-2628	United Laboratories (UNILAB) Inc.	8.03 / 28.8	0.65	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
04/17/2020 13:38	S20-2550	Water Pump, Poblacion	7.21 / 30.3	0.25	ABSENCE	ABSENCE	-
04/17/2020 13:59	S20-2551	Barangay Hall, Poblacion	7.18 / 29.3	0.24	ABSENCE	ABSENCE	-
BRGY. PLATERO							
04/15/2020 10:10	S20-2412	Elevated Water Tank, Mondo Bambini	7.02 / 28.9	0.25	ABSENCE	ABSENCE	15
04/15/2020 10:17	S20-2413	Clubhouse, Mondo Bambini	7.09 / 28.7	0.20	ABSENCE	ABSENCE	27
04/15/2020 11:27	S20-2414	Elevated Water Tank, Prima Casa	7.09 / 28.1	0.06	ABSENCE	ABSENCE	16
04/15/2020 11:38	S20-2415	Clubhouse, Prima Casa	7.15 / 28.6	0.03	ABSENCE	ABSENCE	1
04/15/2020 11:59	S20-2416	Water Pump, Spring Time	7.11 / 29.1	0.05	ABSENCE	ABSENCE	1
04/15/2020 12:10	S20-2417	Block 1 Lot 7, Spring Time	7.14 / 29.6	0.05	ABSENCE	ABSENCE	< 1
04/23/2020 10:58	S20-2630	Sea-oil, National Road	7.78 / 34.9	0.50	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO							
04/23/2020 12:38	S20-2636	Biñan City Hall	7.84 / 30.8	0.89	ABSENCE	ABSENCE	< 1
04/23/2020 12:46	S20-2637	Alonte Stadium	7.95 / 31.1	1.12	ABSENCE	ABSENCE	< 1
04/23/2020 11:11	S20-2631	Water Pump, Margarita Homes Subdivision	7.81 / 31.0	0.67	ABSENCE	ABSENCE	< 1
04/23/2020 11:21	S20-2632	Block 1 Lot 12, Margarita Homes Subdivision	7.86 / 31.4	0.58	ABSENCE	ABSENCE	4
04/17/2020 11:42	S20-2544	9022 Water Pump, Faraon Subdivision	7.16 / 30.6	0.42	ABSENCE	ABSENCE	55
04/17/2020 11:59	S20-2545	Faraon Health Center	7.21 / 29.8	0.35	ABSENCE	ABSENCE	17

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s): (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/17/2020 12:11	S20-2546	Drinking Fountain 1, Faraon Elementary School	7.23 / 30.3	0.27	ABSENCE	ABSENCE	39
04/17/2020 12:23	S20-2547	Drinking Fountain 2, Faraon Elementary School	7.24 / 30.6	0.25	ABSENCE	ABSENCE	88
04/23/2020 11:5	S20-2634	Watson, Pavillion Mall	7.78 / 33.7	0.42	ABSENCE	ABSENCE	< 1
04/03/2020 13:10	S20-2077	Jacobo Integrated National High School	7.23 / 29.6	0.32	ABSENCE	ABSENCE	< 1
04/23/2020 10:31	S20-2633	Cistern Tank, Pavillion Mall	7.88 / 31.0	0.73	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
04/23/2020 10:50	S20-2635	Jollibee National Hi-Way	8.08 / 30.5	0.61	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
04/23/2020 11:37	S20-2639	407 Water Pump, San Vicente Subdivision	7.80 / 31.5	0.30	ABSENCE	ABSENCE	< 1
04/03/2020 12:58	S20-2085	Block 8 Lot 6, Bayabas St., Phase 7 Olivarez Homes	7.60 / 31.1	0.15	ABSENCE	ABSENCE	84
04/03/2020 13:17	S20-2086	Cistern Tank, Central Mall	8.01 / 33.5	0.04	ABSENCE	ABSENCE	390
BRGY. SANTO TOMAS							
04/23/2020 11:58	S20-2629	Water Pump, Adelina Subdivision	8.15 / 30.2	0.33	ABSENCE	ABSENCE	1
04/23/2020 12:09	S20-2640	HOA Office, Adelina Subdivision	7.85 / 32.6	0.56	ABSENCE	ABSENCE	< 1
04/03/2020 12:06	S20-2091	Water Pump, Pragmatic	7.80 / 30.2	0.17	ABSENCE	ABSENCE	< 1
04/03/2020 12:18	S20-2092	Block 1 Lot 5, Bais St., Pragmatic	7.66 / 31.2	0.08	ABSENCE	ABSENCE	< 1
04/03/2020 11:25	S20-2082	Block 42 Lot 16 Tawi Tawi St., Phase 6, South City Homes	8.02 / 32.2	0.18	ABSENCE	ABSENCE	< 1
04/03/2020 11:48	S20-2080	Pump, South Plains II Subdivision	7.65 / 29.6	0.77	ABSENCE	ABSENCE	1
04/03/2020 11:41	S20-2081	Block 11 Lot 2, South Plains II Subdivision	7.56 / 31.5	0.83	ABSENCE	ABSENCE	< 1
04/03/2020 10:16	S20-2087	Water Pump, Town & Country, Amsterdam	7.89 / 28.5	0.60	ABSENCE	ABSENCE	1
04/03/2020 10:28	S20-2088	Blk 35 Lt 21, Town & Country, Amsterdam	7.68 / 28.9	0.54	ABSENCE	ABSENCE	< 1
04/03/2020 10:44	S20-2089	Blk 2 Lt 5, Town & Country, Pennsylvania	7.68 / 30.1	0.31	ABSENCE	ABSENCE	< 1
04/03/2020 11:03	S20-2090	Blk 1 Lt 16, Phase 4, Olivarez Home South	7.26 / 29.6	0.26	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
04/17/2020 10:10	S20-2540	Water Pump, 9067 Manila S Road	7.22 / 29.2	0.27	ABSENCE	ABSENCE	9
04/17/2020 10:16	S20-2541	#76 Manila S Road	7.27 / 30.1	0.23	ABSENCE	ABSENCE	66
BRGY. TUBIGAN							
04/03/2020 13:37	S20-2083	#60 Florinda Compound	8.02 / 32.2	0.18	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
04/15/2020 11:03	S20-2408	Water Pump, Summer Breeze	7.71 / 28.4	0.70	ABSENCE	ABSENCE	24
04/15/2020 11:16	S20-2409	Clubhouse, Summer Breeze	7.70 / 28.7	0.05	ABSENCE	ABSENCE	37

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/15/2020 10:24	S20-2410	Elevated Water Tank, Evergreen	7.77 / 29.7	0.05	ABSENCE	ABSENCE	9
04/15/2020 10:49	S20-2411	Clubhouse, Evergreen	7.76 / 29.1	0.03	ABSENCE	ABSENCE	6
04/23/2020 12:00	S20-2638	Clubhouse, Althea Residences	7.97 / 30.9	0.29	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A – Electrometric; B – Colorimetric; C- Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.