

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
 CONTACT NO.: (049) 543-1916
 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 70

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 01/20/2020-01/31/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	PARAMETER		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
01/20/2020 15:27	S20-0394	Guardhouse Entrance, Phase 4C, San Jose Village I	7.03 / 27.7	0.65	ABSENCE	ABSENCE	< 1
01/20/2020 11:44	S20-0395	Clubhouse, Phase 3B, San Jose Village I	7.09 / 27.6	0.49	ABSENCE	ABSENCE	< 1
01/20/2020 11:19	S20-0396	Pump 11, Phase 5, San Jose Village II	7.22 / 27.2	0.52	ABSENCE	ABSENCE	< 1
01/20/2020 11:31	S20-0397	Clubhouse, Phase 5, San Jose Village II	7.24 / 27.7	0.97	ABSENCE	ABSENCE	< 1
01/20/2020 11:02	S20-0398	Clubhouse, Phase 6, San Jose Village III	7.50 / 28.2	0.94	ABSENCE	ABSENCE	< 1
01/20/2020 15:38	S20-0399	Burgies Convenience Store, AVIDA Shophouse	7.12 / 30.6	0.62	ABSENCE	ABSENCE	< 1
01/20/2020 15:15	S20-0400	De La Salle University and Technology Complex	7.49 / 28.2	0.40	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
01/29/2020 12:01	S20-0578	Clubhouse, Golden City Canlalay	7.20 / 29.2	0.62	ABSENCE	ABSENCE	< 1
01/29/2020 12:24	S20-0579	Drinking Fountain, Canlalay Elementary School	7.10 / 28.9	0.73	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
01/29/2020 11:17	S20-0584	Water Pump, Almeda Subdivision	7.50 / 29.5	0.89	ABSENCE	ABSENCE	< 1
01/29/2020 11:36	S20-0585	Barangay Hall	7.43 / 29.2	0.07	ABSENCE	ABSENCE	1
BRGY. GANADO							
01/21/2020 14:02	S20-0432	Ganado Elementary School	7.35 / 28.5	0.85	ABSENCE	ABSENCE	5
BRGY. HALANG							
01/29/2020 12:50	S20-0574	9999 WP Metroville Complex	7.25 / 28.8	0.86	ABSENCE	ABSENCE	1
01/29/2020 12:50	S20-0575	Block 30 Lot 17, Metroville Complex	7.20 / 29.0	0.93	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
01/28/2020 08:40	S20-0552	Block 3 Lot 9, Phase II, Southville	7.39 / 27.5	0.38	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR STAMP



TR20-0274

February 3, 2020 8:50 PM

ORIG



ANALYZED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
01/20/2020 13:32	S20-0404	Drinking Fountain, Southville 5A National High School	7.25 / 28.9	0.49	ABSENCE	ABSENCE	12
01/20/2020 13:39	S20-0405	Drinking Fountain, Langkwa Elementary School	7.35 / 27.7	1.06	ABSENCE	ABSENCE	5
BRGY. LOMA							
01/20/2020 12:47	S20-0401	Block 43 Lot 13, Celina Technopark	7.18 / 27.8	1.00	ABSENCE	ABSENCE	< 1
01/20/2020 12:27	S20-0403	Drinking Fountain, Loma Elementary School	7.21 / 27.7	1.01	ABSENCE	ABSENCE	1
01/21/2020 14:20	S20-0417	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air III	7.58 / 26.5	0.80	ABSENCE	ABSENCE	-
01/21/2020 14:55	S20-0418	Hilcrest Road, Block 2, Laguna Bel-Air III	7.04 / 28.5	1.08	ABSENCE	ABSENCE	-
01/21/2020 14:47	S20-0419	Clubhouse, Laguna Bel-Air III	7.12 / 29.9	1.01	ABSENCE	ABSENCE	-
BRGY. MAMPLASAN							
01/20/2020 13:07	S20-0402	Clubhouse, Verdana Homes Subdivision	7.19 / 27.8	0.98	ABSENCE	ABSENCE	< 1
01/21/2020 13:42	S20-0433	United Laboratories (UNILAB) Inc.	7.33 / 27.7	0.91	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
01/29/2020 09:39	S20-0586	Water Pump, Poblacion	7.16 / 28.8	0.13	ABSENCE	ABSENCE	220
01/29/2020 09:31	S20-0587	Barangay Hall, Poblacion	7.20 / 28.2	0.74	ABSENCE	ABSENCE	1
BRGY. PLATERO							
01/20/2020 10:30	S20-0387	Elevated Water Tank, Mondo Bambini	7.17 / 28.8	0.40	ABSENCE	ABSENCE	< 1
01/20/2020 10:40	S20-0388	Clubhouse, Mondo Bambini	7.09 / 27.5	0.35	ABSENCE	ABSENCE	< 1
01/20/2020 12:48	S20-0389	Elevated Water Tank, Prima Casa	7.00 / 27.6	0.30	ABSENCE	ABSENCE	3
01/20/2020 13:00	S20-0390	Clubhouse, Prima Casa	7.10 / 27.4	0.25	ABSENCE	ABSENCE	5
01/20/2020 12:30	S20-0391	Water Pump, Spring Time	7.47 / 27.9	0.28	ABSENCE	ABSENCE	7
01/20/2020 12:40	S20-0392	Block 1 Lot 7, Spring Time	7.29 / 25.0	<0.20	ABSENCE	ABSENCE	3
01/21/2020 09:05	S20-0437	Drinking Fountain, St. Michael School of Biñan	7.45 / 28.1	0.95	ABSENCE	ABSENCE	< 1
01/21/2020 09:30	S20-0435	Sea-oil, National Road	7.25 / 29.3	0.73	ABSENCE	ABSENCE	1
BRGY. SAN ANTONIO							
01/21/2020 13:27	S20-0443	Biñan City Hall	7.53 / 29.2	0.02	ABSENCE	ABSENCE	31
01/21/2020 13:18	S20-0444	Alonte Stadium	7.51 / 29.6	0.03	ABSENCE	ABSENCE	< 1
01/21/2020 13:42	S20-0438	Water Pump, Margarita Homes Subdivision	7.70 / 29.0	0.67	ABSENCE	ABSENCE	< 1
01/21/2020 09:48	S19-0439	Block 5 Lot 12, Margarita Homes Subdivision	7.64 / 28.1	0.69	ABSENCE	ABSENCE	< 1
01/29/2020 09:56	S20-0579	9022 Water Pump, Faraon Subdivision	7.53 / 30.6	0.86	ABSENCE	ABSENCE	< 1
01/29/2020 10:21	S20-0580	Faraon Health Center	7.46 / 28.0	0.78	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR STAMP



TR20-0274

February 3, 2020 8:50 PM

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis



ANALYZED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUERRERAZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
01/29/2020 10:39	S20-0581	Drinking Fountain 1, Faraon Elementary School	7.51 / 29.2	0.83	ABSENCE	ABSENCE	1
01/29/2020 10:39	S20-0582	Drinking Fountain 2, Faraon Elementary School	7.56 / 29.9	0.97	ABSENCE	ABSENCE	5
01/29/2020 09:07	S20-0588	Jacobo Integrated National High School	7.36 / 27.3	0.64	ABSENCE	ABSENCE	2
01/21/2020 10:50	S20-0440	Cistern Tank, Pavillion Mall	7.44 / 28.5	0.96	ABSENCE	ABSENCE	< 1
01/21/2020 11:14	S20-0441	Mesa Inasal, Pavillion Mall	7.40 / 28.1	0.64	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
01/21/2020 13:42	S20-0442	Jollibee National Hi-Way	7.37 / 28.2	0.02	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
01/21/2020 12:17	S20-0446	407 Water Pump, San Vicente Subdivision	7.44 / 30.3	0.32	ABSENCE	ABSENCE	< 1
01/28/2020 12:30	S20-0554	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.28 / 28.7	0.30	ABSENCE	ABSENCE	6
01/21/2020 09:17	S20-0436	Biñan Doctors Hospital	7.30 / 27.9	0.81	ABSENCE	ABSENCE	1
01/28/2020 13:40	S20-0555	Cistern Tank, Central Mall	7.09 / 23.9	0.50	ABSENCE	ABSENCE	< 1
01/28/2020 12:40	S20-0553	Drinking Fountain, San Vicente Elementary School	7.18 / 28.1	0.54	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
01/21/2020 12:41	S20-0434	Water Pump, Adelina Subdivision	7.42 / 29.1	0.08	ABSENCE	ABSENCE	1
01/21/2020 12:54	S20-0447	HOA Office, Adelina Subdivision	7.41 / 27.6	0.20	ABSENCE	ABSENCE	< 1
01/28/2020 12:00	S20-0560	Water Pump, Pragmatic	7.28 / 28.3	0.14	ABSENCE	ABSENCE	< 1
01/28/2020 12:15	S20-0561	Block 1 Lot 5, Bais St., Pragmatic	7.50 / 27.4	0.10	ABSENCE	ABSENCE	< 1
01/28/2020 11:25	S20-0550	Tawi Tawi St., Phase 6, South City Homes	7.37 / 27.5	0.40	ABSENCE	ABSENCE	< 1
01/28/2020 10:56	S20-0548	Pump, South Plains II Subdivision	7.50 / 28.2	0.64	ABSENCE	ABSENCE	< 1
01/28/2020 11:10	S20-0549	Block 11 Lot 2, South Plains II Subdivision	7.40 / 28.9	0.59	ABSENCE	ABSENCE	< 1
01/28/2020 09:59	S20-0556	Water Pump, Town & Country, Amsterdam	7.41 / 27.1	0.07	ABSENCE	ABSENCE	< 1
01/28/2020 10:10	S20-0557	Blk 35 Lt 21, Town & Country, Amsterdam	7.30 / 27.6	0.05	ABSENCE	ABSENCE	1
01/28/2020 10:18	S20-0558	Blk 2 Lt 5, Town & Country, Pennsylvania	7.35 / 27.4	0.04	ABSENCE	ABSENCE	< 1
01/28/2020 10:28	S20-0559	Blk 1 Lot 16, Phase 4, Olivarez Home South	7.14 / 27.0	0.79	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
01/29/2020 14:09	S20-0576	Water Pump, 9067 Manila S Road	7.16 / 29.1	1.24	ABSENCE	ABSENCE	< 1
01/29/2020 13:46	S20-0577	#76 Manila S Road	7.10 / 28.9	0.87	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
01/28/2020 13:10	S20-0551	#60 Florinda Compound	7.30 / 27.4	0.49	ABSENCE	ABSENCE	1
BRGY. ZAPOTE							
01/20/2020 11:50	S20-0383	Water Pump, Summer Breeze	7.42 / 24.2	0.77	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR STAMP



TR20-0274

February 3, 2020 8:50 PM

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis



ANALYZED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/20/2020 12:03	S20-0384	Clubhouse, Summer Breeze	7.31 / 27.6	0.60	ABSENCE	ABSENCE	3
01/20/2020 11:25	S20-0385	Elevated Water Tank, Evergreen	7.54 / 27.7	0.38	ABSENCE	ABSENCE	< 1
01/20/2020 11:34	S20-0386	Clubhouse, Evergreen	7.50 / 27.5	0.40	ABSENCE	ABSENCE	< 1
01/21/2020 11:38	S20-0445	Clubhouse, Althea	7.30 / 27.7	0.82	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP




O
R
I
G



TR20-0274

February 3, 2020 8:50 PM

ANALYZED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:


ANNA KARIA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis