

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 08/01/2022 – 08/08/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
08/01/2022 16:57	S22-3958	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1
BRGY. GULOD					
08/01/2022 13:48	S22-3942	Water Pump, Block 12, Noah St., Celestine Ville	ABSENCE	ABSENCE	10
08/01/2022 13:55	S22-3943	Guard House, Celestine Ville	ABSENCE	ABSENCE	68
BRGY. MARINIG					
08/01/2022 15:55	S22-3946	Water Pump, Block 3 Lot 17, Phase 1, Celestine Homes	ABSENCE	ABSENCE	< 1
08/01/2022 16:26	S22-3947	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	< 1
08/01/2022 16:10	S22-3948	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	ABSENCE	ABSENCE	< 1
08/01/2022 16:16	S22-3949	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	< 1
08/01/2022 15:31	S22-3950	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
08/01/2022 15:20	S22-3951	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
08/01/2022 17:15	S22-3959	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1
08/01/2022 15:03	S22-3953	Block 40 Lot 129, Phase 8, Southville	ABSENCE	ABSENCE	< 1
08/01/2022 14:50	S22-3952	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
08/01/2022 14:32	S22-3955	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	< 1
08/01/2022 14:19	S22-3954	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	< 1
BRGY. SALA					
08/01/2022 16:40	S22-3960	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 08/01/2022 – 08/01/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
08/01/2022 13:47	S22-3956	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	39
08/01/2022 13:24	S22-3957	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	<1
BRGY. BANLIC					
08/01/2022 07:40	S22-3925	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
08/01/2022 07:59	S22-3926	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
08/01/2022 10:38	S22-3938	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	180
08/01/2022 10:29	S22-3939	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	200
08/01/2022 11:46	S22-3932	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	2
08/01/2022 12:20	S22-3934	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/01/2022 13:12	S22-3940	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	2
08/01/2022 11:56	S22-3933	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	2
08/01/2022 12:33	S22-3935	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/01/2022 12:59	S22-3941	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	3
08/01/2022 11:31	S22-3965	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/01/2022 13:21	S22-3930	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
08/01/2022 13:34	S22-3931	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/01/2022 12:55	S22-3966	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/01/2022 11:49	S22-3967	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/01/2022 11:10	S22-3936	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
08/01/2022 3937	S22-3937	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
08/01/2022 11:05	S22-3968	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
08/01/2022 11:17	S22-3969	Block 58 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
08/01/2022 10:01	S22-3944	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	50
08/01/2022 10:10	S22-3945	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	46
BRGY. PULO					
08/01/2022 08:12	S22-3921	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
08/01/2022 08:18	S22-3922	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
08/01/2022 08:35	S22-3923	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
08/01/2022 08:55	S22-3924	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
08/01/2022 09:49	S22-3929	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
08/01/2022 09:20	S22-3927	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	3
08/01/2022 09:31	S22-3928	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis