

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES :15

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 05/10/2022 - 05/12/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	НРС^в (CFU/mL)	
BRGY. BIGAA						
05/10/2022 08:36	S22-2336	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1	
BRGY. GULOD						
05/10/2022 15:59	S22-2362	Water Pump, Block 12, Noah St., Celestine Ville	ABSENCE	ABSENCE	2	
05/10/2022 14:10	S22-2363	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1	
BRGY. MARINIG						
05/10/2022 09:30	S22-2324	Water Pump, Block 3 Lot 17, Phase 1, Celestine Homes	ABSENCE	ABSENCE	1	
05/10/2022 10:21	S22-2325	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	16	
05/10/2022 09:55	S22-2326	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 10:06	S22-2327	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 10:59	S22-2328	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1	

NOT VALID WITHOUT QR CODE



REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE C. PENALES, RMT Microbiology Unit Manager

S GUTIERREZ, RMT ANNA KARI Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis

License No(s). (PRC 0064969)



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	HPC [₿] (CFU/mL)	
BRGY. NIUGAN						
05/10/2022 15:30	S22-2337	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	<1	
05/10/2022 11:43	S22-2331	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	<1	
05/10/2022 11:56	S22-2330	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	<1	
05/10/2022 12:11	S22-2333	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	3	
05/10/2022 12:38	S22-2332	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	31	
05/10/2022 15:18	S22-2338	Water Pump, Niugan Elementary School	ABSENCE	ABSENCE	< 1	
BRGY. SALA			•			
05/10/2022 09:08	S22-2339	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE C. PENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969)

S. GUTIERREZ, RMT ANNA KARI Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 05/10/2022 - 05/12/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. BANAY-BANAY						
05/10/2022 13:00	\$22-2334	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	140	
05/10/2022 13:25	S22-2335	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	13	
BRGY. BANLIC						
05/10/2022 10:38	S22-2372	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1	
05/10/2022 10:45	S22-2373	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1	
BRGY. MAMATID						
05/10/2022 13:55	S22-2358	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1	
05/10/2022 13:59	S22-2359	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	46	
05/10/2022 14:20	S22-2352	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 14:46	S22-2354	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 15:39	S22-2360	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	19	
05/10/2022 14:38	S22-2353	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 14:59	S22-2355	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 15:47	S22-2361	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	<1	
05/10/2022 14:22	S22-2344	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	170	
05/10/2022 15:14	S22-2350	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1	
05/10/2022 15:20	S22-2351	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 14:53	S22-2345	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	22	

NOT VALID WITHOUT QR CODE

ALYSSA MARIE ÞENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969)

REVIEWED BY:

ANNA KAR GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

CERTIFIED CORRECT BY:

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis

Page 1 of 2



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORMA			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	НРС^в (CFU/mL)	
05/10/2022 14:40	S22-2346	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 14:09	S22-2356	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1	
05/10/2022 14:11	S22-2357	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1	
05/10/2022 13:51	S22-2347	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1	
05/10/2022 14:04	S22-2348	Block 58 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1	
05/10/2022 13:31	S22-2364	9001,Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1	
05/10/2022 13:45	S22-2365	Perez Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1	
BRGY. PULO						
05/10/2022 10:59	S22-2368	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	4	
05/10/2022 11:10	S22-2369	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1	
05/10/2022 11:25	S22-2370	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1	
05/10/2022 11:38	S22-2371	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1	
BRGY. SAN ISIDRO						
05/10/2022 13:02	S22-2376	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1	
05/10/2022 12:18	S22-2374	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1	
05/10/2022 12:29	S22-2375	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

C. PENALES, RMT ALYSSA MARIE Microbiológy Unit Manager License No(s). (PRC 0064969)

ANNA KARLA 6) GUTIERREZ, RMT Laboratory Servises Manager License No(s). (PRC 0060968)

CERTIFIED CORRECT BY:

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis

Page 2 of 2