

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 05/07/2024-05/23/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. BIGAA						
05/07/2024 15:40	S24-2479	#253 Elsol Subdivision	ABSENCE	ABSENCE	220	
BRGY. GULOD						
05/09/2024 14:18	S24-2573	Celestine Ville Subdivision	ABSENCE	ABSENCE	<1	
05/09/2024 14:29	S24-2574	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1	
BRGY. MARINIG						
05/07/2024 14:26	S24-2462	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	< 1	
05/07/2024 14:29	S24-2463	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	<1	
05/07/2024 15:24	S24-2465	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	<1	
05/07/2024 15:42	S24-2466	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	<1	
05/07/2024 14:05	S24-2468	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	<1	
05/07/2024 13:21	S24-2469	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLAS. GUTJERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. NIUGAN						
05/07/2024 09:34	S24-2480	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1	
05/23/2024 08:39	S24-2883	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	<1	
05/07/2024 12:54	S24-2471	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	8	
05/07/2024 12:06	S24-2475	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	<1	
05/07/2024 12:11	S24-2474	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	<1	
BRGY. SALA			•			
05/07/2024 16:26	S24-2481	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	5	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA(S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 31 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 05/07/2024-05/28/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BANAY-BANAY					
05/07/2024 11:10	S24-2477	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	<1
05/07/2024 10:16	S24-2478	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	2
BRGY. BANLIC					
05/24/2024 09:21	S24-2908	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
05/24/2024 09:30	S24-2909	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
05/09/2024 09:16	S24-2567	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
05/09/2024 09:21	S24-2568	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
05/09/2024 11:13	S24-2561	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	<1
05/09/2024 13:42	S24-2558	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	<1
05/09/2024 14:01	\$24-2559	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	<1
05/09/2024 11:19	S24-2562	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
05/09/2024 10:34	S24-2571	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	8
05/09/2024 10:25	S24-2570	Water Pump, Block 198, Galacia St., Phase II	ABSENCE	ABSENCE	< 1
05/24/2024 09:54	S24-2896	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	<1
05/09/2024 15:06	S24-2555	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	<1
05/09/2024 15:15	S24-2556	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
05/24/2024 10:07	S24-2897	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	<1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORMA		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
05/24/2024 10:16	S24-2898	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	<1
05/09/2024 09:47	S24-2564	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	<1
05/09/2024 09:47	S24-2565	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	<1
05/24/2024 09:27	S24-2899	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	<1
05/24/2024 09:36	S24-2900	Block 60 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	<1
05/09/2024 10:01	S24-2575	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	<1
05/09/2024 10:12	S24-2576	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	<1
BRGY. PULO					
05/24/2024 10:10	S24-2913	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	<1
05/24/2024 11:13	S24-2907	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	<1
05/28/2024 14:01	S24-2961	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	<1
05/24/2024 10:29	S24-2914	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	<1
BRGY. SAN ISIDRO					
05/24/2024 09:00	S24-2901	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	<1
05/24/2024 09:54	S24-2910	Water Pump, San Isidro Homes Subdivision	ABSENCE	ABSENCE	<1
05/24/2024 10:10	S24-2911	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	<1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA^IS GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)