

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

10/10/2

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 10/06/2022 – 10/07/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
10/07/2022 09:30	S22-5087	#253 Elsol Subdivision	ABSENCE	ABSENCE	8
BRGY. GULOD					
10/06/2022 11:20	S22-4989	Water Pump, Block 12, Noah St., Celestine Ville	ABSENCE	ABSENCE	2
10/06/2022 11:59	S22-4990	Guard House, Celestine Ville	ABSENCE	ABSENCE	3
BRGY. MARINIG					
10/07/2022 10:13	S22-5075	Water Pump, Block 3 Lot 17, Phase 1, Celestine Homes	ABSENCE	ABSENCE	1
10/07/2022 10:44	S22-5076	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	25
10/07/2022 10:28	S22-5077	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	ABSENCE	ABSENCE	6
10/07/2022 10:36	S22-5078	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	15
10/07/2022 11:09	S22-5079	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
10/07/2022 11:16	S22-5080	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	4

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
10/07/2022 08:57	S22-5088	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	2
10/07/2022 11:32	S22-5082	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	12
10/07/2022 11:42	S22-5081	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	11
10/07/2022 12:28	S22-5084	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	5
10/07/2022 12:09	S22-5083	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	6
BRGY. SALA					
10/07/2022 09:50	S22-5089	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	34

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 10/06/2022-10/10/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
10/07/2022 13:00	S22-5085	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	84
10/07/2022 13:12	S22-5086	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	97
BRGY. BANLIC					
10/06/2022 08:05	S22-4972	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	5
10/06/2022 08:14	S22-4973	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	10
BRGY. MAMATID					
10/06/2022 13:20	S22-4985	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	29
10/06/2022 13:39	S22-4986	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	26
10/06/2022 11:34	S22-4979	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
10/06/2022 12:21	S22-4981	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	57
10/06/2022 13:01	S22-4987	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	3
10/06/2022 11:50	S22-4980	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
10/06/2022 12:44	S22-4982	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	11
10/06/2022 13:10	S22-4988	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	10
10/07/2022 13:52	S22-5094	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	4
10/10/2022 08:32	S22-5035	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
10/10/2022 08:32	S22-5036	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
10/07/2022 13:44	S22-5095	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	150

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
10/07/2022 13:32	S22-5096	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	140
10/06/2022 13:21	S22-4983	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
10/06/2022 13:34	S22-4984	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	3
10/07/2022 14:02	S22-5097	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	2
10/07/2022 14:16	S22-5098	Block 58 Lot 8, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	9
10/06/2022 10:35	S22-4991	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	6
10/06/2022 10:43	S22-4992	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	3
BRGY. PULO					
10/06/2022 10:10	S22-4968	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	3
10/06/2022 10:17	S22-4969	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
10/06/2022 09:29	S22-4970	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
10/06/2022 09:45	S22-4971	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
10/06/2022 09:10	S22-4976	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
10/06/2022 08:21	S22-4974	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	2
10/06/2022 08:45	S22-4875	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	3

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis