

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 07/04/2022 – 07/07/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
07/04/2022 10:34	S22-3365	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	<1
07/04/2022 10:21	S22-3366	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	<1
BRGY. BANLIC					
07/04/2022 10:41	S22-3385	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
07/04/2022 10:52	S22-3386	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
07/04/2022 11:25	S22-3398	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	1
07/04/2022 11:32	S22-3399	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
07/04/2022 12:17	S22-3392	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 12:47	S22-3394	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 13:16	S22-3400	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 12:05	S22-3393	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 12:55	S22-3395	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 13:28	S22-3401	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 09:33	S22-3375	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	20
07/04/2022 13:37	S22-3390	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
07/04/2022 13:49	S22-3391	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 09:53	S22-3376	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	18


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager(OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
07/04/2022 09:45	S22-3377	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
07/04/2022 11:40	S22-3396	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
07/04/2022 11:55	S22-3397	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
07/04/2022 09:12	S22-3378	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
07/04/2022 09:20	S22-3379	Block 58 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
07/04/2022 10:48	S22-3404	9001,Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
07/04/2022 10:59	S22-3405	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
BRGY. PULO					
07/04/2022 09:19	S22-3381	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
07/04/2022 09:31	S22-3382	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
07/04/2022 08:50	S22-3383	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
07/04/2022 09:01	S22-3384	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
07/04/2022 10:21	S22-3389	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
07/04/2022 09:50	S22-3387	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1
07/04/2022 10:10	S22-3388	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager(OIC)
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis