

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 11/02/2021 – 11/14/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BANAY-BANAY							
11/03/2021 15:10	S21-7484	Water Pump, Block 63, Lakeside Nest Subdivision	-	0.22	ABSENCE	ABSENCE	81
11/03/2021 14:59	S21-7485	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	-	0.15	ABSENCE	ABSENCE	36
BRGY. BANLIC							
11/12/2021 10:40	S21-7660	Water Pump, Gran Seville Subdivision	7.52 / 29.1	0.46	ABSENCE	ABSENCE	< 1
11/12/2021 10:26	S21-7661	Gate Entrance, Gran Seville Subdivision	7.45 / 27.6	0.38	ABSENCE	ABSENCE	< 1
BRGY. BIGAA							
11/03/2021 12:25	S21-7486	#253 Elsol Subdivision	-	0.82	ABSENCE	ABSENCE	2
BRGY. GULOD							
11/02/2021 15:22	S21-7439	Water Pump, Block 12, Noah St., Celestine Ville	7.44 / 28.2	0.30	ABSENCE	ABSENCE	3
11/02/2021 15:37	S21-7440	Guardhouse, Celestine Ville	7.40 / 28.6	0.21	ABSENCE	ABSENCE	< 1
BRGY. MARINIG							
11/03/2021 13:24	S21-7474	Block 3 Lot 17, Phase 1, Celestine Homes	-	0.04	ABSENCE	ABSENCE	2
11/03/2021 13:13	S21-7475	Block 23, Lot 10, Phase 1, Celestine Homes	-	0.15	ABSENCE	ABSENCE	6
11/03/2021 12:57	S21-7476	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	-	0.81	ABSENCE	ABSENCE	< 1
11/03/2021 13:03	S21-7477	Block 13 Lot 2, Phase 2, Celestine Homes	-	0.64	ABSENCE	ABSENCE	< 1
11/03/2021 13:43	S21-7478	Water Pump, Block 25, Phase 3, Southville	-	0.25	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
11/03/2021 13:51	S21-7479	Block 19 Lot 33, Phase 3, Southville	-	0.41	ABSENCE	ABSENCE	< 1
BRGY. NIUGAN							
11/03/2021 15:47	S21-7487	Block 2 Lot 6, St. Francis Homes VI	-	0.05	ABSENCE	ABSENCE	2
11/03/2021 14:04	S21-7481	Block 40 Lot 132, Phase 8, Southville	-	1.29	ABSENCE	ABSENCE	< 1
11/03/2021 14:12	S21-7480	Water Pump, Block 42, Phase 8, Southville	-	0.49	ABSENCE	ABSENCE	< 1
11/03/2021 14:26	S21-7483	Block 47 Lot 101, Phase 10, Southville	-	0.93	ABSENCE	ABSENCE	< 1
11/15/2021 14:24	S21-7722	Water Pump, Block 54, Phase 10, Southville	7.75 / 29.3	0.13	ABSENCE	ABSENCE	23
11/03/2021 15:35	S21-7488	Water Pump, Niugan Elementary School	-	0.06	ABSENCE	ABSENCE	< 1
BRGY. SALA							
11/03/2021 12:43	S21-7489	Gate Entrance, Amaia Scapes	-	0.78	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO							
11/12/2021 11:19	S21-7664	Block 3 Lot 33, Multiland IV	7.55 / 27.6	0.11	ABSENCE	ABSENCE	< 1
11/12/2021 10:52	S21-7662	Water Pump, San Isidro Heights Subdivision	7.51 / 28.1	0.30	ABSENCE	ABSENCE	< 1
11/12/2021 10:59	S21-7663	Block 3 Lot 1, San Isidro Heights Subdivision	7.56 / 29.1	0.24	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis