



April 30, 2026

DR. RONNIE C. LAZANAS
Medical Officer IV
Environmental Sanitation and Information Section
New City Hall, Bacnotan, Real
City of Calamba, Laguna

THRU: JOSE B. BELDA
Sanitation Inspector

Subject: Microbiological Examination Report – April 2026


Dear Mr. Belda:

Greetings from Laguna Water!


We are **Laguna AAWater Corporation**, the authorized water concessionaire of the Province of Laguna. Laguna Water is a joint venture company between the Provincial Government of Laguna and Manila Water Philippine Ventures Company (owned by Manila Water Company Inc., the water service provider in the East Zone of Metro Manila).

As part of our mandate on improving the water quality, we are pleased to submit to you a summary of the Microbiological Tests that we are conducting all throughout our covered Service Areas.

Respectfully,


Marvin Jasper G. Abenojar
Microbiology Unit Manager
Laguna AAWater Corp.

Noted By:


Jandrick N. Patricio
Technical Operation Head
Laguna AAWater Corp.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2237

DATE/TIME SUBMITTED : 04/15/2026 13:40

DATE/TIME COLLECTION : 04/15/2026 12:16

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PHASE 1, APO ST., AYALA GREENFIELD ESTATES, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/15/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/15/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/15/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/15/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCH
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2236

DATE/TIME SUBMITTED : 04/15/2026 13:40

DATE/TIME COLLECTION : 04/15/2026 12:01

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 11, KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/15/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/15/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/15/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/15/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2154

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 08:44

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2159

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 10:04

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.80	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWAC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2160

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 10:24

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWAC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2161

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 10:29

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.70	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWAC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2162

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 10:55

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2157

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 09:41

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.48	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWAC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2158

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 09:48

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : EDUCATION BUILDING, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.48	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2163

DATE/TIME SUBMITTED : 04/13/2026 13:05

DATE/TIME COLLECTION : 04/13/2026 09:31

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : TPH, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/13/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/13/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/13/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)