

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S23-2357

**DATE/TIME SUBMITTED :** 05/04/2023 16:10

**DATE/TIME COLLECTION :** 05/04/2023 13:33

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** APO STREET, AYALA GREENFIELD ESTATES, SAMAT ST., BRGY. PUTTING LUPA, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.39	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/04/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	05/04/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	05/04/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/04/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCH  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2356

**DATE/TIME SUBMITTED** : 05/04/2023 16:10

**DATE/TIME COLLECTION** : 05/04/2023 13:01

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BLOCK 11, KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTTING LUPA, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.41	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/04/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/04/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCH  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2355

**DATE/TIME SUBMITTED** : 05/04/2023 16:10

**DATE/TIME COLLECTION** : 05/04/2023 13:14

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTTING LUPA, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.30</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/04/2023	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	<500 (cfu/mL)	9215B. Pour Plate Method	05/04/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2323

**DATE/TIME SUBMITTED** : 05/03/2023 14:20

**DATE/TIME COLLECTION** : 05/03/2023 11:05

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.19	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/03/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	1	<500 (cfu/mL)	9215B. Pour Plate Method	05/03/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2324

**DATE/TIME SUBMITTED** : 05/03/2023 14:20

**DATE/TIME COLLECTION** : 05/03/2023 11:12

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.40</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/03/2023	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	<500 (cfu/mL)	9215B. Pour Plate Method	05/03/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2325

**DATE/TIME SUBMITTED** : 05/03/2023 14:20

**DATE/TIME COLLECTION** : 05/03/2023 11:21

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.70</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/03/2023	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	<500 (cfu/mL)	9215B. Pour Plate Method	05/03/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2326

**DATE/TIME SUBMITTED** : 05/03/2023 14:20

**DATE/TIME COLLECTION** : 05/03/2023 11:32

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BLOCK 39, LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.36</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/03/2023	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	<i>ABSENCE</i>	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	<500 (cfu/mL)	9215B. Pour Plate Method	05/03/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** **A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2354

**DATE/TIME SUBMITTED** : 05/04/2023 16:10

**DATE/TIME COLLECTION** : 05/04/2023 13:14

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.51	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/04/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/04/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/04/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCH  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-2328

**DATE/TIME SUBMITTED** : 05/03/2023 14:20

**DATE/TIME COLLECTION** : 05/03/2023 10:20

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : EDUCATION BUILDING, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.35	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/03/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/03/2023	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/03/2023	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 090336)

  
KRISTEEN Y. ALDAY, RCH  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)