

Accreditations, Recognitions and Licenses:

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

DATE/TIME COLLECTION : 10/06/2022 11:39 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SOURCE, WATER PUMP, CALAUAN LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
*Residual Chlorine	mg/L	2.23	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0090336)

KRISTEEM Y/A/LDAY,RCh Analytical Service Unit Manager License No(s). (PRC 0013295) NNA KARLA SI GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



Accreditations, Recognitions and Licenses:

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

DATE/TIME COLLECTION : 10/06/2022 12:05 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : MARGARETTE BUILDING, CALAUAN LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
*Residual Chlorine	mg/L	0.39	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ÉLLISON G. RAMOS, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0090336)

KRISTEEN Y. J. DAY,RCh Analytical Service Unit Manager License No(s). (PRC 0013295)

NNA KARLA S. GUMERREZ, RMT Laboratory Servises Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis