

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I (CHO-1)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 24

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 04/15/2020-04/29/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BANAY-BANAY							
04/15/2020 11:25	S20-2443	Water Pump, Block 63, Lakeside Nest Subdivision	6.18 / 30.2	0.12	ABSENCE	ABSENCE	-
04/15/2020 11:34	S20-2444	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	6.34 / 30.9	0.08	ABSENCE	ABSENCE	-
BRGY. BANLIC							
04/27/2020 11:08	S20-2675	Water Pump, Gran Seville Subdivision	7.60 / 27.9	0.30	ABSENCE	ABSENCE	< 1
04/27/2020 11:16	S20-2676	Gate Entrance, Gran Seville Subdivision	7.48 / 28.8	0.27	ABSENCE	ABSENCE	1
BRGY. BIGAA							
04/15/2020 13:42	S20-2445	#253 Elsol Subdivision	8.13 / 31.0	0.51	ABSENCE	ABSENCE	-
BRGY. GULOD							
04/27/2020 14:30	S20-2709	Block 12, Noah St., Celestine Ville	7.75 / 30.2	0.26	ABSENCE	ABSENCE	< 1
04/27/2020 14:40	S20-2710	Guardhouse, Celestine Ville	7.52 / 29.2	0.16	ABSENCE	ABSENCE	5
BRGY. MARINIG							
04/15/2020 12:40	S20-2433	Block 3 Lot 17, Phase 1, Celestine Homes	7.75 / 30.5	0.97	ABSENCE	ABSENCE	< 1
04/15/2020 13:26	S20-2434	Block 23, Lot 10, Phase 1, Celestine Homes	7.48 / 31.4	1.01	ABSENCE	ABSENCE	< 1
04/15/2020 13:06	S20-2435	Block 9, Carnation St., Phase 2, Celestine Homes	8.01 / 30.4	0.83	ABSENCE	ABSENCE	< 1
04/15/2020 13:14	S20-2436	Block 13 Lot 2, Phase 2, Celestine Homes	7.98 / 31.2	0.78	ABSENCE	ABSENCE	-
04/15/2020 12:34	S20-2437	Water Pump, Block 25, Phase 3, Southville	7.69 / 31.8	0.59	ABSENCE	ABSENCE	-
04/15/2020 12:23	S20-2438	Block 19 Lot 33, Phase 3, Southville	7.63 / 30.2	0.76	ABSENCE	ABSENCE	-
BRGY. NIUGAN							
04/15/2020 14:04	S20-2446	Block 2 Lot 6, St. Francis Homes 6	7.86 / 31.6	0.32	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
04/27/2020 16:00	S20-2711	Water Pump, Phase 9, Southville	7.29 / 28.5	0.31	ABSENCE	ABSENCE	< 1
04/27/2020 16:15	S20-2712	De Guzman Residence, Phase 9, Southville	7.25 / 27.6	0.25	ABSENCE	ABSENCE	< 1
04/15/2020 11:51	S20-2442	Block 47 Lot 101, Phase 10, Southville	7.45 / 31.1	0.34	ABSENCE	ABSENCE	-
04/15/2020 12:05	S20-2439	Water Pump, Block 45, Phase 8	7.69 / 29.7	0.43	ABSENCE	ABSENCE	-
04/15/2020 12:16	S20-2440	Block 40 Lot 129, Phase 8	7.48 / 29.9	0.38	ABSENCE	ABSENCE	-
04/15/2020 11:24	S20-2441	Water Pump, Block 54, Phase 10, Southville	7.08 / 29.7	0.47	ABSENCE	ABSENCE	-
BRGY. SALA							
04/27/2020 15:30	S20-2713	Gate Entrance, Amaia Scapes	7.55 / 33.4	0.67	ABSENCE	ABSENCE	6
BRGY. SAN ISIDRO							
04/27/2020 12:29	S20-2679	Block 3 Lot 33, Multiland IV	7.95 / 30.3	1.00	ABSENCE	ABSENCE	< 1
04/27/2020 12:42	S20-2677	Water Pump, San Isidro Heights Subdivision	7.89 / 28.9	1.02	ABSENCE	ABSENCE	11
04/27/2020 12:52	S20-2678	Block 3 Lot 1, San Isidro Heights Subdivision	7.93 / 31.1	0.81	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric ; **C**- Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0050968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II (CHO-2)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 17

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 04/27/2020-04/29/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. MAMATID							
04/27/2020 14:15	S20-2706	Water Pump, Buena Rosario Subdivision	7.99 / 28.9	0.37	ABSENCE	ABSENCE	< 1
04/27/2020 13:25	S20-2702	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	7.74 / 28.4	0.54	ABSENCE	ABSENCE	< 1
04/27/2020 12:50	S20-2703	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	7.69 / 29.1	0.47	ABSENCE	ABSENCE	3
04/27/2020 13:00	S20-2704	Block 134 Lot 22, Phase 2, Mabuhay City Homes	7.67 / 27.7	0.30	ABSENCE	ABSENCE	< 1
04/27/2020 12:30	S20-2707	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	7.64 / 29.3	0.14	ABSENCE	ABSENCE	10
04/27/2020 12:40	S20-2708	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	7.66 / 28.9	0.30	ABSENCE	ABSENCE	1
04/27/2020 12:00	S20-2680	Water Pump, Joshua St., Phase 5, Mabuhay City Homes	8.08 / 30.7	0.28	ABSENCE	ABSENCE	1
04/27/2020 12:09	S20-2681	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	7.92 / 31.5	0.28	ABSENCE	ABSENCE	2
04/27/2020 11:57	S20-2700	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	6.70 / 28.3	0.56	ABSENCE	ABSENCE	< 1
04/27/2020 12:15	S20-2701	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay City Homes	7.74 / 28.4	0.54	ABSENCE	ABSENCE	< 1
04/27/2020 11:46	S20-2682	Water Pump, Panganig St., Phase 3, Mabuhay City Homes	7.88 / 29.2	0.45	ABSENCE	ABSENCE	< 1
04/27/2020 11:35	S20-2683	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	7.52 / 29.5	0.36	ABSENCE	ABSENCE	< 1
04/27/2020 13:50	S20-2705	Water Pump, Phase 1E Mabuhay Executive	7.59 / 33.3	0.49	ABSENCE	ABSENCE	< 1
BRGY. PULO							

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIÉRREZ, RMT
Laboratory Services Manager
License No(s) (PRC 0050968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/27/2020 10:43	S20-2671	Water Pump, Block 12 Lot 22, Cabuyao Central	6.81 / 27.6 MDL: NA LOQ: NA	0.25 MDL: 0.06 LOQ: 0.20	ABSENCE	ABSENCE	< 1
04/27/2020 10:53	S20-2672	Clubhouse, Narra Avenue, Cabuyao Central	7.53 / 28.5	1.45	ABSENCE	ABSENCE	< 1
04/27/2020 13:06	S20-2673	Water Pump, Block 11, Willow Park Homes	7.81 / 29.1	0.02	ABSENCE	ABSENCE	1
04/27/2020 13:13	S20-2674	Clubhouse, Willow Park Homes	7.76 / 33.6	0.02	ABSENCE	ABSENCE	130

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0050968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis