

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6412

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 11:50

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	19	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6413

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 11:59

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : RESERVIOR, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.60	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6415

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 10:59

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CHRISTIAN HOSPITAL, BRGY. POBLACION II, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6416

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 10:34

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : DIMAYUGA RESIDENCE, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6445

DATE/TIME SUBMITTED : 11/12/2024 14:29

DATE/TIME COLLECTION : 11/12/2024 09:32

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PUMP STATION 5, BRGY. POBLACION 2, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.74	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/12/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/12/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6417

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 10:18

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BIG BOY EATERY, RIZAL STREET, BRGY. POBLACION II, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.40	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation
ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6446 **DATE/TIME SUBMITTED** : 11/12/2024 14:29
DATE/TIME COLLECTION : 11/12/2024 08:30 **COLLECTED BY** : Edwin O. Aguilar
NO. OF SAMPLES : 1 **TOTAL PARAMETERS TESTED** : 4

SAMPLE LOCATION : DE DIOS RESIDENCE, BRGY. POBLACION I, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/12/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/12/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation
ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6418 **DATE/TIME SUBMITTED :** 11/11/2024 15:30
DATE/TIME COLLECTION : 11/11/2024 11:00 **COLLECTED BY :** Edwin O. Aguilar
NO. OF SAMPLES : 1 **TOTAL PARAMETERS TESTED :** 4
SAMPLE LOCATION : PAGWAD OFFICE, BRGY. POBLACION II, PAGSANJAN, LAGUNA
SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.34	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6419

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 10:50

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SAMPALOC ELEMENTARY SCHOOL, BRGY.SAMPALOC, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6447

DATE/TIME SUBMITTED : 11/12/2024 14:29

DATE/TIME COLLECTION : 11/12/2024 08:12

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PUMP STATION 2, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.34	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/12/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/12/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6448

DATE/TIME SUBMITTED : 11/12/2024 14:29

DATE/TIME COLLECTION : 11/12/2024 08:21

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : MANALO RESIDENCES, BRGY. PINAGSANJAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.45	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/12/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	<500 (cfu/mL)	9215B. Pour Plate Method	11/12/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLAS S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6420

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 12:25

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : MAGNAYE RESIDENCE, BRGY. CABANBANAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6598

DATE/TIME SUBMITTED : 11/15/2024 13:20

DATE/TIME COLLECTION : 11/15/2024 09:08

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : FERRER RESIDENCE, BRGY. SAN ISIDRO, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/15/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/15/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/15/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/15/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6450

DATE/TIME SUBMITTED : 11/12/2024 14:29

DATE/TIME COLLECTION : 11/12/2024 09:20

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PUMP STATION 4, BRGY. POBLACION I, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.50	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/12/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/12/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/12/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6421

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 11:20

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : AREZA PUBLIC MARKET, BRGY. BINAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.44	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6422

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 12:42

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : MARQUESES RESIDENCE, VILLA CORAZON ST. BRGY. BINAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.42	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6423

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 13:16

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SITIO 3, PANTAY ROAD JESSI OCTOBIO II, BRGY. BINAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	130	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6424

DATE/TIME SUBMITTED : 11/11/2024 15:30

DATE/TIME COLLECTION : 11/11/2024 13:00

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PHOENIX GAS STATION, BRGY. BINAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.33	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/11/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/11/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	31	<500 (cfu/mL)	9215B. Pour Plate Method	11/11/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S24-6597

DATE/TIME SUBMITTED : 11/15/2024 13:20

DATE/TIME COLLECTION : 11/15/2024 08:46

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : PUMP STATION 7, PINAGSANJAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.61	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	11/15/2024	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/15/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/15/2024	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	11/15/2024	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis