

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-0264

DATE/TIME SUBMITTED : 01/19/2023 16:30

DATE/TIME COLLECTION : 01/19/2023 07:40

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, BRGY. KABULUSAN, PAKIL, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|--|---------------------------------|-----------|--|------------|-----|
| | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.42 | 4500-Cl-G.DPD Colorimetric | 01/19/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 01/19/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 01/19/2023 | NGR |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 01/19/2023 | NGR |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-0265

DATE/TIME SUBMITTED : 01/19/2023 16:30

DATE/TIME COLLECTION : 01/19/2023 07:50

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : REY AND LYN, BRGY. KABULUSAN, PAKIL, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|--|---------------------------------|-----------|--|------------|-----|
| | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.40 | 4500-Cl-G.DPD Colorimetric | 01/28/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 01/19/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 01/19/2023 | NGR |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 01/19/2023 | NGR |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)