

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-7789

DATE/TIME SUBMITTED : 12/02/2025 15:06

DATE/TIME COLLECTION : 12/02/2025 11:39

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SOURCE, BELLA VITA, BRGY. PANSOL, PILA LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.49	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	12/02/2025	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	12/02/2025	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	12/02/2025	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	450	< 500 (cfu/mL)	9215B. Pour Plate Method	12/02/2025	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


* - Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE

REVIEWED BY:


 MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:


 KRISTEEN Y. ALDAY, RCh
 Analytical Service Unit Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-7926

DATE/TIME SUBMITTED : 12/04/2025 14:40

DATE/TIME COLLECTION : 12/04/2025 11:34

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 1 LOT 3, BELLA VITA, BRGY. PANSOL, PILA LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.34	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	12/04/2025	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	12/04/2025	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	12/04/2025	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	12/04/2025	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


* - Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE

REVIEWED BY:


MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
 Analytical Service Unit Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis