

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S26-2335

**DATE/TIME SUBMITTED** : 04/20/2026 14:08

**DATE/TIME COLLECTION** : 04/20/2026 12:06

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.30</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/20/2026	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>25</b>	< 500 (cfu/mL)	9215B. Pour Plate Method	04/20/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Laboratory Service Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-2336

**DATE/TIME SUBMITTED :** 04/20/2026 14:08

**DATE/TIME COLLECTION :** 04/20/2026 12:14

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** CLUBHOUSE, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.40</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/20/2026	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	< 500 (cfu/mL)	9215B. Pour Plate Method	04/20/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Laboratory Service Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-2337

**DATE/TIME SUBMITTED :** 04/20/2026 14:08

**DATE/TIME COLLECTION :** 04/20/2026 09:57

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.39	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/20/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	04/20/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Laboratory Service Manager  
License No(s). (PRC 0013295)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S26-2338

**DATE/TIME SUBMITTED :** 04/20/2026 14:08

**DATE/TIME COLLECTION :** 04/20/2026 11:50

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** BLOCK 65 LOT 2, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	<b>0.71</b>	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	04/20/2026	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/20/2026	MGA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	< 500 (cfu/mL)	9215B. Pour Plate Method	04/20/2026	MGA

**REMARKS:** Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 24<sup>th</sup> Edition

**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
MARVIN JASPER G. ABENOJAR  
Microbiology Unit Manager

APPROVED BY:

  
KRISTEEN Y. ALDAY, RCh  
Laboratory Service Manager  
License No(s). (PRC 0013295)