

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-0662

**DATE/TIME SUBMITTED** : 02/08/2023 16:20

**DATE/TIME COLLECTION** : 02/08/2023 11:31

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : SOURCE, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S)                                      | UNIT(S)                      | RESULT(S)      | PNSDW LIMIT(S) | METHOD(S)                                   | ANALYSIS   |     |
|---|------------------------------|----------------|----------------|---|------------|-----|
|   |                              |                |                |   | DATE       | BY  |
| *Residual Chlorine                                | mg/L                         | <b>0.78</b>    | 0.30 – 1.50    | 4500-Cl-G.DPD Colorimetric                  | 02/08/2023 | EOA |
| Total Coliform                                    | Coliforms/100 mL             | <b>ABSENCE</b> | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL             | <b>ABSENCE</b> | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Heterotrophic Plate Count (HPC) <sup>A</sup>      | Colony Forming Unit (CFU)/mL | <b>&lt; 1</b>  | <500 (cfu/mL)  | 9215B. Pour Plate Method                    | 02/08/2023 | NGR |

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-0663

**DATE/TIME SUBMITTED** : 02/08/2023 16:20

**DATE/TIME COLLECTION** : 02/08/2023 11:31

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : CLUB HOUSE, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S)                                      | UNIT(S)                      | RESULT(S) | PNSDW LIMIT(S) | METHOD(S)                                   | ANALYSIS   |     |
|---|------------------------------|-----------|----------------|---|------------|-----|
|   |                              |           |                |   | DATE       | BY  |
| *Residual Chlorine                                | mg/L                         | 0.40      | 0.30 – 1.50    | 4500-Cl-G.DPD Colorimetric                  | 02/08/2023 | EOA |
| Total Coliform                                    | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Heterotrophic Plate Count (HPC) <sup>A</sup>      | Colony Forming Unit (CFU)/mL | < 1       | <500 (cfu/mL)  | 9215B. Pour Plate Method                    | 02/08/2023 | NGR |

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-0665

**DATE/TIME SUBMITTED** : 02/08/2023 16:20

**DATE/TIME COLLECTION** : 02/08/2023 14:09

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S)                                      | UNIT(S)                      | RESULT(S) | PNSDW LIMIT(S) | METHOD(S)                                   | ANALYSIS   |     |
|---|------------------------------|-----------|----------------|---|------------|-----|
|   |                              |           |                |   | DATE       | BY  |
| *Residual Chlorine                                | mg/L                         | 0.68      | 0.30 – 1.50    | 4500-Cl-G.DPD Colorimetric                  | 02/08/2023 | EOA |
| Total Coliform                                    | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Heterotrophic Plate Count (HPC) <sup>A</sup>      | Colony Forming Unit (CFU)/mL | < 1       | <500 (cfu/mL)  | 9215B. Pour Plate Method                    | 02/08/2023 | NGR |

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S23-0666

**DATE/TIME SUBMITTED** : 02/08/2023 16:20

**DATE/TIME COLLECTION** : 02/08/2023 14:20

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BLOCK 65 LOT 23, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S)                                      | UNIT(S)                      | RESULT(S) | PNSDW LIMIT(S) | METHOD(S)                                   | ANALYSIS   |     |
|---|------------------------------|-----------|----------------|---|------------|-----|
|   |                              |           |                |   | DATE       | BY  |
| *Residual Chlorine                                | mg/L                         | 0.38      | 0.30 – 1.50    | 4500-Cl-G.DPD Colorimetric                  | 02/08/2023 | EOA |
| Total Coliform                                    | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL             | ABSENCE   | ABSENCE        | 9223B. Enzyme Substrate Test (Colilert-18®) | 02/08/2023 | NGR |
| Heterotrophic Plate Count (HPC) <sup>A</sup>      | Colony Forming Unit (CFU)/mL | < 1       | <500 (cfu/mL)  | 9215B. Pour Plate Method                    | 02/08/2023 | NGR |

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis