

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4039

DATE/TIME SUBMITTED : 07/06/2026 14:10

DATE/TIME COLLECTION : 07/06/2026 07:27

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/06/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/06/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4040

DATE/TIME SUBMITTED : 07/06/2026 14:10

DATE/TIME COLLECTION : 07/06/2026 07:40

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HAND HYGIENE, PROVINCIAL HEALTH OFFICE, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/06/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/06/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4041

DATE/TIME SUBMITTED : 07/06/2026 14:10

DATE/TIME COLLECTION : 07/06/2026 12:07

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OVAL, STA. CRUZ SPORTS COMPLEX, BRGY. BUBUKAL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.38	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/06/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/06/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4044

DATE/TIME SUBMITTED : 07/06/2026 14:10

DATE/TIME COLLECTION : 07/06/2026 11:34

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : SOURCE, RECS VILLAGE, LAGUNA SPORTS COMPLEX, BRGY. BUBUKAL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.72	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/06/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/06/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/06/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4101

DATE/TIME SUBMITTED : 07/07/2026 13:48

DATE/TIME COLLECTION : 07/07/2026 12:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.55	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/07/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/07/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/07/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/07/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4102

DATE/TIME SUBMITTED : 07/07/2026 13:48

DATE/TIME COLLECTION : 07/07/2026 11:40

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/07/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/07/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/07/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/07/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F One Evotech Building, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna 4026

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-4103

DATE/TIME SUBMITTED : 07/07/2026 13:48

DATE/TIME COLLECTION : 07/07/2026 11:51

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	07/07/2026	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/07/2026	ABG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert- 18®)	07/07/2026	ABG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	< 500 (cfu/mL)	9215B. Pour Plate Method	07/07/2026	ABG

REMARKS: Sample collection was performed by LAWC accredited sampler and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

* - Performed Onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday, RCh.
KRISTEEN Y. ALDAY, RCh.
Laboratory Services Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis