

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5037

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 08:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	2.09	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEENY ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5038

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 08:38

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVERRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.45	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5039

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 08:24

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.70	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5040

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 09:01

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : KITCHEN, PROVINCIAL HEALTH OFFICE, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.38	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5041

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 11:12

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OVAL, BUBUKAL COMPLEX, SANTA CRUZ, CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.49	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-5042

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 09:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HAND HYGIENE, PROVINCIAL HEALTH OFFICE, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.29	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S22-4542

DATE/TIME SUBMITTED : 10/06/2022 14:00

DATE/TIME COLLECTION : 10/06/2022 11:06

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : DEEPWELL, SPORTS COMPLEX, SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.29	4500-Cl-G.DPD Colorimetric	10/06/2022	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/06/2022	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	10/06/2022	NGR

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis