

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 08/12/2024-08/27/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
08/27/2024 13:11	S24-4800	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
08/15/2024 13:42	S24-4637	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
08/15/2024 14:35	S24-4638	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
08/15/2024 14:16	S24-4641	Block 2 Lot 16, Phase 8 Southville	ABSENCE	ABSENCE	3
08/15/2024 13:37	S24-4639	Southville Integrated Highschool	ABSENCE	ABSENCE	19
BRGY. KANLURAN					
08/15/2024 11:32	S24-4632	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
08/15/2024 10:39	S24-4631	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
08/15/2024 11:12	S24-4640	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
08/15/2024 10:11	S24-4629	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
08/14/2024 11:39	S24-4588	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
08/14/2024 11:59	S24-4590	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
08/14/2024 12:22	S24-4599	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
08/14/2024 12:33	S24-4600	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
08/14/2024 10:50	S24-4589	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	2
08/14/2024 11:23	S24-4591	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	61
08/14/2024 13:36	S24-4592	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
08/14/2024 13:44	S24-4593	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
08/19/2024 10:40	S24-4702	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	78
08/14/2024 13:07	S24-4595	Pepa Wings, Robinson's Mall	ABSENCE	ABSENCE	7
08/12/2024 15:23	S24-4522	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	2
08/12/2024 10:14	S24-4523	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	7

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 39

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 08/12/2024-08/27/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
08/27/2024 13:11	S24-4800	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
08/15/2024 15:01	S24-4630	#4354 Facundo Compound	ABSENCE	ABSENCE	2
08/13/2024 11:38	S24-4558	Water Pump, South Hampton Residence	ABSENCE	ABSENCE	< 1
08/13/2024 11:21	S24-4557	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
08/22/2024 10:45	S24-4786	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
08/22/2024 10:31	S24-4787	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	20
08/12/2024 16:01	S24-4520	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	11
BRGY. DILA					
08/12/2024 13:41	S24-4508	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	24
08/12/2024 13:57	S24-4509	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	40
08/12/2024 11:37	S24-4511	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
08/12/2024 13:06	S24-4512	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
08/13/2024 11:08	S24-4559	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
08/12/2024 14:17	S24-4513	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
08/12/2024 11:12	S24-4514	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
08/12/2024 10:45	S24-4516	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
08/12/2024 10:51	S24-4517	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/12/2024 10:33	S24-4518	#1780, National Road	ABSENCE	ABSENCE	< 1
08/12/2024 10:14	S24-4524	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
08/13/2024 10:53	S24-4560	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
08/13/2024 14:49	S24-4571	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/13/2024 14:31	S24-4570	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/13/2024 14:06	S24-4574	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/13/2024 16:02	S24-4565	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
08/13/2024 15:49	S24-4566	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
08/13/2024 15:20	S24-4567	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
08/13/2024 15:28	S24-4568	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
08/13/2024 15:04	S24-4575	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
08/14/2024 10:30	S24-4601	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
08/14/2024 09:54	S24-4597	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
08/14/2024 10:12	S24-4598	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
08/12/2024 10:00	S24-4519	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
08/13/2024 10:34	S24-4564	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
08/13/2024 10:00	S24-4562	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1
08/13/2024 10:14	S24-4563	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC					
08/15/2024 12:09	S24-4634	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
08/15/2024 12:19	S24-4635	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
08/13/2024 12:26	S24-4555	Manzano Residence	ABSENCE	ABSENCE	< 1
08/13/2024 11:59	S24-4554	Water Pump	ABSENCE	ABSENCE	< 1
08/22/2024 11:03	S24-4789	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
08/22/2024 10:48	S24-4788	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO					
08/13/2024 15:36	S24-4569	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
08/22/2024 11:30	S24-4790	Water Pump	ABSENCE	ABSENCE	< 1
08/22/2024 11:48	S24-4791	Lagonay Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.