

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 04/08/2026-04/22/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/08/2026 12:57	S26-2074	Laguna Wellfield I	ABSENCE	ABSENCE	1
BRGY. CAINGIN					
04/22/2026 12:22	S26-2464	Water Pump, Block 57, Phase I, Southville	ABSENCE	ABSENCE	< 1
04/22/2026 14:17	S26-2465	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
04/22/2026 14:00	S26-2466	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
04/22/2026 11:18	S26-2461	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
04/22/2026 08:54	S26-2460	Canteen, Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
04/22/2026 10:41	S26-2467	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
04/22/2026 10:11	S26-2458	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	4

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Mabenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
04/20/2026 12:37	S26-2361	#6031 JP Rizal Boulevard	ABSENCE	ABSENCE	1
04/20/2026 11:30	S26-2363	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	<1
04/20/2026 12:12	S26-2370	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	<1
04/20/2026 12:18	S26-2371	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	8
04/20/2026 13:24	S26-2362	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
04/20/2026 12:53	S26-2364	Block 14 Lot 17, Buena Rosa X	ABSENCE	ABSENCE	210
04/20/2026 12:34	S26-2365	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	2
04/20/2026 11:20	S26-2366	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	1
04/20/2026 10:52	S26-2367	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	<1
04/22/2026 15:22	S26-2471	Sonyda, Robinson's Mall	ABSENCE	ABSENCE	1
04/22/2026 12:24	S26-2436	Water Pump, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1
04/22/2026 12:39	S26-2437	Clubhouse, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**- Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 39

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 04/08/2026-04/30/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/08/2026 12:57	S26-2074	Laguna Wellfield I	ABSENCE	ABSENCE	1
BRGY. BALIBAGO					
04/22/2026 14:53	S26-2459	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
04/14/2026 10:17	S26-2203	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	1
04/22/2026 13:10	S26-2435	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
04/22/2026 10:04	S26-2469	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
04/23/2026 14:53	S26-2517	2nd Floor Faucet, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
BRGY. DILA					
04/30/2026 11:09	S26-2617	Water Pump, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/28/2026 13:12	S26-2595	Block 2 Lot 10, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/22/2026 11:29	S26-2427	Water Pump, Block 12, Phase IIE, Mabuhay Homes 2000	ABSENCE	ABSENCE	11
04/22/2026 11:40	S26-2428	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	210
04/14/2026 10:12	S26-2204	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
04/22/2026 12:01	S26-2429	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
04/22/2026 09:31	S26-2430	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	1
04/22/2026 09:31	S26-2431	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	1
04/22/2026 10:00	S26-2432	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/22/2026 10:14	S26-2433	#1780, National Road	ABSENCE	ABSENCE	< 1
04/22/2026 10:21	S26-2438	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	15
04/14/2026 10:29	S26-2205	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	1
BRGY. DON JOSE					
04/16/2026 13:08	S26-2295	Church, Block 108, Phase V, Laguna Bel-Air	ABSENCE	ABSENCE	13
04/16/2026 14:21	S26-2294	Clubhouse, Phase I, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
04/16/2026 14:01	S26-2298	Block 47 Lot 12, Phase IV, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
04/16/2026 16:32	S26-2289	Clubhouse. Phase IV-B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
04/16/2026 15:56	S26-2290	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	79
04/16/2026 15:04	S26-2291	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
04/16/2026 15:12	S26-2292	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
04/16/2026 14:37	S26-2299	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	76
BRGY. MACABLING					
04/20/2026 13:57	S26-2372	Block 4 Lot 44, Phase 2, Buena Rosa IX Subdivision	ABSENCE	ABSENCE	13
04/20/2026 13:00	S26-2369	Clubhouse, Corinthian Homes Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
04/22/2026 10:38	S26-2434	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	1
04/14/2026 10:05	S26-2207	Gate entrance guard house, Terra Fortuna	ABSENCE	ABSENCE	9
04/28/2026 12:21	S26-2600	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
04/22/2026 14:25	S26-2462	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
04/22/2026 14:31	S26-2463	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
04/14/2026 11:11	S26-2200	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
04/14/2026 11:17	S26-2201	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	< 1
04/14/2026 10:54	S26-2202	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
04/16/2026 15:33	S26-2293	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
04/28/2026 13:51	S26-2601	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	< 1
04/28/2026 13:58	S26-2602	Tope Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-2075 **DATE/TIME SUBMITTED :** 04/08/2026 13:34

DATE/TIME COLLECTION : 04/08/2026 11:42 **COLLECTED BY :** Jonnel S. Mercado

NO. OF SAMPLES : 1 **TOTAL PARAMETERS TESTED :** 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear and sterile glass container with 3% sodium thiosulfate.

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.94	4500-Cl-G.DPD Colorimetric	04/08/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/08/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	04/08/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 39

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 04/08/2026-04/30/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/08/2026 12:57	S26-2074	Laguna Wellfield I	ABSENCE	ABSENCE	1
BRGY. BALIBAGO					
04/22/2026 14:53	S26-2459	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
04/14/2026 10:17	S26-2203	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	1
04/22/2026 13:10	S26-2435	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
04/22/2026 10:04	S26-2469	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
04/23/2026 14:53	S26-2517	2nd Floor Faucet, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
BRGY. DILA					
04/30/2026 11:09	S26-2617	Water Pump, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/28/2026 13:12	S26-2595	Block 2 Lot 10, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/22/2026 11:29	S26-2427	Water Pump, Block 12, Phase IIE, Mabuhay Homes 2000	ABSENCE	ABSENCE	11
04/22/2026 11:40	S26-2428	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	210
04/14/2026 10:12	S26-2204	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
04/22/2026 12:01	S26-2429	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
04/22/2026 09:31	S26-2430	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	1
04/22/2026 09:31	S26-2431	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	1
04/22/2026 10:00	S26-2432	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/22/2026 10:14	S26-2433	#1780, National Road	ABSENCE	ABSENCE	< 1
04/22/2026 10:21	S26-2438	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	15
04/14/2026 10:29	S26-2205	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	1
BRGY. DON JOSE					
04/16/2026 13:08	S26-2295	Church, Block 108, Phase V, Laguna Bel-Air	ABSENCE	ABSENCE	13
04/16/2026 14:21	S26-2294	Clubhouse, Phase I, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
04/16/2026 14:01	S26-2298	Block 47 Lot 12, Phase IV, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
04/16/2026 16:32	S26-2289	Clubhouse. Phase IV-B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
04/16/2026 15:56	S26-2290	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	79
04/16/2026 15:04	S26-2291	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
04/16/2026 15:12	S26-2292	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
04/16/2026 14:37	S26-2299	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	76
BRGY. MACABLING					
04/20/2026 13:57	S26-2372	Block 4 Lot 44, Phase 2, Buena Rosa IX Subdivision	ABSENCE	ABSENCE	13
04/20/2026 13:00	S26-2369	Clubhouse, Corinthian Homes Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
04/22/2026 10:38	S26-2434	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	1
04/14/2026 10:05	S26-2207	Gate entrance guard house, Terra Fortuna	ABSENCE	ABSENCE	9
04/28/2026 12:21	S26-2600	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
04/22/2026 14:25	S26-2462	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
04/22/2026 14:31	S26-2463	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
04/14/2026 11:11	S26-2200	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
04/14/2026 11:17	S26-2201	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	< 1
04/14/2026 10:54	S26-2202	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
04/16/2026 15:33	S26-2293	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
04/28/2026 13:51	S26-2601	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	< 1
04/28/2026 13:58	S26-2602	Tope Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Laboratory Service Manager
License No(s). (PRC 0013295)