

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21

TOTAL PARAMETERS TESTED: 3


ANALYSIS DATE(S) : 02/09/2023-02/22/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/13/2023 12:32	S23-0727	Laguna Wellfield 1	ABSENCE	ABSENCE	1
BRGY. CAINGIN					
02/21/2023 11:43	S23-0979	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
02/21/2023 12:07	S23-0980	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	2
02/21/2023 11:59	S23-0983	Block 2 Lot 16, Phase 9 Southville	ABSENCE	ABSENCE	< 1
02/21/2023 13:37	S23-0981	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
02/21/2023 12:32	S23-0976	Block 18 Lot 2, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
02/22/2023 14:18	S23-1023	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/21/2023 13:37	S23-0982	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
02/21/2023 13:01	S23-0973	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
02/09/2023 10:52	S23-0669	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/09/2023 11:14	S23-0671	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
02/09/2023 11:26	S23-0679	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
02/09/2023 11:34	S23-0680	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
02/09/2023 10:11	S23-0670	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
02/09/2023 10:57	S23-0672	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
02/09/2023 12:43	S23-0673	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
02/09/2023 12:50	S23-0674	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	170
02/09/2023 11:57	S23-0675	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	2
02/09/2023 12:04	S22-0676	Ilonggo, Robinson's Mall	ABSENCE	ABSENCE	220
02/16/2023 12:01	S23-0861	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1
02/16/2023 12:10	S23-0862	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 43

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 02/14/2023-02/20/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/13/2023 12:32	S23-0727	Laguna Wellfield 1	ABSENCE	ABSENCE	1
BRGY. BALIBAGO					
02/22/2023 13:47	S23-1022	#4354 Facundo Compound	ABSENCE	ABSENCE	3
02/14/2023 09:10	S23-0758	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
02/14/2023 09:00	S23-0765	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	< 1
02/20/2023 15:01	S23-0954	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	1
02/20/2023 14:50	S23-0955	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	3
02/16/2023 09:14	S23-0860	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
02/16/2023 10:21	S23-0850	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	8
02/16/2023 10:39	S23-0851	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	2
02/16/2023 11:09	S23-0852	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	3
02/16/2023 11:18	S23-0853	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
02/14/2023 10:27	S23-0759	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
02/16/2023 11:30	S23-0854	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
02/16/2023 10:10	S23-0855	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	1
02/16/2023 08:10	S23-0856	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
02/16/2023 08:17	S23-0857	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/16/2023 08:31	S23-0858	#1780, National Road	ABSENCE	ABSENCE	< 1
02/16/2023 09:25	S23-0863	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
02/14/2023 10:13	S23-0760	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	12
BRGY. DON JOSE					
02/16/2023 13:57	S23-0904	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/16/2023 13:48	S23-0903	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/16/2023 13:39	S23-0907	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/16/2023 15:25	S23-0898	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	18
02/16/2023 15:35	S23-0899	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
02/16/2023 14:22	S23-0900	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
02/16/2023 14:27	S23-0901	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
02/16/2023 14:08	S23-0908	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
02/09/2023 13:44	S23-0681	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
02/09/2023 13:25	S23-0677	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	4
02/09/2023 13:34	S23-0678	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
02/16/2023 08:50	S23-0859	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
02/14/2023 10:01	S23-0764	Block 11 Lot 16, Terra Fortuna	ABSENCE	ABSENCE	< 1
02/14/2023 09:30	S23-0762	Water Pump, 9999 W, Villa Las Casas	ABSENCE	ABSENCE	< 1
02/14/2023 09:49	S23-0761	Block 5 Lot 21, Phase 1A Annex, San Lorenzo Subdivision	ABSENCE	ABSENCE	< 1
02/14/2023 09:38	S23-0763	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC					
02/21/2023 11:03	S23-0977	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
02/21/2023 11:16	S23-0978	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
02/14/2023 11:00	S23-0755	Manzano Residence	ABSENCE	ABSENCE	< 1
02/14/2023 10:52	S23-0757	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
02/14/2023 10:46	S23-0756	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
02/14/2023 11:09	S23-0766	Water Pump, Pulong Sta. Cruz, Brgy. Sitio Aratan	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO					
02/16/2023 14:39	S23-0902	Clubhouse Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
02/16/2023 14:54	S23-0909	Water Pump	ABSENCE	ABSENCE	< 1
02/16/2023 15:01	S23-0910	Tope Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.