

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

#### CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

#### ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

## SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21

**TOTAL PARAMETERS TESTED: 3** 

ANALYSIS DATE(S) : 03/07/2022 - 03/19/2022

DATE/TIME COLLECTED	SAMPLE CODE		PARAMETER		
			COLIF	ORM <sup>A</sup>	HPC <sup>B</sup> (CFU/mL)
		SAMPLE LOCATION	<b>TOTAL</b> (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	
BRGY. BIÑAN				•	
03/07/2022 14:55	S22-1157	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
03/14/2022 10:10	S22-1266	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
03/14/2022 10:49	S22-1267	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
03/16/2022 10:42	S22-1359	Block 2 Lot 16, Phase 8, Southville	ABSENCE	ABSENCE	< 1
03/14/2022 10:15	S22-1268	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
03/14/2022 11:11	S22-1263	Block 18 Lot 2, Alfonso Homes I	ABSENCE	ABSENCE	5
BRGY. MALUSAK					
03/14/2022 12:13	S22-1262	Santa Rosa City Hall	ABSENCE	ABSENCE	2
03/14/2022 12:03	S22-1269	Drinking Fountain I, Central I Elementary	ABSENCE	ABSENCE	11
BRGY. SINALHAN					
03/14/2022 11:36	S22-1260	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	10

NOT VALID WITHOUT QR CODE



**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

ALYSSA MARIE PENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969)

GUTIÉRREZ, RMT ANNA KAR/L Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED			PARAMETER			
			COLIFORMA		HPC <sup>B</sup> (CFU/mL)	
	SAMPLE CODE	SAMPLE LOCATION TOTAL (Coliforms/ 100mL)		FECAL/ E. coli (Coliforms/ 100 mL)		
BRGY. TAGAPO						
03/10/2022 11:21	S22-1230	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	-	
03/10/2022 11:43	S22-1232	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	-	
03/10/2022 11:21	S22-1240	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	-	
03/10/2022 11:26	S22-1241	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	-	
03/10/2022 10:39	S22-1231	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	-	
03/10/2022 11:03	S22-1233	Block 14 Lot 6, Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1	
03/10/2022 12:36	S22-1234	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	-	
03/10/2022 12:41	S22-1235	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	-	
03/10/2022 12:06	S22-1236	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	-	
03/10/2022 12:14	S22-1237	llonggo, Robinson's Mall	ABSENCE	ABSENCE	-	
03/18/2022 15:03	S22-1457	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	-	
03/18/2022 15:04	S22-1458	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	-	

**REMARKS:** Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable DEVIATIONS: No deviation noted on sample collection and submission.

**METHODS:** <u>A</u>- Enzyme Substrate; <u>B</u> – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

ALYSSA MARIE C. PENALES, RMT

ALYSSA MARIZ (C. PENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969) Albutiun ANNA KARLA S. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



Accreditations, Recognitions and Licenses: DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

### CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

### ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

#### SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 47

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 03/07/2022 - 03/19/2022

	SAMPLE CODE		PARAMETER			
			COLIFORMA			
DATE/TIME COLLECTED		SAMPLE LOCATION	<b>TOTAL</b> (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	<b>НРС<sup>в</sup></b> (CFU/mL)	
BRGY. BIÑAN	•	· · · · · ·			•	
03/07/2022 14:55	S22-1157	Laguna Wellfield 1	ABSENCE	ABSENCE	<1	
BRGY. BALIBAGO						
03/14/2022 11:36	S22-1261	#4354 Facundo Compound	ABSENCE	ABSENCE	30	
03/18/2022 16:00	S22-1426	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	-	
03/18/2022 15:24	S22-1456	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	-	
03/18/2022 16:39	S22-1420	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	-	
03/18/2022 16:31	S22-1421	2 <sup>nd</sup> Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	-	
BRGY. DILA						
03/18/2022 15:49	S22-1444	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 15:58	S22-1445	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 16:10	S22-1446	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	-	
03/18/2022 16:18	S22-1447	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	-	
03/18/2022 16:10	S22-1425	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	-	
03/18/2022 16:22	S22-1448	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	-	
BRGY. DITA						
03/18/2022 13:58	S22-1449	Water Pump, Block 24 Lot 2, New Santa Rosa Homes	ABSENCE	ABSENCE	-	
03/18/2022 14:10	S22-1450	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	-	
03/18/2022 15:02	S22-1451	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 15:10	S22-1452	Lagua Residence, SolCar Ville Subdivision	ABSENCE	ABSENCE	-	

NOT VALID WITHOUT QR CODE



**REVIEWED BY:** 

ALYSSA MARIE C. PENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969)

**CERTIFIED CORRECT BY:** 

ANNA KARLÀ S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.

## Page 1 of 3



Accreditations, Recognitions and Licenses: DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

# ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916

WEBSITE:	www	lagunaw	ater com	n nh
VVLDJIIL.		lugunuw		1. PT

			PARAMETER			
DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	COLIFORM <sup>A</sup>			
			<b>TOTAL</b> (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	<b>HPC</b> <sup>₿</sup> (CFU/mL)	
03/18/2022 15:36	S22-1453	Innes Store, National Road	ABSENCE	ABSENCE	-	
03/18/2022 16:24	S22-1459	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	-	
03/18/2022 15:50	S22-1427	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	-	
BRGY. DON JOSE						
03/09/2022 13:11	S22-1207	Science High School, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1	
03/09/2022 11:08	S22-1209	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1	
03/09/2022 13:23	S22-1208	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1	
03/09/2022 12:57	S22-1212	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	1	
03/09/2022 14:48	S22-1202	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1	
03/09/2022 15:00	S22-1203	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	1	
03/09/2022 14:34	S22-1204	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
03/09/2022 14:38	S22-1205	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1	
03/09/2022 13:37	S22-1213	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1	
BRGY. MACABLING	•					
03/10/2022 14:10	S22-1242	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	-	
03/10/2022 13:50	S22-1238	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	-	
03/10/2022 13:57	S22-1239	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	-	
BRGY. MALITLIT						
03/18/2022 16:40	S22-1454	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 13:17	S22-1428	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 13:13	S22-1429	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	ABSENCE	ABSENCE	-	
03/18/2022 13:46	S22-1432	Water Pump, Main Road, Phase 2, Terra Fortuna	ABSENCE	ABSENCE	-	
03/18/2022 13:51	S22-1433	Block 11 Lot 16, Terra Fortuna	ABSENCE	ABSENCE	-	
03/18/2022 13:30	S22-1430	Water Pump, 9999 W, Villa Las Casas	ABSENCE	ABSENCE	_	
03/18/2022 13:36	S22-1431	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	-	
03/18/2022 16:59	S22-1455	Drinking Fountain, Malitlit Elementary	ABSENCE	ABSENCE	-	

NOT VALID WITHOUT QR CODE



**REVIEWED BY:** 

ALYSSA MARIE C. PENALES, RMT Microbiology Unit Manager License No(s). (PRC 0064969)

**CERTIFIED CORRECT BY:** 

ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



Accreditations, Recognitions and Licenses: DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM <sup>A</sup>			
			<b>TOTAL</b> (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	<b>НРС<sup>в</sup></b> (CFU/mL)	
BRGY. POOC						
03/14/2022 09:46	S22-1264	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	<1	
03/14/2022 09:50	S22-1265	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	<1	
BRGY. PULONG STA. CRI	JZ					
03/18/2022 11:17	S22-1422	Block 6 Lot 8, Buklod Diwa	ABSENCE	ABSENCE	-	
03/18/2022 11:40	S22-1424	Drinking Fountain 2, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	-	
03/18/2022 11:36	S22-1423	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	-	
BRGY. SANTO DOMINGO	)					
03/09/2022 13:56	S22-1206	Clubhouse Santa Rosa Estates II	ABSENCE	ABSENCE	< 1	
03/09/2022 14:10	S22-1214	Water Pump, Sto. Domingo	ABSENCE	ABSENCE	< 1	
03/09/2022 14:15	S22-1215	Household 6345, Sto. Domingo	ABSENCE	ABSENCE	<1	

**REMARKS:** Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quanitification; <u>NA</u> – Not Applicable **DEVIATIONS:** No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT OR CODE



**REVIEWED BY:** 

ALYSSA MARIE Microbiology Unit Manager License No(s). (PRC 0064969)

**CERTIFIED CORRECT BY:** 

ANNA KARLA S. GUTJERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.