

DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20 TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 12/11/2024-12/23/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
12/03/2024 14:28	S24-6954	Laguna Wellfield 1	ABSENCE	ABSENCE	<1
BRGY. CAINGIN					
12/18/2024 12:36	S24-7352	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	<1
12/18/2024 13:04	S24-7353	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	10
12/23/2024 08:25	S24-7423	Southville Integrated Highschool	ABSENCE	ABSENCE	<1
BRGY. KANLURAN					
12/18/2024 11:40	S24-7349	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	<1
BRGY. MALUSAK					
12/18/2024 11:23	S24-7348	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	16
12/18/2024 11:09	S24-7355	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	<1
BRGY. SINALHAN					
12/18/2024 10:24	S24-7346	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	<1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLAIS, GUTTERREZ, RM-Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. TAGAPO						
12/17/2024 11:27	S24-7320	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1	
12/17/2024 11:38	S24-7322	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	3	
12/17/2024 11:55	S24-7329	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	<1	
12/17/2024 12:04	S24-7330	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	<1	
12/17/2024 10:49	S24-7321	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	3	
12/17/2024 11:11	S24-7323	Block 14 Lot 17 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1	
12/17/2024 13:01	S24-7324	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	19	
12/17/2024 13:07	S24-7325	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	23	
12/17/2024 12:30	S24-7326	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	12	
12/17/2024 12:37	S24-7327	Buko Haus, Robinson's Mall	ABSENCE	ABSENCE	< 1	
12/11/2024 13:20	S24-7145	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	
12/11/2024 13:38	S24-7146	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA'S (dutier lez, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 35 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 12/06/2024-12/23/2024

DATE/TIME COLLECTED			PARAMETER		
			COLIFORM ^A		
	SAMPLE CODE	SAMPLE LOCATIOHN	TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
12/03/2024 14:29	S24-6954	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
12/18/2024 10:26	S24-7347	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
12/06/2024 12:18	S24-7046	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
12/23/2024 10:38	S24-7427	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
12/23/2024 10:30	S24-7428	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
12/11/2024 13:58	S24-7144	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
12/11/2024 11:40	S24-7134	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
12/11/2024 11:55	S24-7135	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
12/11/2024 12:16	S24-7136	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	<1
12/11/2024 12:34	S24-7137	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
12/06/2024 12:18	S24-7047	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	<1
12/11/2024 12:50	S24-7138	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	<1
BRGY. DITA				•	•
12/11/2024 10:25	S24-7139	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	<1
12/11/2024 10:10	S24-7140	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1
12/11/2024 10:16	S24-7141	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S, GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORMA			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
12/11/2024 10:34	S24-7142	#1780, National Road	ABSENCE	ABSENCE	< 1	
12/11/2024 11:22	S24-7147	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	<1	
12/06/2024 12:09	S24-7048	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	<1	
BRGY. DON JOSE						
12/09/2024 11:51	S24-7097	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	42	
12/09/2024 12:50	S24-7096	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
12/09/2024 12:39	S24-7100	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
12/09/2024 09:47	S24-7091	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1	
12/09/2024 09:58	S24-7092	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	3	
12/09/2024 10:10	S24-7093	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1	
12/09/2024 10:16	S24-7094	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
12/09/2024 11:31	S24-7101	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1	
BRGY. MACABLING						
12/17/2024 10:31	S24-7331	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	<1	
12/17/2024 10:18	S24-7328	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	<1	
BRGY. MALITLIT						
12/23/2024 09:30	S24-7424	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	<1	
12/06/2024 11:48	S24-7051	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1	
12/06/2024 11:20	S24-7049	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	1	
12/06/2024 11:37	S24-7050	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	<1	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S GUTTERREZ, RM-Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED			PARAMETER		
			COLIFORM ^A		
	SAMPLE CODE	SAMPLE LOCATION	TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. POOC					
12/18/2024 12:02	S24-7350	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	6
12/18/2024 12:17	S24-7351	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	N
BRGY. PULONG STA. CR	UZ				
12/06/2024 12:53	S24-7043	Water Pump	ABSENCE	ABSENCE	<1
12/06/2024 13:04	S24-7044	Block 6 Lot 8, Buklod Diwa	ABSENCE	ABSENCE	<1
12/06/2024 12:33	S24-7045	Drinking Fountain II, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	<1
BRGY. SANTO DOMINGO	o				
12/09/2024 10:28	S24-7095	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	<1
12/09/2024 10:58	S24-7102	Water Pump	ABSENCE	ABSENCE	7
12/09/2024 11:10	S24-7103	Ortega Residence	ABSENCE	ABSENCE	1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quanitification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.