

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 02/03/2026-02/26/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/09/2026 13:46	S26-0874	Laguna Wellfield I	ABSENCE	ABSENCE	310
BRGY. CAINGIN					
02/26/2026 12:03	S26-1280	Water Pump, Block 57, Phase I, Southville	ABSENCE	ABSENCE	< 1
02/26/2026 11:48	S26-1281	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	33
02/23/2026 13:31	S26-1199	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
02/25/2026 14:25	S26-1276	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	1
BRGY. MALUSAK					
02/23/2026 11:35	S26-1193	Canteen, Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/23/2026 11:19	S26-1200	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
02/23/2026 10:52	S26-1191	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
02/03/2026 09:15	S26-0701	#6031 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/03/2026 09:28	S26-0703	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	2
02/03/2026 09:46	S26-0710	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	<1
02/03/2026 09:53	S26-0711	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	1
02/03/2026 08:36	S26-0702	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
02/03/2026 08:56	S26-0704	Block 14 Lot 17, Buena Rosa X	ABSENCE	ABSENCE	14
02/03/2026 10:51	S26-0705	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
02/03/2026 10:56	S26-0706	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
02/03/2026 10:16	S26-0707	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
02/03/2026 10:22	S26-0708	Sisig Station, Robinson's Mall	ABSENCE	ABSENCE	11
02/16/2026 12:38	S26-1002	Water Pump, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	210
02/16/2026 12:50	S26-1003	Clubhouse, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B**- Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 40

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 02/03/2026-02/24/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/09/2026 13:46	S26-0874	Laguna Wellfield I	ABSENCE	ABSENCE	310
BRGY. BALIBAGO					
02/23/2026 14:21	S26-1192	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
02/03/2026 13:31	S26-0716	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
02/16/2026 12:24	S26-1001	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
02/23/2026 15:13	S26-1208	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
02/23/2026 15:02	S26-1209	2nd Floor Faucet, Waltermart Santa Rosa	ABSENCE	ABSENCE	1
BRGY. DILA					
02/16/2026 10:50	S26-0991	Water Pump, Phase III E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
02/16/2026 10:59	S26-0992	Block 2 Lot 10, Phase III E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	220
02/16/2026 11:21	S26-0993	Water Pump, Block 12, Phase IIE, Mabuhay Homes 2000	ABSENCE	ABSENCE	4
02/16/2026 11:39	S26-0994	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	8
02/03/2026 13:27	S26-0717	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
02/16/2026 12:01	S26-0995	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	2
BRGY. DITA					
02/16/2026 09:54	S26-0996	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
02/16/2026 09:10	S26-0997	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
02/16/2026 09:16	S26-0998	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/16/2026 09:29	S26-0999	#1780, National Road	ABSENCE	ABSENCE	< 1
02/24/2026 10:50	S26-1216	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
02/03/2026 13:11	S26-0718	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
02/05/2026 13:02	S26-0830	Church, Block 108, Phase V, Laguna Bel-Air	ABSENCE	ABSENCE	45
02/05/2026 13:52	S26-0829	Clubhouse, Phase I, Laguna Bel-Air	ABSENCE	ABSENCE	1
02/05/2026 13:43	S26-0833	Block 47 Lot 12, Phase IV, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/05/2026 10:26	S26-0824	Clubhouse, Phase IV-B, Santa Rosa Village I	ABSENCE	ABSENCE	2
02/05/2026 10:34	S26-0825	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	1
02/05/2026 11:49	S26-0826	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	10
02/05/2026 11:43	S26-0827	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	2
02/05/2026 12:47	S26-0834	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	6
BRGY. MACABLING					
02/03/2026 08:22	S26-0712	Block 4 Lot 44, Phase 2, Buena Rosa IX Subdivision	ABSENCE	ABSENCE	3
02/03/2026 08:12	S26-0709	Clubhouse, Corinthian Homes Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
02/16/2026 10:16	S26-1000	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	340
02/03/2026 13:02	S26-0721	Water Pump, Terra Fortuna	ABSENCE	ABSENCE	< 1
02/03/2026 12:32	S26-0719	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	3
02/03/2026 12:47	S26-0720	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
02/23/2026 12:31	S26-1195	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
02/23/2026 12:44	S26-1196	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
02/03/2026 14:07	S26-0713	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
02/03/2026 14:12	S26-0714	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	1
02/03/2026 13:53	S26-0715	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
02/05/2026 11:30	S26-0828	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	2
02/05/2026 10:54	S26-0835	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	6
02/05/2026 11:06	S26-0836	Tope Residence	ABSENCE	ABSENCE	1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-0875

DATE/TIME SUBMITTED : 02/09/2026 14:49

DATE/TIME COLLECTION : 02/09/2026 12:43

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.50	4500-Cl-G.DPD Colorimetric	02/09/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	02/09/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	02/09/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN V. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)