

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 01/06/2026-01/19/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
01/06/2026 12:09	S26-0074	Laguna Wellfield I	ABSENCE	ABSENCE	4
BRGY. CAINGIN					
01/14/2026 11:11	S26-0316	Water Pump, Block 57, Phase I, Southville	ABSENCE	ABSENCE	< 1
01/14/2026 11:32	S26-0317	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
01/14/2026 11:05	S26-0318	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
01/14/2026 09:24	S26-0313	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
01/14/2026 09:05	S26-0312	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	230
01/14/2026 08:05	S26-0319	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	6
BRGY. SINALHAN					
01/14/2026 08:13	S26-0310	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	82

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
01/08/2026 09:43	S26-0163	#6031 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
01/06/2026 00:14	S26-0086	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
01/06/2026 10:41	S26-0092	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	120
01/06/2026 10:47	S26-0093	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	94
01/06/2026 09:22	S26-0085	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
01/06/2026 09:41	S26-0087	Block 14 Lot 17, Buena Rosa X	ABSENCE	ABSENCE	< 1
01/06/2026 11:37	S26-0088	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
01/06/2026 11:45	S26-0095	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	1
01/06/2026 11:04	S26-0089	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	49
01/06/2026 11:11	S26-0090	Sizzlers, Robinson's Mall	ABSENCE	ABSENCE	8
01/19/2026 12:40	S26-0425	Water Pump, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1
01/19/2026 13:00	S26-0426	Clubhouse, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	340

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B**- Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 38

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 01/06/2026-01/19/2026

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
01/06/2026 12:09	S26-0074	Laguna Wellfield I	ABSENCE	ABSENCE	4
BRGY. BALIBAGO					
01/14/2026 11:41	S26-0311	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
01/14/2026 13:15	S26-0326	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
01/19/2026 13:12	S26-0424	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
01/22/2026 10:40	S26-0548	Water Pump, Phase III E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	3
01/22/2026 11:01	S26-0549	Block 2 Lot 10, Phase III E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
01/19/2026 11:50	S26-0416	Water Pump, Block 12, Phase IIE, Mabuhay Homes 2000	ABSENCE	ABSENCE	220
01/19/2026 12:12	S26-0417	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
01/14/2026 13:05	S26-0325	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
01/19/2026 12:19	S26-0418	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
01/19/2026 10:10	S26-0419	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
01/19/2026 09:30	S26-0420	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
01/19/2026 09:41	S26-0421	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/19/2026 10:25	S26-0422	#1780, National Road	ABSENCE	ABSENCE	< 1
01/19/2026 10:50	S26-0427	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
01/14/2026 12:54	S26-0324	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
01/19/2026 09:30	S26-0407	Church, Block 108, Phase V, Laguna Bel-Air	ABSENCE	ABSENCE	110
01/19/2026 10:56	S26-0406	Clubhouse, Phase I, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
01/19/2026 10:20	S26-0410	Block 47 Lot 12, Phase IV, Laguna Bel-Air	ABSENCE	ABSENCE	1
01/19/2026 12:45	S26-0401	Clubhouse, Phase IV-B, Santa Rosa Village I	ABSENCE	ABSENCE	1
01/19/2026 12:54	S26-0402	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
01/19/2026 12:22	S26-0403	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
01/19/2026 12:31	S26-0404	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
01/19/2026 11:13	S26-0411	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	1
BRGY. MACABLING					
01/06/2026 09:08	S26-0094	Block 4 Lot 44, Phase 2, Buena Rosa IX Subdivision	ABSENCE	ABSENCE	< 1
01/06/2026 08:54	S26-0091	Clubhouse, Corinthian Homes Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
01/19/2026 10:34	S26-0423	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
01/14/2026 12:40	S26-0323	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
01/14/2026 12:20	S26-0321	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1
01/14/2026 12:31	S26-0322	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
01/14/2026 10:24	S26-0314	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
01/14/2026 10:36	S26-0315	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
01/14/2026 13:43	S26-0328	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
01/14/2026 13:50	S26-0329	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	< 1
01/14/2026 13:28	S26-0327	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
01/19/2026 12:05	S26-0405	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	1
01/19/2026 11:37	S26-0412	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	< 1
01/19/2026 11:48	S26-0413	Labrador Residence	ABSENCE	ABSENCE	1

REMARKS: Sample collection was performed by LAWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S26-0075 **DATE/TIME SUBMITTED :** 01/06/2026 13:34

DATE/TIME COLLECTION : 01/06/2026 10:32 **COLLECTED BY :** Jonnel S. Mercado

NO. OF SAMPLES : 1 **TOTAL PARAMETERS TESTED :** 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.69	4500-Cl-G.DPD Colorimetric	01/06/2026	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	01/06/2026	MGA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	01/06/2026	MGA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	01/06/2026	MGA

REMARKS: Sample collection was performed by LAWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)