

DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20 TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 06/10/2025-06/25/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. BIÑAN						
06/11/2025 13:57	S25-3843	Laguna Wellfield 1	ABSENCE	ABSENCE	<1	
BRGY. CAINGIN						
06/24/2025 14;01	S25-4197	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	<1	
06/25/2025 14:16	S25-4199	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	1	
06/24/2025 13:47	S25-4198	Southville Integrated Highschool	ABSENCE	ABSENCE	51	
BRGY. KANLURAN						
06/23/2025 13:39	S25-4161	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	<1	
BRGY. MALUSAK						
06/23/2025 13:05	S25-4159	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	170	
06/23/2025 13:15	S25-4160	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	50	
BRGY. SINALHAN						
06/23/2025 12:07	S25-4158	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	16	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

SHEENA MAE B. ANDRES Laboratory Analyst

.NNA KARLA'S. GUTJERREZ, RM Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. TAGAPO						
06/10/2025 10:21	S25-3753	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1	
06/10/2025 10:33	S25-3755	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1	
06/10/2025 10:52	S25-3762	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	<1	
06/24/2025 12:18	S25-4193	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	15	
06/10/2025 09:41	S25-3754	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1	
06/10/2025 10:09	S25-3756	Block 14 Lot 7, Buena Rosa 10	ABSENCE	ABSENCE	4	
06/10/2025 11:52	S25-3757	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1	
06/10/2025 11:58	S25-3758	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1	
06/10/2025 11:24	S25-3759	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	1	
06/10/2025 11:32	S25-3760	Sonyda, Robinson's Mall	ABSENCE	ABSENCE	< 1	
06/25/2025 12:16	S25-4220	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	
06/25/2025 12:28	S25-4221	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	<1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

HEENA MAEB. ANDRES
Laboratory Analyst

ANNA KARLA S GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 40 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 06/10/2025-06/30/2025

DATE/TIME COLLECTED		SAMPLE LOCATIOHN	PARAMETER		
			COLIFORM ^A		
	SAMPLE CODE		TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
06/11/2025 13:57	S25-3843	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
06/23/2025 14;36	S25-4163	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
06/24/2025 12:18	S25-4194	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
06/23/2025 10:34	S25-4156	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
06/23/2025 10:25	S25-4157	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	<1
06/25/2025 13:10	S25-4219	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
06/10/2025 14:10	S25-3796	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
06/10/2025 14:19	S25-3797	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
06/10/2025 13:20	S25-3798	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	8
06/25/2025 11:54	S25-4217	Block 34 Lot 9, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
06/18/2025 10:25	S25-4000	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	2
06/10/2025 11:59	S25-3800	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA				•	-
06/10/2025 11:48	S25-3801	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
06/10/2025 11:10	S25-3802	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
06/10/2025 11:16	S25-3803	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

SHEENA MAE B. ANDRES Laboratory Analyst

ANNA KARLA S. GUTJERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORMA			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
06/10/2025 11:29	S25-3804	#1780, National Road	ABSENCE	ABSENCE	< 1	
06/25/2025 11:18	S25-4222	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	74	
06/18/2025 10:16	S25-4001	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	30	
BRGY. DON JOSE						
06/11/2025 13:09	S25-3825	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	470	
06/11/2025 13:09	S25-3824	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1	
06/18/2025 11:40	S25-4005	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	42	
06/18/2025 12:04	S25-4006	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	16	
06/11/2025 11:27	S25-3820	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1	
06/11/2025 11:41	S25-3821	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1	
06/11/2025 11:47	S25-3822	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
06/11/2025 12:08	S25-3829	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1	
BRGY. MACABLING						
06/10/2025 09:26	S25-3764	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1	
06/10/2025 09:15	S25-3761	Clubhouse, Corinthian Subdivision	ABSENCE	ABSENCE	< 1	
BRGY. MALITLIT						
06/30/2025 09:01	S25-4295	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	8	
06/18/2025 10:06	S25-4004	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1	
06/18/2025 09:32	S25-4002	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1	
06/18/2025 09:45	S25-4003	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1	
BRGY. POOC						
06/24/2025 13:15	S25-4195	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	17	
06/24/2025 13:24	S25-4196	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	1	
BRGY. PULONG STA. CR	UZ					
06/25/2025 13:34	S25-4208	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	22	
06/25/2025 13:42	S25-4209	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	< 1	
06/18/2025 10:53	S25-3998	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	4	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

SHEENA MAB B. ANDRES Laboratory Analyst

ANNA KARLAS. GUTHRREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED			PARAMETER			
			COLIFC	DRM ^A	HPC ^B (CFU/mL)	
	SAMPLE CODE	SAMPLE LOCATION	TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)		
BRGY. SANTO DOMINGO						
06/11/2025 10:50	S25-3823	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	<1	
06/11/2025 10:01	S25-3830	Water Pump, Sto. Domingo	ABSENCE	ABSENCE	2	
06/11/2025 10:14	S25-3831	Labrador Residence	ABSENCE	ABSENCE	<1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quanitification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT OR CODE

REVIEWED BY:

SHEENA MAE B. ANDRES Laboratory Analyst **CERTIFIED CORRECT BY:**

ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.