

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21 TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 05/07/2024-05/28/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
05/23/2023 13:13	S24-2869	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
05/16/2024 11:41	S24-2739	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
05/16/2024 12:21	S24-2740	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
05/16/2024 12:04	S24-2743	Block 2 Lot 16, Phase 8 Southville	ABSENCE	ABSENCE	<1
05/16/2024 11:24	S24-2741	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
05/16/2024 13:30	S24-2734	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	2
BRGY. MALUSAK					
05/16/2024 14:11	S24-2733	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	6
05/16/2024 13:52	S24-2742	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
05/16/2024 14:36	S24-2731	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORMA			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. TAGAPO						
05/07/2024 11:09	S24-2500	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1	
05/07/2024 11:21	S24-2502	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1	
05/07/2024 11:43	S24-2510	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1	
05/07/2024 11:48	S24-2511	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	<1	
05/07/2024 10:39	S24-2501	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1	
05/07/2024 10:56	S24-2503	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1	
05/07/2024 12:50	S24-2504	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1	
05/07/2024 13:02	S24-2505	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1	
05/07/2024 12:31	S24-2506	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	<1	
05/07/2024 12:37	S24-2507	Sonyda, Robinson's Mall	ABSENCE	ABSENCE	18	
05/28/2024 15:01	S24-2960	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	
05/20/2024 12:29	S24-2778	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLAS. GUT ERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 40 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 05/07/2024-05/28/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
05/23/2023 13:13	S24-2869	Laguna Wellfield 1	ABSENCE	ABSENCE	<1
BRGY. BALIBAGO					
05/16/2024 10:00	S24-2732	#4354 Facundo Compound	ABSENCE	ABSENCE	<1
05/20/2024 11:51	S24-2789	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	<1
05/20/2024 11:35	S24-2788	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	<1
05/20/2024 14:28	S24-2780	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	<1
05/20/2024 14:14	S24-2781	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	6
05/20/2024 12:41	S24-2775	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
05/20/2024 11:35	S24-2763	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
05/20/2024 11:47	S24-2764	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
05/20/2024 11:10	S24-2766	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	<1
05/20/2024 11:19	S24-2767	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	<1
05/20/2024 13:53	S24-2790	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	<1
05/20/2024 10:16	S24-2768	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	<1
BRGY. DITA					
05/20/2024 10:30	S24-2769	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	<1
05/20/2024 09:21	S24-2772	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1
05/20/2024 09:38	S24-2773	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336)

ANNA KARLA S. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
05/22/2024 09:50	S24-2773	#1780, National Road	ABSENCE	ABSENCE	<1	
05/20/2024 10:00	S24-2779	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	<1	
05/20/2024 13:20	S24-2791	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	2	
BRGY. DON JOSE						
05/15/2024 11:32	S24-2697	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
05/22/2024 13:18	S24-2696	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
05/15/2024 13:07	S24-2700	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
05/15/2024 10:17	S24-2691	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	<1	
05/15/2024 10:27	S24-2692	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	<1	
05/15/2024 10:42	S24-2693	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	4	
05/15/2024 10:51	S24-2694	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
05/15/2024 11:07	S24-2701	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	<1	
BRGY. MACABLING						
05/07/2024 10:24	S24-2512	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1	
05/07/2024 09:54	S24-2508	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	2	
05/07/2024 10:09	S24-2509	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	<1	
BRGY. MALITLIT						
05/28/2024 14:24	S24-2959	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	<1	
05/20/2024 13:09	S24-2795	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	<1	
05/20/2024 12:21	S24-2793	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	12	
05/20/2024 12:41	S24-2794	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	<1	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) ANNA KARLA S GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED		SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
	SAMPLE CODE		TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. POOC						
05/16/2024 10:36	S24-2736	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	<1	
05/16/2024 10:42	S24-2737	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	<1	
BRGY. PULONG STA. CR	UZ					
05/20/2024 11:08	S24-2784	Manzano Residence	ABSENCE	ABSENCE	<1	
05/20/2024 10:54	S24-2783	Water Pump	ABSENCE	ABSENCE	<1	
05/20/2024 14:49	S24-2786	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	<1	
05/20/2024 14:44	S24-2785	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	<1	
BRGY. SANTO DOMINGO	0					
05/15/2024 10:01	S24-2696	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	<1	
05/15/2024 09:30	S24-2702	Water Pump	ABSENCE	ABSENCE	<1	
05/15/2024 09:38	S24-2703	Tope Residence	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quanitification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: $\underline{\mathbf{A}}$ - Enzyme Substrate; $\underline{\mathbf{B}}$ – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) ANNA KARLA S. GUTIFRREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.