

DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21 TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 10/14/2024-10/30/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
10/30/2024 09:33	S24-6237	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
10/23/2024 13:23	S24-6160	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	8
10/23/2024 13:33	S24-6161	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	6
10/23/2024 14:04	S24-6164	Block 2 Lot 16, Phase 8 Southville	ABSENCE	ABSENCE	< 1
10/23/2024 13:17	S24-6162	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
10/23/2024 11:47	S24-6155	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	5
BRGY. MALUSAK					
10/23/2024 11:21	S24-6154	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	33
10/23/2024 11:12	S24-6163	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	<!--</b-->
BRGY. SINALHAN					
10/23/2024 10:33	S24-6152	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S. GUTJERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
BRGY. TAGAPO						
10/14/2024 14:20	S24-5880	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1	
10/14/2024 14:29	S24-5882	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1	
10/14/2024 15:08	S24-5890	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	19	
10/14/2024 15:19	S24-5891	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	<1	
10/14/2024 13:53	S24-5881	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1	
10/14/2024 14:11	S24-5883	Block 1 Lot 17 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1	
10/14/2024 16:12	S24-5884	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	3	
10/14/2024 16:18	S24-5885	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	10	
10/14/2024 15:41	S24-5886	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	98	
10/14/2024 15:49	S24-5887	Sonyda, Robinson's Mall	ABSENCE	ABSENCE	110	
10/17/2024 13:12	S24-6009	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	<1	
10/17/2024 13:19	S24-6010	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	<1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA \$ GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 36 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 10/14/2024-10/30/2024

DATE/TIME COLLECTED			PARAMETER		
			COLIFORM ^A		
	SAMPLE CODE	SAMPLE LOCATION	TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. BIÑAN					
10/30/2024 09:33	S24-6237	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
10/23/2024 15:44	S24-6153	#4354 Facundo Compound	ABSENCE	ABSENCE	7
10/22/2024 11:44	S24-6112	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
10/22/2024 12:17	S24-6106	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	8
10/29/2024 13:19	S24-6213	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	27
10/17/2024 12:30	S24-6007	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
10/17/2024 11:35	S24-5995	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
10/17/2024 11:29	S24-5996	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	1
10/17/2024 11:11	S24-5998	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	2
10/17/2024 11:18	S24-5999	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	2
10/22/2024 11:20	S24-6113	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	1
10/17/2024 12:10	S24-6000	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	<1
BRGY. DITA				•	
10/17/2024 13:45	S24-6001	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	1
10/17/2024 09:42	S24-6003	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1
10/17/2024 09:59	S24-6004	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA(s). GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2)
PNRI (RML No. Y04.04132.23)
PRC Certificate of Authority to Operate No. 111
PNP (License No. PDD03-230616-04201)
DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM ^A			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)	
10/17/2024 10:16	S24-6005	#1780, National Road	ABSENCE	ABSENCE	<1	
10/17/2024 13:30	S24-6011	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	<1	
10/22/2024 11:08	S24-6114	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	<1	
BRGY. DON JOSE						
10/15/2024 11:55	S24-5902	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	110	
10/15/2024 13:22	S24-5901	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
10/15/2024 13:12	S24-5905	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
10/15/2024 10:46	S24-5896	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	<1	
10/15/2024 10:56	S24-5897	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	1	
10/15/2024 11:09	S24-5898	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	1	
10/15/2024 11:18	S24-5899	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
10/22/2024 13:53	S24-6119	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	100	
BRGY. MACABLING						
10/14/2024 13:11	S24-5892	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1	
10/14/2024 13:35	S24-5888	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	<1	
BRGY. MALITLIT						
10/17/2024 10:29	S24-6006	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	1	
10/22/2024 10:55	S24-6118	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	<1	
10/22/2024 10:03	S24-6116	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	<1	
10/22/2024 10:24	S24-6117	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	<1	

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:**

ANNA KARLA S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (4A-0005-2426-LW-2) PNRI (RML No. Y04.04132.23) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201) DENR Environmental Laboratory Recognition (C.R. No.091/2022)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC ^B (CFU/mL)
BRGY. POOC					
10/23/2024 15:12	S24-6157	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	< 1
10/23/2024 15:20	S24-6158	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	3
BRGY. PULONG STA. CR	UZ				
09/23/2024 12:22	S24-5378	Manzano Residence	ABSENCE	ABSENCE	<1
10/22/2024 13:29	S24-6109	Water Pump	ABSENCE	ABSENCE	<1
10/22/2024 12:36	S24-6110	Block 6 Lot 8, Buklod Diwa	ABSENCE	ABSENCE	<1
10/22/2024 13:06	\$24-6111	Drinking Fountain 2, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	2
BRGY. SANTO DOMING	0		<u> </u>	· · · · · · · · · · · · · · · · · · ·	
10/15/2024 10:32	S24-5900	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	<1
10/15/2024 09:51	S24-5907	Water Pump	ABSENCE	ABSENCE	<1
10/15/2024 10:03	S24-5908	Doploso Residence	ABSENCE	ABSENCE	58

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC - Heterotrophic Plate Count; CFU - Colony Forming Units; MDL - Method Detection Limit; LOQ - Limit of Quanitification; NA - Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

ANNA KARLA(S. GIZTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)