

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 22

TOTAL PARAMETERS TESTED : 5


ANALYSIS DATE(S) : 12/02/2021 – 12/29/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
12/02/2021 10:00	S21-8014	Laguna Wellfield 1	7.48 / 27.9	0.45	ABSENCE	ABSENCE	5
BRGY. CAINGIN							
12/09/2021 13:59	S21-8212	Water Pump, Block 57, Phase 1, Southville	8.23 / 30.0	1.41	ABSENCE	ABSENCE	< 1
12/09/2021 14:32	S21-8213	Block 25 Lot 7, Phase 3, Southville	8.11 / 29.6	1.11	ABSENCE	ABSENCE	< 1
12/09/2021 14:15	S21-8216	Block 2 Lot 16, Phase 8, Southville	7.78 / 29.4	0.11	ABSENCE	ABSENCE	< 1
12/09/2021 14:04	S21-8214	Southville Integrated Highschool	8.26 / 30.1	1.48	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN							
12/27/2021 10:23	S21-8478	Gate Entrance, Alfonso Homes I	7.33 / 27.4	0.27	ABSENCE	ABSENCE	1
12/27/2021 10:09	S21-8475	#621 Rizal Boulevard	7.36 / 27.1	0.30	ABSENCE	ABSENCE	27
BRGY. MALUSAK							
12/27/2021 09:42	S21-8476	Santa Rosa City Hall	7.42 / 26.4	0.32	ABSENCE	ABSENCE	< 1
12/27/2021 10:01	S21-8477	Drinking Fountain I, Central I Elementary	7.38 / 27.6	0.28	ABSENCE	ABSENCE	84
BRGY. SINALHAN							
12/27/2021 09:35	S21-8474	Block 8 Lot 16, Bayshore III	7.34 / 26.6	0.38	ABSENCE	ABSENCE	45


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
12/06/2021 14:00	S21-8120	#6031 JP Rizal Boulevard	8.00 / 28.5	0.96	ABSENCE	ABSENCE	< 1
12/06/2021 14:50	S21-8122	Block 1 Lot 18, Fairfield of Margana Subdivision	8.17 / 28.8	1.10	ABSENCE	ABSENCE	< 1
12/06/2021 14:08	S21-8130	Water Pump, Rosewood Homes I	8.08 / 28.3	1.16	ABSENCE	ABSENCE	< 1
12/06/2021 14:15	S21-8131	Block 3 Lot 31, Rosewood Homes I	8.08 / 28.3	1.04	ABSENCE	ABSENCE	< 1
12/06/2021 15:00	S21-8132	Block 2 Lot 8, Rosewood Homes II	8.01 / 28.6	0.76	ABSENCE	ABSENCE	2
12/06/2021 13:31	S21-8121	Pump House Eye Wash, Buena Rosa 1 Subdivision	7.76 / 28.2	0.12	ABSENCE	ABSENCE	< 1
12/06/2021 13:49	S21-8123	Block 1 Lot 64, Buena Rosa 10 Subdivision	7.56 / 27.8	0.09	ABSENCE	ABSENCE	< 1
12/06/2021 15:43	S21-8124	Cistern Tank, SM Santa Rosa	8.11 / 27.2	2.28	ABSENCE	ABSENCE	< 1
12/06/2021 15:49	S21-8125	Admin Pantry, SM Santa Rosa	8.13 / 27.2	0.87	ABSENCE	ABSENCE	< 1
12/06/2021 15:16	S21-8126	Cistern Tank, Robinson's Mall	8.45 / 28.6	0.97	ABSENCE	ABSENCE	< 1
12/06/2021 15:21	S21-8127	Ilonggo, Robinson's Mall	8.47 / 26.1	0.21	ABSENCE	ABSENCE	< 1
12/06/2021 15:30	S21-8159	Water Pump, Metrogate Heritage Subd.	7.57 / 29.1	0.95	ABSENCE	ABSENCE	< 1
12/06/2021 15:41	S21-8160	Clubhouse, Metrogate Heritage Subd.	7.40 / 28.1	0.60	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis