

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : SANTA ROSA CITY HEALTH OFFICE I**

### SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5


ANALYSIS DATE(S) : 02/07/2022 – 02/18/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>							
02/07/2022 12:10	S22-0565	Laguna Wellfield 1	7.26 / 28.5	0.12	ABSENCE	ABSENCE	< 1
<b>BRGY. CAINGIN</b>							
02/08/2022 13:22	S22-0635	Water Pump, Block 57, Phase 1, Southville	7.83 / 30.6	1.05	ABSENCE	ABSENCE	< 1
02/08/2022 13:57	S22-0636	Block 25 Lot 7, Phase 3, Southville	7.74 / 30.5	0.84	ABSENCE	ABSENCE	< 1
02/08/2022 13:42	S22-0639	Block 2 Lot 16, Phase 8, Southville	7.40 / 28.9	0.09	ABSENCE	ABSENCE	< 1
02/08/2022 13:34	S22-0637	Southville Integrated Highschool	7.91 / 30.7	0.99	ABSENCE	ABSENCE	< 1
<b>BRGY. KANLURAN</b>							
02/08/2022 12:15	S22-0632	Block 18 Lot 2, Alfonso Homes I	7.34 / 29.1	0.06	ABSENCE	ABSENCE	< 1
02/08/2022 11:59	S22-0630	#621 Rizal Boulevard	7.36 / 29.1	0.05	ABSENCE	ABSENCE	< 1
<b>BRGY. MALUSAK</b>							
02/08/2022 11:54	S22-0631	Santa Rosa City Hall	7.41 / 29.4	0.06	ABSENCE	ABSENCE	< 1
02/08/2022 12:05	S22-0638	Drinking Fountain I, Central I Elementary	7.38 / 29.4	0.05	ABSENCE	ABSENCE	< 1
<b>BRGY. SINALHAN</b>							
02/08/2022 11:40	S22-0629	Block 8 Lot 16, Bayshore III	7.57 / 29.3	0.06	ABSENCE	ABSENCE	6


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. TAGAPO</b>							
02/17/2022 13:54	S22-0817	#60 31 JP Rizal Boulevard	7.82 / 26.9	< 0.02	ABSENCE	ABSENCE	42
02/17/2022 14:28	S22-0819	Block 1 Lot 18, Fairfield of Margana Subdivision	7.81 / 28.5	< 0.02	ABSENCE	ABSENCE	15
02/17/2022 14:41	S22-0827	Water Pump, Rosewood Homes I	7.79 / 28.9	< 0.02	ABSENCE	ABSENCE	20
02/17/2022 14:09	S22-0828	Block 3 Lot 31, Rosewood Homes I	7.82 / 28.4	< 0.02	ABSENCE	ABSENCE	15
02/18/2022 16:28	S22-0837	Block 2 Lot 26, Rosewood Homes II	7.97 / 28.7	0.06	ABSENCE	ABSENCE	< 1
02/17/2022 13:17	S22-0818	Pump House Eye Wash, Buena Rosa 1 Subdivision	7.50 / 27.8	0.14	ABSENCE	ABSENCE	2
02/17/2022 13:40	S22-0820	Block 1 Lot 64, Buena Rosa 10 Subdivision	7.85 / 29.7	0.07	ABSENCE	ABSENCE	< 1
02/17/2022 15:25	S22-0821	Cistern Tank, SM Santa Rosa	7.93 / 27.4	0.36	ABSENCE	ABSENCE	< 1
02/17/2022 15:31	S22-0822	Admin Pantry, SM Santa Rosa	7.88 / 27.6	0.51	ABSENCE	ABSENCE	< 1
02/17/2022 15:00	S22-0823	Cistern Tank, Robinson's Mall	8.12 / 28.7	0.78	ABSENCE	ABSENCE	< 1
02/17/2022 15:07	S22-0824	Ilonggo, Robinson's Mall	8.10 / 27.1	0.46	ABSENCE	ABSENCE	< 1
02/02/2022 10:20	S22-0548	Water Pump, Metrogate Heritage Subd.	7.60 / 27.9	0.60	ABSENCE	ABSENCE	< 1
02/02/2022 10:31	S22-0549	Clubhouse, Metrogate Heritage Subd.	7.61 / 28.1	0.54	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis