

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 22

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 10/06/2021 – 10/14/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
10/06/2021 11:33	S21-6949	Laguna Wellfield 1	7.22 / 28.6	0.95	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
10/12/2021 15:02	S21-7121	Water Pump, Block 57, Phase 1, Southville	-	1.54	ABSENCE	ABSENCE	< 1
10/12/2021 15:47	S21-7122	Block 25 Lot 7, Phase 3, Southville	-	1.09	ABSENCE	ABSENCE	< 1
10/12/2021 15:26	S21-7124	Block 2 Lot 16, Phase 8, Southville	-	0.12	ABSENCE	ABSENCE	< 1
10/12/2021 15:10	S21-7123	Southville Integrated Highschool	-	1.26	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN							
10/12/2021 14:10	S21-7117	Block 18 Lot 2, Alfonso Homes I	-	0.19	ABSENCE	ABSENCE	< 1
10/12/2021 13:58	S21-7116	#621 Rizal Boulevard	-	0.03	ABSENCE	ABSENCE	25
BRGY. MALUSAK							
10/12/2021 13:34	S21-7117	Santa Rosa City Hall	-	0.03	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN							
10/12/2021 13:16	S21-7115	Block 8 Lot 16, Bayshore III	-	0.03	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO							
10/11/2021 13:07	S21-7053	#6031 JP Rizal Boulevard	-	0.08	ABSENCE	ABSENCE	< 1
10/11/2021 13:46	S21-7055	Block 1 Lot 18, Fairfield of Margana Subdivision	-	0.26	ABSENCE	ABSENCE	< 1
10/11/2021 13:20	S21-7063	Water Pump, Rosewood Homes I	-	0.81	ABSENCE	ABSENCE	< 1
10/11/2021 13:27	S21-7064	Block 3 Lot 31, Rosewood Homes I	-	0.77	ABSENCE	ABSENCE	< 1
10/11/2021 14:07	S21-7065	Block 2 Lot 8, Rosewood Homes II	-	0.70	ABSENCE	ABSENCE	< 1
10/11/2021 12:33	S21-7054	Pump House Eye Wash, Buena Rosa 1 Subdivision	-	0.10	ABSENCE	ABSENCE	5
10/11/2021 12:56	S21-7056	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.10	ABSENCE	ABSENCE	< 1
10/11/2021 14:54	S21-7057	Cistern Tank, SM Santa Rosa	-	0.59	ABSENCE	ABSENCE	< 1
10/11/2021 15:01	S21-7058	Admin Pantry, SM Santa Rosa	-	0.59	ABSENCE	ABSENCE	< 1
10/11/2021 14:27	S21-7059	Cistern Tank, Robinson's Mall	-	0.41	ABSENCE	ABSENCE	< 1
10/11/2021 14:33	S21-7060	Sizzler's, Robinson's Mall	-	0.20	ABSENCE	ABSENCE	20
10/07/2021 08:40	S21-6994	Water Pump, Metrogate Heritage Subd.	7.60 / 27.0	0.40	ABSENCE	ABSENCE	< 1
10/07/2021 08:55	S21-6995	Clubhouse, Metrogate Heritage Subd.	7.58 / 27.6	0.45	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis