

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 48

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 04/05/2021 – 04/29/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)			
BRGY. BIÑAN							
04/20/2021 11:59	S21-3026	Laguna Wellfield 1	7.61 / 27.6	0.59	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
04/05/2021 15:15	S21-2479	#1354 Facundo Compound	7.40 / 28.9	0.11	ABSENCE	ABSENCE	< 1
04/08/2021 10:16	S21-2615	Clubhouse, South Hampton Residences	7.65 / 30.3	0.30	ABSENCE	ABSENCE	-
04/05/2021 11:25	S21-2407	Block 5 Lot 25, JB Village	7.58 / 27.2	0.31	ABSENCE	ABSENCE	< 1
04/27/2021 14:30	S21-3133	Cistern Tank, Waltermart Santa Rosa	7.45 / 30.0	0.12	ABSENCE	ABSENCE	< 1
04/27/2021 14:45	S21-3134	2 nd Floor faucet, Waltermart, Santa Rosa	7.48 / 28.6	0.08	ABSENCE	ABSENCE	< 1
BRGY. DILA							
04/05/2021 13:28	S21-2395	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.59 / 27.8	0.26	ABSENCE	ABSENCE	< 1
04/05/2021 13:39	S21-2396	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.55 / 27.6	0.20	ABSENCE	ABSENCE	< 1
04/05/2021 13:58	S21-2397	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.65 / 28.4	0.29	ABSENCE	ABSENCE	1
04/05/2021 14:11	S21-2398	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.60 / 28.4	0.26	ABSENCE	ABSENCE	< 1
04/08/2021 10:46	S21-2625	Clubhouse, Alabaster St., Villa Esmeralda	7.60 / 28.6	0.12	ABSENCE	ABSENCE	-
04/05/2021 14:15	S21-2399	Drinking Fountain, Dila Elementary	7.48 / 28.6	0.10	ABSENCE	ABSENCE	< 1
BRGY. DITA							
04/05/2021 14:29	S21-2400	Block 24 Lot 2, New Santa Rosa Homes	7.49 / 27.6	0.13	ABSENCE	ABSENCE	< 1
04/05/2021 14:38	S21-2401	Block 19 Lot 11, New Santa Rosa Homes	7.46 / 27.5	0.10	ABSENCE	ABSENCE	1
04/05/2021 12:40	S21-2402	Water Tank, SolCar Ville Subdivision	7.51 / 28.1	0.48	ABSENCE	ABSENCE	< 1
04/05/2021 12:55	S21-2403	Block 3 Lot 7, SolCar Ville Subdivision	7.50 / 27.6	0.37	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
04/05/2021 13:15	S21-2404	#1780, National Road	7.50 / 27.4	0.41	ABSENCE	ABSENCE	< 1
04/05/2021 12:31	S21-2410	R & B Ice Plant, Inc.	7.61 / 27.8	0.61	ABSENCE	ABSENCE	< 1
04/08/2021 12:53	S21-2616	Clubhouse, San Lorenzo Royale	7.44 / 29.6	0.10	ABSENCE	ABSENCE	-
BRGY. DON JOSE							
04/07/2021 11:17	S21-2575	Science High School, Phase 1, Laguna Bel-Air	7.44 / 31.2	0.25	ABSENCE	ABSENCE	< 1
04/07/2021 12:54	S21-2577	Church, Block 108, Phase 5, Laguna Bel-Air	7.65 / 30.7	0.22	ABSENCE	ABSENCE	< 1
04/07/2021 11:28	S21-2576	Block 34 Lot 59, Phase 1, Laguna Bel-Air	7.61 / 30.9	0.35	ABSENCE	ABSENCE	< 1
04/07/2021 11:50	S21-2581	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.51 / 30.6	0.18	ABSENCE	ABSENCE	2
04/07/2021 14:45	S21-2569	8001, Pump 1, Acacia St., Santa Rosa Village I	7.61 / 30.1	0.62	ABSENCE	ABSENCE	< 1
04/07/2021 15:01	S21-2570	Clubhouse, Phase 4B, Santa Rosa Village I	7.41 / 29.6	0.45	ABSENCE	ABSENCE	< 1
04/07/2021 14:32	S21-2571	Clubhouse, Santa Rosa Village II	7.65 / 30.3	0.30	ABSENCE	ABSENCE	< 1
04/07/2021 13:41	S21-2572	Pump 9 & 10, Santa Rosa Estates I	7.45 / 30.8	0.27	ABSENCE	ABSENCE	< 1
04/07/2021 13:57	S21-2573	Clubhouse, Santa Rosa Estates I	7.40 / 29.6	0.22	ABSENCE	ABSENCE	< 1
04/07/2021 13:14	S21-2582	Drinking Fountain, Don Jose National High School	7.44 / 29.7	0.35	ABSENCE	ABSENCE	< 1
04/07/2021 10:58	S21-2583	Block 29 Lot 4, Laguna Belair III	7.47 / 30.2	0.47	ABSENCE	ABSENCE	< 1
BRGY. MACABLING							
04/05/2021 12:06	S21-2493	Water Pump, Buena Rosa 9 Subdivision	7.44 / 28.9	0.36	ABSENCE	ABSENCE	< 1
04/05/2021 12:10	S21-2494	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	7.25 / 30.0	0.42	ABSENCE	ABSENCE	< 1
04/05/2021 11:48	S21-2488	Water Pump, Corinthian Subdivision	7.66 / 28.4	0.39	ABSENCE	ABSENCE	69
04/05/2021 11:54	S21-2489	Block 11 Lot 19, Corinthian Subdivision	7.42 / 30.2	0.69	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT							
04/05/2021 12:15	S21-2405	Clubhouse, Casan Residencia Subdivision	7.45 / 27.1	0.36	ABSENCE	ABSENCE	< 1
04/08/2021 11:49	S21-2617	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.55 / 30.7	0.22	ABSENCE	ABSENCE	-
04/08/2021 12:01	S21-2618	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.60 / 30.3	0.18	ABSENCE	ABSENCE	-
04/08/2021 11:23	S21-2621	Water Pump, Main Road, Phase 2, Terra Fortuna	7.60 / 29.6	0.05	ABSENCE	ABSENCE	-
04/08/2021 11:18	S21-2622	Block 11 Lot 16, Terra Fortuna	7.60 / 30.8	0.03	ABSENCE	ABSENCE	-
04/08/2021 12:15	S21-2619	Water Pump, 9999 W, Villa Las Casas	7.39 / 31.5	0.15	ABSENCE	ABSENCE	-
04/08/2021 12:38	S21-2620	Block 1 Lot 17, Villa Las Casas	7.46 / 30.5	0.10	ABSENCE	ABSENCE	-
04/05/2021 11:10	S21-2406	Drinking Fountain, Malitlit Elementary	7.60 / 26.1	0.39	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC							
04/21/2021 11:53	S21-3034	Water Pump, Villa Mercedes	-	0.10	ABSENCE	ABSENCE	2
04/21/2021 12:02	S21-3035	Block 2 Lot 1, Villa Mercedes	-	0.06	ABSENCE	ABSENCE	2
BRGY. PULONG STA. CRUZ							
04/08/2021 09:55	S21-2614	Lagatao Residence, Buklod Diwa	7.47 / 29.6	0.25	ABSENCE	ABSENCE	-
04/08/2021 13:24	S21-2623	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.50 / 29.6	0.20	ABSENCE	ABSENCE	-
04/08/2021 13:59	S21-2624	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.55 / 29.4	0.15	ABSENCE	ABSENCE	-
BRGY. SANTO DOMINGO							
04/07/2021 14:12	S21-2574	Clubhouse Santa Rosa Estates II	7.32 / 30.7	0.35	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric ; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 22

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 04/05/2021 – 04/23/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
04/20/2021 11:59	S21-3026	Laguna Wellfield 1	7.61 /27.6	0.59	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
04/21/2021 12:33	S21-3036	Water Pump, Block 57, Phase 1, Southville	-	1.09	ABSENCE	ABSENCE	< 1
04/21/2021 13:30	S21-3037	Block 25 Lot 7, Phase 3, Southville	-	1.10	ABSENCE	ABSENCE	1
04/21/2021 12:21	S21-3038	Southville Integrated Highschool	-	0.87	ABSENCE	ABSENCE	3
04/21/2021 13:09	S21-3039	Block 2 Lot 16, Phase 9, Southville	-	0.02	ABSENCE	ABSENCE	14
BRGY. KANLURAN							
04/21/2021 11:29	S21-3033	Block 18 Lot 2, Alfonso Homes I	-	0.04	ABSENCE	ABSENCE	4
04/21/2021 11:16	S21-3031	#621 Rizal Boulevard	-	0.03	ABSENCE	ABSENCE	4
BRGY. MALUSAK							
04/21/2021 11:07	S21-3032	Santa Rosa City Hall	-	< 0.02	ABSENCE	ABSENCE	20
BRGY. SINALHAN							
04/21/2021 10:38	S21-3030	Block 8 Lot 16, Bayshore III	-	0.03	ABSENCE	ABSENCE	15

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
04/05/2021 12:56	S21-2480	#60 31 JP Rizal Boulevard	7.48 / 29.1	0.68	ABSENCE	ABSENCE	15
04/05/2021 13:24	S21-2482	Block 1 Lot 18, Fairfield of Margana Subdivision	7.31 / 29.4	0.73	ABSENCE	ABSENCE	< 1
04/05/2021 13:06	S21-2490	Water Pump, Rosewood Homes I	7.65 / 28.3	0.75	ABSENCE	ABSENCE	< 1
04/05/2021 13:10	S21-2491	Block 3 Lot 31, Rosewood Homes I	7.16 / 31.3	0.45	ABSENCE	ABSENCE	< 1
04/05/2021 13:34	S21-2492	Block 4 Lot 1, Rosewood Homes II	7.28 / 29.6	0.52	ABSENCE	ABSENCE	< 1
04/05/2021 12:25	S21-2481	Eye wash, Buena Rosa 1 Subdivision	7.56 / 30.1	0.11	ABSENCE	ABSENCE	< 1
04/05/2021 12:41	S21-2483	Block 1 Lot 64, Buena Rosa 10 Subdivision	7.41 / 28.2	0.10	ABSENCE	ABSENCE	< 1
04/05/2021 14:51	S21-2484	Cistern Tank, SM Santa Rosa	7.70 / 29.2	0.71	ABSENCE	ABSENCE	< 1
04/05/2021 14:57	S21-2485	Admin Pantry, SM Santa Rosa	7.48 / 27.5	0.60	ABSENCE	ABSENCE	88
04/07/2021 14:12	S21-2564	Cistern Tank, Robinson's Mall	-	0.78	ABSENCE	ABSENCE	3
04/05/2021 13:57	S21-2487	Buko House, Robinson's Mall	7.48 / 28.7	0.04	ABSENCE	ABSENCE	81
04/05/2021 11:45	S21-2408	Water Pump, Metrogate Heritage Subd.	7.50 / 28.1	0.45	ABSENCE	ABSENCE	< 1
04/05/2021 11:59	S21-2409	Clubhouse, Metrogate Heritage Subd.	7.60 / 28.1	0.40	ABSENCE	ABSENCE	6

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis