

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 07/02/2021 – 07/23/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
07/23/2021 11:40	S21-5368	Laguna Wellfield 1	7.51 / 28.6	0.88	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
07/15/2021 11:34	S21-5206	Water Pump, Block 57, Phase 1, Southville	7.65 / 31.4	1.03	ABSENCE	ABSENCE	1
07/15/2021 12:24	S21-5207	Block 25 Lot 7, Phase 3, Southville	7.40 / 31.6	0.46	ABSENCE	ABSENCE	< 1
07/21/2021 13:48	S21-5283	Block 2 Lot 16, Phase 8, Southville	7.24 / 25.1	0.38	ABSENCE	ABSENCE	2
07/15/2021 11:12	S21-5208	Block 52 Lot 25, Southville	7.68 / 31.1	1.13	ABSENCE	ABSENCE	6
BRGY. KANLURAN							
07/21/2021 13:20	S21-5282	Gate Entrance, Alfonso Homes I	7.19 / 26.5	0.28	ABSENCE	ABSENCE	< 1
07/21/2021 13:48	S21-5283	#621 Rizal Boulevard	7.18 / 24.9	0.38	ABSENCE	ABSENCE	150
BRGY. MALUSAK							
07/21/2021 12:53	S21-5279	Santa Rosa City Hall	7.16 / 25.1	0.35	ABSENCE	ABSENCE	2
07/21/2021 13:01	S21-5280	Drinking Fountain I, Central I Elementary School	7.18 / 25.4	0.32	ABSENCE	ABSENCE	2
BRGY. SINALHAN							
07/21/2021 12:28	S21-5278	Block 8 Lot 16, Bayshore III	7.22 / 25.9	0.42	ABSENCE	ABSENCE	90

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
07/15/2021 14:34	S21-5212	#60 31 JP Rizal Boulevard	7.22 / 29.4	0.51	ABSENCE	ABSENCE	< 1
07/15/2021 15:08	S21-5214	Block 1 Lot 18, Fairfield of Margana Subdivision	7.52 / 30.2	0.94	ABSENCE	ABSENCE	< 1
07/15/2021 14:46	S21-5222	Water Pump, Rosewood Homes I	7.49 / 30.0	1.05	ABSENCE	ABSENCE	< 1
07/15/2021 14:51	S21-5223	Block 3 Lot 31, Rosewood Homes I	7.47 / 32.8	0.38	ABSENCE	ABSENCE	< 1
07/15/2021 15:18	S21-5224	Block 2 Lot 18, Rosewood Homes II	7.30 / 28.4	0.10	ABSENCE	ABSENCE	< 1
07/21/2021 11:52	S21-5277	Pump House Eye Wash, Buena Rosa 1 Subdivision	7.24 / 25.1	0.73	ABSENCE	ABSENCE	< 1
07/15/2021 14:25	S21-5215	Block 1 Lot 64, Buena Rosa 10 Subdivision	7.25 / 29.0	0.61	ABSENCE	ABSENCE	< 1
07/15/2021 16:11	S21-5216	Cistern Tank, SM Santa Rosa	7.50 / 28.3	0.33	ABSENCE	ABSENCE	2
07/15/2021 16:17	S21-5217	Admin Pantry, SM Santa Rosa	7.57 / 27.1	0.48	ABSENCE	ABSENCE	10
07/15/2021 15:44	S21-5218	Cistern Tank, Robinson's Mall	8.07 / 29.0	1.97	ABSENCE	ABSENCE	< 1
07/15/2021 15:50	S21-5219	Ilonggo, Robinson's Mall	8.01 / 26.5	1.57	ABSENCE	ABSENCE	< 1
07/13/2021 14:01	S21-5078	Water Pump, Metrogate Heritage Subd.	7.55 / 28.1	0.45	ABSENCE	ABSENCE	< 1
07/13/2021 14:18	S21-5079	Clubhouse, Metrogate Heritage Subd.	7.57 / 27.3	0.40	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 46

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 07/13/2021 – 07/25/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
07/23/2021 11:40	S21-5368	Laguna Wellfield 1	7.51 / 28.6	0.88	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
07/21/2021 11:26	S21-5276	#1354 Facundo Compound	7.14 / 24.9	0.38	ABSENCE	ABSENCE	1
07/19/2021 11:13	S21-5288	Clubhouse, South Hampton Residences	7.30 / 29.1	0.20	ABSENCE	ABSENCE	< 1
07/13/2021 13:18	S21-5077	Block 5 Lot 25, JB Village	7.45 / 27.6	0.30	ABSENCE	ABSENCE	5
07/19/2021 10:30	S21-5285	Cistern Tank, Waltermart Santa Rosa	7.61 / 28.6	0.15	ABSENCE	ABSENCE	< 1
07/19/2021 10:49	S21-5286	2 nd Floor faucet, Waltermart, Santa Rosa	7.60 / 28.4	0.13	ABSENCE	ABSENCE	1
BRGY. DILA							
07/13/2021 11:21	S21-5065	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.60 / 27.5	0.29	ABSENCE	ABSENCE	< 1
07/13/2021 11:38	S21-5066	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.45 / 28.6	0.20	ABSENCE	ABSENCE	< 1
07/13/2021 11:58	S21-5067	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.48 / 27.6	0.31	ABSENCE	ABSENCE	< 1
07/13/2021 12:20	S21-5068	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.51 / 27.0	0.18	ABSENCE	ABSENCE	< 1
07/19/2021 11:32	S21-5298	Clubhouse, Alabaster St., Villa Esmeralda	7.51 / 28.2	0.15	ABSENCE	ABSENCE	< 1
07/13/2021 10:29	S21-5069	Drinking Fountain, Dila Elementary	7.80 / 28.0	0.30	ABSENCE	ABSENCE	180
BRGY. DITA							
07/13/2021 10:40	S21-5070	Block 24 Lot 2, New Santa Rosa Homes	7.41 / 27.6	0.21	ABSENCE	ABSENCE	10
07/13/2021 10:55	S21-5071	Block 19 Lot 11, New Santa Rosa Homes	7.51 / 28.0	0.18	ABSENCE	ABSENCE	< 1
07/13/2021 10:10	S21-5072	Water Tank, SolCar Ville Subdivision	7.60 / 27.5	0.48	ABSENCE	ABSENCE	11
07/13/2021 10:18	S21-5073	Block 3 Lot 7, SolCar Ville Subdivision	7.65 / 28.0	0.50	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
07/13/2021 12:39	S21-5074	#1780, National Road	7.38 / 28.1	0.31	ABSENCE	ABSENCE	< 1
07/13/2021 13:29	S21-5080	R & B Ice Plant, Inc.	7.40 / 28.0	0.36	ABSENCE	ABSENCE	3
07/19/2021 11:50	S21-5289	Clubhouse, San Lorenzo Royale	7.60 / 28.7	0.30	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE							
07/22/2021 08:17	S21-5347	Science High School, Phase 1, Laguna Bel-Air	7.45 / 29.3	0.20	ABSENCE	ABSENCE	18
07/22/2021 09:19	S21-5349	Church, Block 108, Phase 5, Laguna Bel-Air	7.55 / 29.7	0.47	ABSENCE	ABSENCE	56
07/22/2021 08:34	S21-5348	Block 34 Lot 59, Phase 1, Laguna Bel-Air	7.61 / 29.7	0.30	ABSENCE	ABSENCE	16
07/22/2021 09:52	S21-5353	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.61 / 29.3	0.27	ABSENCE	ABSENCE	10
07/22/2021 12:16	S21-5341	8001, Pump 1, Acacia St., Santa Rosa Village I	7.61 / 28.1	0.37	ABSENCE	ABSENCE	27
07/22/2021 12:33	S21-5342	Clubhouse, Phase 4B, Santa Rosa Village I	7.55 / 28.7	0.32	ABSENCE	ABSENCE	20
07/22/2021 11:47	S21-5343	Clubhouse, Santa Rosa Village II	7.41 / 28.9	0.40	ABSENCE	ABSENCE	16
07/22/2021 10:42	S21-5344	Pump 9 & 10, Santa Rosa Estates I	7.43 / 28.7	0.37	ABSENCE	ABSENCE	200
07/22/2021 10:59	S21-5345	Clubhouse, Santa Rosa Estates I	7.60 / 29.1	0.24	ABSENCE	ABSENCE	30
07/22/2021 10:14	S21-5354	Drinking Fountain, Don Jose National High School	7.63 / 29.5	0.30	ABSENCE	ABSENCE	< 1
BRGY. MACABLING							
07/21/2021 14:29	S21-5284	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	7.28 / 25.5	0.82	ABSENCE	ABSENCE	1
07/15/2021 16:50	S21-5220	Water Pump, Corinthian Subdivision	7.26 / 27.2	0.81	ABSENCE	ABSENCE	16
07/15/2021 16:57	S21-5221	Block 11 Lot 19, Corinthian Subdivision	7.18 / 25.0	0.78	ABSENCE	ABSENCE	11
BRGY. MALITLIT							
07/13/2021 12:59	S21-5075	Clubhouse, Casan Residencia Subdivision	7.43 / 27.0	0.30	ABSENCE	ABSENCE	1
07/19/2021 13:27	S21-5290	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.47 / 29.6	0.37	ABSENCE	ABSENCE	< 1
07/19/2021 13:33	S21-5291	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.51 / 29.6	0.32	ABSENCE	ABSENCE	< 1
07/19/2021 12:14	S21-5294	Water Pump, Main Road, Phase 2, Terra Fortuna	7.55 / 28.3	0.10	ABSENCE	ABSENCE	< 1
07/19/2021 12:24	S21-5295	Block 11 Lot 16, Terra Fortuna	7.55 / 29.5	0.11	ABSENCE	ABSENCE	< 1
07/19/2021 12:43	S21-5292	Water Pump, 9999 W, Villa Las Casas	7.65 / 29.7	0.25	ABSENCE	ABSENCE	< 1
07/19/2021 13:01	S21-5293	Block 1 Lot 17, Villa Las Casas	7.60 / 27.3	0.23	ABSENCE	ABSENCE	< 1
07/13/2021 09:48	S21-5076	Drinking Fountain, Malitlit Elementary	7.45 / 28.6	0.36	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC							
07/15/2021 11:02	S21-5204	Water Pump, Villa Mercedes	7.51 / 30.8	0.04	ABSENCE	ABSENCE	82
07/15/2021 11:16	S21-5205	Block 2 Lot 1, Villa Mercedes	7.52 / 30.9	0.04	ABSENCE	ABSENCE	6
BRGY. PULONG STA. CRUZ							
07/19/2021 14:32	S21-5287	Lagatao Residence, Buklod Diwa	7.47 / 28.5	0.17	ABSENCE	ABSENCE	< 1
07/19/2021 14:07	S21-5296	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.47 / 29.3	0.20	ABSENCE	ABSENCE	< 1
07/19/2021 14:13	S21-5297	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.55 / 28.3	0.19	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO							
07/22/2021 11:20	S21-5346	Clubhouse Santa Rosa Estates II	7.63 / 29.3	0.25	ABSENCE	ABSENCE	20

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric ; **C** - Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.