

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S24-4454

**DATE/TIME SUBMITTED :** 08/08/2024 15:30

**DATE/TIME COLLECTION :** 08/08/2024 10:30

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** SOURCE, SANTA CRUZ SPORTS COMPLEX, BRGY. BUBUKAL SANTA CRUZ, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.46	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S24-4455

**DATE/TIME SUBMITTED** : 08/08/2024 15:30

**DATE/TIME COLLECTION** : 08/08/2024 10:54

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : OVAL SPORTS COMPLEX, BRGY. BUBUKAL, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.34	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S24-4449

**DATE/TIME SUBMITTED :** 08/08/2024 15:30

**DATE/TIME COLLECTION :** 08/08/2024 08:40

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** SOURCE, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.19	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S24-4450

**DATE/TIME SUBMITTED** : 08/08/2024 15:30

**DATE/TIME COLLECTION** : 08/08/2024 09:29

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVERRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.41	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna Water Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S24-4452

**DATE/TIME SUBMITTED :** 08/08/2024 15:30

**DATE/TIME COLLECTION :** 08/08/2024 09:12

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** CISTERN TANK, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.65	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S24-4451

**DATE/TIME SUBMITTED** : 08/08/2024 15:30

**DATE/TIME COLLECTION** : 08/08/2024 08:59

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : KITCHEN, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.34	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. AVDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna Water Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S24-4453

**DATE/TIME SUBMITTED** : 08/08/2024 15:30

**DATE/TIME COLLECTION** : 08/08/2024 09:18

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : COMFORT ROOM, PROVINCIAL CAPITOL, SANTA CRUZ CITY, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	08/08/2024	SBA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	08/08/2024	SBA
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	08/08/2024	SBA

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** <sup>A</sup> – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite

**DEVIATIONS:** No deviations noted on sample collection and submission.


**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


**STANDARD REFERENCE:** Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis