

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1855 Date Prepared : 06/28/2019
Sample Code : S19-2666
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 06/12/2019 13:43 Date/Time Submitted : 06/12/2019 18:48
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : SOURCE, AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Heterotrophic Plate Count	CFU/mL	38	500 (max.)	9215B. Pour Plate Method	06/12/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: **CFU** – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1856 Date Prepared : 06/28/2019
 Sample Code : S19-2667
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 06/12/2019 13:25 Date/Time Submitted : 06/12/2019 18:48
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Heterotrophic Plate Count	CFU/mL	14	500 (max.)	9215B. Pour Plate Method	06/12/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1857 Date Prepared : 06/28/2019
 Sample Code : S19-2668
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 06/12/2019 14:12 Date/Time Submitted : 06/12/2019 18:48
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA
 PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	06/12/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 6/28/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1858 Date Prepared : 06/28/2019
Sample Code : S19-2669
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 06/12/2019 14:26 Date/Time Submitted : 06/12/2019 18:48
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : LT CATO, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA
PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	06/12/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 6/24/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1859 Date Prepared : 06/28/2019
Sample Code : S19-2670
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 06/12/2019 14:14 Date/Time Submitted : 06/12/2019 18:48
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : HOSPITAL BUILDING, LAGUNA MEDICAL CENTER, LAGUNA, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/12/2019	JDE
Heterotrophic Plate Count	CFU/mL	7	500 (max.)	9215B. Pour Plate Method	06/12/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: **CFU** – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 6/28/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis